Carrier®

# Product Data

**AQUAZONE™**
**50VQP084-300**
**Vertical Large Capacity**
**Water Source Heat Pumps**
**with PURON® Refrigerant (R-410A)**
**50 Hz**

22 to 80 Nominal kW

AQUAZONE™



ASHRAE 90.1 COMPLIANT

CE

Puron®
the environmentally sound refrigerant

Single-package vertically mounted water source heat pumps (WSHPs) with electronic controls.

- Non-ozone depleting Puron refrigerant (R-410A)
- Performance certified to AHRI/ISO/ASHRAE 13256-1
- Wide application use with operating temperature range of –6.7 C to 48.9 C
- Dual refrigerant circuits for 2-stage operation
- High-efficiency scroll compressors
- Thermostatic expansion valve (TXV) provides efficient and reliable refrigerant flow
- High-static capability available
- Available mute package for quiet operation
- Available low temperature insulation to prevent condensation
- Easy service access
- CE Mark approval

# Features/Benefits

**Carrier's Aquazone™ large capacity units offer low cost, energy efficient solutions for all challenging water source heat pump applications.**

### Operating efficiency

Carrier's Aquazone large capacity vertical water source heat pumps are designed for quality and high performance over a lifetime of operation. Aquazone units offer cooling EERs (Energy Efficiency Ratio) to 6.7 and heating COPs (Coefficient of Performance) to 5.3.

Copyright 2010 Carrier Corporation

# Features/Benefits (cont)

Efficiencies stated are in accordance with standard conditions under ISO (International Organization for Standardization) Standard 13256-1 and provide among the highest ratings in the industry, exceeding ASHRAE (American Society of Heating, Refrigerating and Air Conditioning Engineers) 90.1 Energy Standards.

### High quality construction and testing

All units are manufactured to meet extensive quality control protocol from start to finish through an automated control system, which provides continuous monitoring of each unit and performs quality control checks as equipment progresses through the production process. Standard construction features of the Aquazone™ units include:

**Cabinet —** Standard unit fabrication consists of heavy gage galvanized sheet metal cabinet construction that provides maximum strength. Cabinet interior surfaces are lined with 13 mm thick, 24 kg/m$^3$ acoustic type insulation. Sheet metal surfaces are treated for maximum corrosion protection to ensure resilience for long term vitality. The condensate pan is coated with baked-on enamel finish and insulated.

**Compressor —** Aquazone large capacity units include dual high capacity scroll compressors. Compressor isolating springs are specially selected for each compressor size. The external isolation springs are mounted on an isolated railing system to minimize vibrations to the unit structure.

**Blower and motor assembly —** Belt driven centrifugal blowers are provided with all units to satisfy many air distribution applications. Optional motor speeds and sizes are available to provide high static capability. Aquazone blower motors are designed to operate at lower temperatures to help improve the reliability of the WSHP.

**Refrigeration/water circuit —** Units have a sealed refrigerant circuit including a scroll compressor. Refrigerant circuits are provided with a standard thermostatic expansion valve (TXV) for higher accuracy and performance. Also standard are a reversing valve (4-way valve), water-to-refrigerant coaxial (tube-in-tube) coil, and enhanced aluminum fin/rifled copper tube air-to-refrigerant heat exchanger coil.

**AHRI/ISO —** Carrier's Aquazone units have AHRI (Air Conditioning, Heating, and Refrigeration Institute)/ ISO, NRTL (Nationally Recognized Testing Lab), or ETL labels and are factory tested under normal operating conditions at nominal water flow rates. Quality assurance is provided via testing report cards shipped with each unit to indicate specific unit performance under cooling and heating modes of operation.

### Puron® refrigerant (R-410A)

Puron refrigerant (R-410A) is a non-chlorine based refrigerant. Puron refrigerant characteristics, compared to R-22, have:

- Binary and near azeotropic mixture of 50% R-32 and 50% R-125.
- Higher efficiencies (50 to 60% higher operating pressures).
- Non-ozone depleting potential and low global warming potential.
- Virtually no glide. Unlike other alternative refrigerants, the two components in Puron refrigerant have virtually the same leak rates. Therefore, refrigerant can be added if necessary without recovering the charge.

### Quiet operation

Fan motor insulation and compressor springs are provided for sound isolation, cabinets are fully insulated to reduce noise transmission, low speed blowers are utilized for quiet operation through reduced outlet air velocities, and air-to-refrigerant coils are designed for lower airflow coil face velocities.

### Design flexibility

Aquazone vertical units are available in four airflow patterns including top or front discharge with right or left return. Extended water temperature range between –6.7 C and 48.9 C offers maximum design flexibility for all applications. Water flow rates as low as 2.4 L/s per kW assist with selection from a various range of circulating pumps. Factory-installed options are offered to meet specific design requirements.

### Safe, reliable operation

Standard safety features for the refrigerant circuit include high-pressure switch and low-pressure sensor to detect loss of refrigerant. A low air temperature sensor safeguards against freezing. Equipment safety features include water loop temperature monitoring, voltage protection, water coil freeze protection, and standard electronic condensate overflow shutdown. All Aquazone safety features are tested at the factory to assure proper operation of all components and safety switches.

All components are carefully designed and selected for endurance, durability, and carefree day-to-day operation.

The Aquazone unit is shipped to provide internal and external equipment protection. Shipping supports are placed under the blower housing

# Table of contents


Features/Benefits . . . . . 1-4
Model Number Nomenclature . . . . . 5
AHRI/ISO Capacity Ratings . . . . . 5
Physical Data . . . . . 6
Options and Accessories . . . . . 7-9
Dimensions . . . . . 10,11
Selection Procedure . . . . . 12
Performance Data . . . . . 13-36
Electrical Data . . . . . 37
Typical Piping and Wiring . . . . . 38
Typical Control Wiring Schematics . . . . . 39-41
Application Data . . . . . 42-46
Guide Specifications . . . . . 47-49

and compressor feet. In addition, units are mounted on oversized pallets with lag bolts for sturdiness and maximum protection during transit.

## Ease of installation

The Aquazone™ unit is packaged for simple low cost handling, with minimal time required for installation. All units are pre-wired and factory charged with refrigerant. Water connections (FPT) and condensate drains (FPT) are anchored securely to the unit cabinet. High and low voltage knockouts are provided on all units.

## Simple maintenance and serviceability

The Aquazone WSHP units are constructed to provide ease of maintenance. Units have large removable panels for easy access. Additional panels are provided to access the blower and control box sections.

The blower housing assembly can be serviced without disconnecting ductwork from the dedicated blower access panel. Blower units are provided with permanently lubricated bearings for worry-free performance.

Electrical disconnection of the blower motor and control box is easily accomplished from quick disconnects on each component.

Easy removal of the control box from the unit provides access to all refrigeration components.

The refrigeration circuit is easily tested and serviced through the use of high and low pressure ports integral to the refrigeration circuit.

## Maximum control flexibility

Aquazone water source heat pumps provide reliable control operation using a standard microprocessor board with flexible alternatives for many direct digital control (DDC) applications including the Carrier Comfort Network® (CCN) and open protocol systems.

Carrier's Aquazone standard unit solid-state control system, the Complete C, provides control of the unit compressor, reversing valve, fan, safety features, and troubleshooting fault indication features. The Complete C control system is one of the most user friendly, low cost, and advanced control boards found in the WSHP industry. Many features are field selectable to provide the ultimate in field installation flexibility. The overall features of this standard control system include:

**75-va transformer** assists in accommodating accessory loads.

**Anti-short cycle timer** provides a minimum off time to prevent the unit from short cycling. The 5-minute timer energizes when the compressor is deenergized, resulting in a 5-minute delay before the unit can be restarted.

**Random start relay** ensures a random delay in energizing each different WSHP unit. This option minimizes peak electrical demand during start-up from different operating modes or after building power outages.

**High and low pressure refrigerant protection** safeguards against unreliable unit operation and prevents refrigerant from leaking.

**Condensate overflow sensor**, mounted to the drain pan, recognizes thirty continuous seconds of condensate pan overflow as a fault. When condensate pan liquid reaches an unacceptable level, unit is automatically deactivated and placed in a lockout condition.

**High and low voltage protection** safe guards against excessive or low voltage conditions.

**Automatic intelligent reset** automatically restarts unit 5 minutes after shutdown if the fault has cleared. Should a fault occur 3 times sequentially, lockout will occur.

**Accessory output** (24-v) is provided to cycle a motorized water valve or damper actuator with compressor in applications such as variable speed pumping arrangements.

**Performance Monitor (PM)** feature monitors water temperatures to warn when the heat pump is operating inefficiently or beyond typical operating range. Field selectable switch initiates a warning code on the unit display.

**Water coil freeze protection (selectable for water or anti-freeze)** field selectable switch for water and water/glycol solution systems initiates a fault when temperatures exceed the selected limit for 30 continuous seconds.

**Air coil freeze protection (check filter operation)** field selectable switch for assessing excessive filter pressure drop initiates a fault when temperatures exceed the selected limit for 30 continuous seconds.

**Alarm relay setting** is a selectable 24-v or pilot duty dry contact for providing activation of a remote alarm.

**Electric heat option** output provided on the controller for operating two stages of emergency electric heat.

**Service test mode with diagnostic LED (Light-emitting diode)** allows service personnel to check the operation of the WSHP and control system efficiently. Upon entering Test mode, time delays are sped up, and the Status LED will flash a code to indicate the last fault experienced for easy diagnosis. Based on the fault code flashed by the status LED, system diagnostics are assisted through the use of Carrier provided troubleshooting tables for easy reference to typical problems.

**LED visual output** indicates high pressure, low pressure, low voltage, high voltage, air/water freeze protection, condensate overflow, and control status on an LED panel.

**Open protocol for diverse control (LON controller)** option is ideal when building automation requires interoperability across diverse control platforms. This LONMark* compliant offering can operate as standalone or as a part of Local Operating Network (LON) via the LONWORKS* FTT-10 Free Topology communication network. Factory completed, pre-engineered applications specific to Aquazone water source heat pumps and digital wall sensors communicating over Sensor Link (S-Link) communication protocol completes a system of networked control.

**Humidity control** on Aquazone 50VQP units enables the units to provide very good latent capacity making them an excellent choice for controlling humidity within a zone in many applications. The latent capacity of the units can be increased based on zone conditions with either the use of fan speed control and a humidistat. The Deluxe D controls option provides fan speed control based on relative humidity and is an effective, low-cost means of controlling humidity.

### PremierLink™ controller adds reliability, efficiency, and simplification

The PremierLink direct digital controller can be ordered as a factory-installed option. Designed and manufactured exclusively by Carrier, the controller can be used to actively monitor and control all modes of operation as well as monitor the following diagnostics and features: unit number, zone temperature, zone set point, zone humidity set point, discharge air temperatures, fan status, stages of heating, stages of cooling, outdoor-air temperature, leaving-air temperature, leaving water

# Features/Benefits (cont)

temperature, alarm status, and alarm lockout condition.

This controller has a 38.4 kilobaud communications capability and is compatible with i-Vu® Open building automation system controls and CCN controls. The addition of the Carrier $CO_2$ sensor in the conditioned space provides ASHRAE 62-99 compliance and demand controlled ventilation (DCV). A DCV control strategy is especially beneficial for a water source heat pump system to minimize the energy utilized to condition ventilation air. In combination with energy efficient Aquazone units, DCV may be the most energy efficient approach ever developed for a water source heat pump system.

The PremierLink peer-to-peer, Internet ready communicating control is designed specifically for constant volume (CV) and variable volume and temperature (VVT®) applications. This comprehensive controls system allows water source heat pumps to be linked together to create a fully functional HVAC (heating, ventilation, and air conditioning) automation system.

*Registered trademark of Echelon Corporation.

# Model number nomenclature

**50VQP 168 B C C 9 0 3 A 1**

**50VQP** – Vertical Large Capacity Water Source Heat Pump with Puron® Refrigerant (R-410A)

**Unit Size**

| | |
|---|---|
| **084** | **192** |
| **096** | **240** |
| **120** | **300** |
| **150** | |
| **168** | |

**Airflow Configuration**

| | Return | Discharge |
|---|---|---|
| **B** – | Rear | Top |
| **F** – | Front | Top |
| **S** – | Rear | Front |
| **Z** – | Front | Rear |

**Controls**
**C** – Complete C Microprocessor Control
**D** – Deluxe D Microprocessor Control
**L** – Complete C with LON
**M** – Deluxe D with LON
**P** – Complete C with PremierLink™ Communicating Control

**Heat Exchanger Options**
**A** – Coated, Copper
**C** – Non-Coated, Copper
**J** – Coated, Cupronickel
**N** – Non-Coated, Cupronickel

**Operating Range and Sound Options**
**1** – Extended Range (-6.7 to 48.9 C)
**2** – Extended Range and Mute Package
**3** – Standard Range (15.6 to 35.0 C)
**4** – Standard Range and Mute Package

**Blower Drive Options**
**A** – Standard rpm/Standard Motor
**B** – Low rpm/Standard Motor
**C** – High rpm/Standard Motor
**E** – High rpm/Large Motor

**Packaging**
**3** – Export

**Revision**
**0** – Current Revision

**Voltage**
**9** – 380/420-3-50

LEGEND

**LON —** LonWorks Interface System

NOTES:
1. Standard cabinet is powder-painted.
2. 380/420 volt unit is wired for 380 volts, but can be field converted to 420 volts.
3. 25 mm return filter included.
4. 75-VA standard transformer included.

# AHRI/ISO capacity ratings

**50VQP UNITS — ASHRAE/AHRI/ISO 13256-1 RATINGS**

| 50VQP UNIT | WATER LOOP HEAT PUMP | | | | GROUND WATER HEAT PUMP | | | | GROUND LOOP HEAT PUMP | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | Cooling 30 C | | Heating 20 C | | Cooling 15 C | | Heating 10 C | | Cooling 25 C | | Heating 0°C | |
| | Capacity Watts | EER W/W | Capacity Watts | COP | Capacity Watts | EER W/W | Capacity Watts | COP | Capacity Watts | EER W/W | Capacity Watts | COP |
| **084** | 22,011 | 4.9 | 26,876 | 5.3 | 23,681 | 6.7 | 22,128 | 4.7 | 22,098 | 5.3 | 17,526 | 4.0 |
| **096** | 24,971 | 4.8 | 31,008 | 5.2 | 27,521 | 6.6 | 25,205 | 4.6 | 25,147 | 5.1 | 19,343 | 3.8 |
| **120** | 31,653 | 4.8 | 38,189 | 5.3 | 35,961 | 6.7 | 30,481 | 4.6 | 31,770 | 5.1 | 24,414 | 3.9 |
| **150** | 40,064 | 4.5 | 48,652 | 5.1 | 45,926 | 6.4 | 39,918 | 4.5 | 40,709 | 4.9 | 30,774 | 3.8 |
| **168** | 44,021 | 4.9 | 53,751 | 5.3 | 47,362 | 6.7 | 44,256 | 4.7 | 44,197 | 5.3 | 35,053 | 4.0 |
| **192** | 49,941 | 4.8 | 62,016 | 5.2 | 55,041 | 6.6 | 50,410 | 4.6 | 50,293 | 5.1 | 38,687 | 3.8 |
| **240** | 63,306 | 4.8 | 76,377 | 5.3 | 71,923 | 6.7 | 60,961 | 4.6 | 63,540 | 5.1 | 48,828 | 3.9 |
| **300** | 80,129 | 4.5 | 97,304 | 5.1 | 91,852 | 6.4 | 79,836 | 4.5 | 81,419 | 4.9 | 61,547 | 3.8 |

LEGEND

**COP** — Coefficient of Performance
**db** — Dry Bulb
**EER** — Energy Efficiency Ratio
**wb** — Wet Bulb

NOTES:
1. Cooling capacities based upon 27 C db, 19 C wb entering air temperature.
2. Heating capacities based upon 20 C db, 15 C wb entering air temperature.
3. All ratings based upon operation at lower voltage of dual voltage rated models.

AHRI CERTIFIED™ www.ahridirectory.org
Water Source HP
ANSI/AHRI/ASHRAE/ISO13256-1

# Physical data

## 50VQP UNIT PHYSICAL DATA

| UNIT 50VQP | 084 | 096 | 120 | 150 | 168 | 192 | 240 | 300 |
|---|---|---|---|---|---|---|---|---|
| **COMPRESSOR QUANTITY** | Scroll (1) | | | | Scroll (2) | | | |
| **Factory Charge HFC-410A (kg) per circuit** | 3.97 | 4.42 | 6.35 | 7.03 | 3.97 | 4.42 | 6.35 | 7.03 |
| **BLOWER MOTOR** | | | | | | | | |
| **Blower Motor Quantity** | 1 | | | | | | | |
| **Standard Motor (kW)** | .75 | 1.12 | 1.49 | 2.24 | 1.49 | 2.24 | 3.73 | 3.73 |
| **Large Motor (kW)** | 1.12 | 1.49 | 2.24 | 3.73 | 2.24 | 3.73 | 5.60 | 5.60 |
| **BLOWER** | | | | | | | | |
| **No. of Blowers** | 1 | | | | 2 | | | |
| **Blower Wheel Size D x W (cm)** | 38.1 x 27.9 | | | 38.1 x 38.1 | 38.1 x 27.9 | | | 38.1 x 38.1 |
| **WATER CONNECTION SIZE** | | | | | | | | |
| **FPT (in.) [mm]** | 1-1/2 [38.1] | | | 2 [50.8] | | | | 2-1/2 [63.5] |
| **COAX VOLUME** | | | | | | | | |
| **Volume (liters)** | 8.28 | | 9.37 | 13.11 | 18.29 | | 24.08 | 27.98 |
| **CONDENSATE CONNECTION SIZE** | | | | | | | | |
| **FPT (in.) [mm]** | 1 [25.4] | | | | | | | |
| **AIR COIL DATA** | | | | | | | | |
| **Air Coil Dimensions H x W (cm)** | 91.4 x 121.9 | | | | 91.4 x 121.9 | | | |
| **Air Coil Total Face Area (sq m)** | 1.11 | | | | 2.22 | | | |
| **Air Coil Tube Size (cm)** | 3/8 [0.953] | | | | | | | |
| **Air Coil Fin Spacing (fins per cm)** | 5.5 | | | 4.72 | 5.5 | | | 4.72 |
| **Air Coil Number of Rows** | 2 | | 3 | 4 | 2 | | 3 | 4 |
| **MISCELLANEOUS DATA** | | | | | | | | |
| **Filter Standard Throwaway (qty) (cm)** | (4) 45.74 x 63.5 x 2.5 | | | | (8) 45.74 x 63.5 x 2.5 | | | |
| **Weight - Operating (kg)** | 399 | | 422 | 435 | 725 | | 755 | 769 |
| **Weight - Packaged (kg)** | 406 | | 429 | 442 | 739 | | 769 | 782 |

LEGEND

**FPT —** Female Pipe Thread

NOTES:

1. All units have grommet and spring compressor mountings, and 2.2 cm and 3.5 cm electrical knockouts.
2. Use the lowest maximum pressure rating when multiple options are combined:

| OPTION | MAXIMUM PRESSURE (kPa) |
|---|---|
| **Base Unit** | 3100 |
| **Motorized Water Valve** | 2750 |
| **Internal Secondary Pump** | 999 |

# Options and accessories

| DESCRIPTION | FACTORY-INSTALLED OPTION | FIELD-INSTALLED ACCESSORY |
|---|---|---|
| Cupronickel Heat Exchangers | X | |
| Sound Attenuation Package (Mute Package) | X | |
| Extended Range | X | |
| High-Static Blower Drive Options | X | |
| Deluxe D Control System | X | |
| PremierLink™ Controller | X | |
| LONMark Compliant Controller | X | |
| Aquazone™ Thermostats | | X |
| Filters | X | X |
| Filter Rack | X | X |
| Fire-Rated Hoses | | X |
| Ball Valves | | X |
| Y Strainers | | X |
| Solenoid Valves | | X |
| Hose Kit Assemblies | | X |
| Remote Sensors (SPT, $CO_2$, Humidity Sensors) | | X |
| PremierLink Accessories | | X |

## Factory-installed options

**Cupronickel heat exchangers** are available for higher corrosion protection for applications such as open tower, geothermal, etc. Consult the water quality guidelines for proper application and selection of this option.

**Sound attenuation package (mute package)** is available for applications that require especially low noise levels. With this option, a double application of sound attenuating material is applied, access panels are double dampened with 13 mm thick density fiberglass insulation, and a unique application of special dampening material is applied to the curved portion of the blower. The mute package in combination with standard unit noise reduction features (i.e., as mentioned previously) provides sound levels and noise reduction to the highest degree.

**Extended range** units provide an insulated water circuit for the coaxial coil and refrigerant circuit to prevent condensation, and therefore potential dripping problems, in applications where the entering water temperature is beyond the normal operating range (less than 15.6 C).

**High-static blower drive options** provide maximum flexibility for the most challenging applications. Three static range motors are available in low, standard, and high rpm configurations. An optional large motor arrangement is available for high-static designs.

**Deluxe D control system** provides the same functions as the Complete C control system while incorporating additional flexibility and functions to include:

Thermostat input capabilities accommodate emergency shutdown mode and night setback with override (NSB) potential. Night setback from low temperature thermostat with 2-hour override is initiated by a momentary signal from the thermostat.

Compressor relay staging is used with dual stage units (units with 2 compressors and 2 Deluxe D controls) or in master/slave applications.

Boilerless electric heat control system allows automatic changeover to electric heat at low loop water temperature.

Intelligent reversing valve operation minimizes reversing valve operation for extended life and quiet operation.

Thermostat type select (Y, O or Y, W) provides ability to work and select heat pump or heat/cool thermostats (Y, W).

Reversing valve signal select (O or B) provides selection for heat pump O/B thermostats.

Multiple units on one thermostat/wall sensor provide communication for up to three heat pumps on one thermostat.

Boilerless changeover temperature provides selection of boilerless changeover temperature set point.

Accessory relays allow configuration for multiple applications including fan and compressor cycling, digital night setback (NSB), mechanical night setback, water valve operation, and outside air damper operation.

**PremierLink™ controller** is compatible with the Carrier Comfort Network® (CCN) and other building automation systems (BAS). This control is designed to allow users the access and ability to change factory-defined settings, thus expanding the function of the standard unit.

**LONMark compliant controller** contains the factory-loaded Aquazone water source heat pump application for an interoperable control solution.

**Filters** are available in 51 mm or 102 mm (MERV 8) sizes.

**Filter rack** is available to accomodate 25, 51, or 102 mm filters in place of the standard 25 mm return air filter to enhance the filtration system of the water source heat pump. The filter rack does not include filters.

## Field-installed accessories

**Carrier's line of Aquazone™ thermostats** are both attractive and multi-functional, accommodating stand-alone water source heat pump installations.

Programmable 7-day thermostat offers 2-stage heat, 2-stage cool, auto changeover, 7-day programmable with copy command, 4 settings per day, fully electronic, 24 vac, backlit LCD, keypad lockout, no batteries required, 5-minute compressor protection, NEVERLOST™ memory, 3 security levels, and temperature display in degrees F or C.

Programmable 7-day light-activated thermostat offers the same features as the 7-day programmable thermostat and

# Options and accessories (cont)

includes occupied comfort settings with lights on, unoccupied energy savings with lights off.

Programmable 7-day flush-mount thermostat offers the same features as the 7-day programmable thermostat and includes locking coverplate with tamper proof screws, flush to wall mount, holiday/vacation programming, set point limiting, dual point with adjustable deadband, O or B terminal, and optional wall or duct-mounted remote sensor.

Programmable 5-day thermostat offers 2-stage heat, 2-stage cool, auto changeover, 5-minute built-in compressor protection, locking cover included, temperature display in degrees F or C, keypad lockout, backlit display, 5-1-1 programming, O or B terminal, dual set point with adjustable deadband, configurable display, self-prompting program, and 4 settings per day.

Non-programmable thermostat offers 2 heat stages, 2 cool stages, auto changeover, 5-minute built in compressor protection, locking cover included, temperature display in degrees F or C, keypad lockout, large display, backlit display, O or B terminal, dual set point with adjustable deadband, and backplate with terminals.

**Filters** are available in 51 mm or 102 mm (MERV 8) sizes.

**Filter rack** is available to accomodate 25, 51, or 102 mm filters in place of the standard 25 mm return air filter to enhance the filtration system of the water source heat pump. The filter rack does not include filters.

**Fire-rated hoses** are 61 cm long and have a fixed MPT on one end and a swivel with an adapter on the other end. Hose kits are provided with both a supply and return hose and can be either stainless steel or galvanized. Five sizes are available ($1/2$, $3/4$, 1, $1\,1/4$, $1\,1/2$ in.).

NOTE: Hose kit connections are English sizes to match unit connections. Metric equivalents are 12.7, 19.0, 25.9, 31.8, and 38.1 mm.

**Ball valves (brass body)** are used for shutoff and balancing water flow and are available with memory, memory stop, and pressure temperature ports. Valves consist of UL-listed brass body, ball and stem type with Teflon* seats and seals. Five sizes are available ($1/2$, $3/4$, 1, $1\,1/4$, $1\,1/2$ in.).

NOTE: Brass valve connections are English sizes to match unit connections. Metric equivalents are 12.7, 19.0, 25.9, 31.8, and 38.1 mm.

**Y strainers (bronze body)** are "Y" type strainers with a brass cap. With a maximum operating pressure rating of 3103 kPa, the strainer screen is made of stainless steel. Strainers are available with blow down valves. Five sizes are available ($1/2$, $3/4$, 1, $1\,1/4$, $1\,1/2$ in.).

NOTE: Strainer connections are English sizes to match unit connections. Metric equivalents are 12.7, 19.0, 25.9, 31.8, and 38.1 mm.

**Solenoid valves (brass body)** offer 3.5 watt coil, 24 volt, 50/60 Hz, 740 amps inrush, and .312 amp holding. Valves operate slowly for quiet system application. Five sizes are available ($1/2$, $3/4$, 1, $1\,1/4$, $1\,1/2$ in.).

NOTE: Valve connections are English sizes to match unit connections. Metric equivalents are 12.7, 19.0, 25.9, 31.8, and 38.1 mm.

**Hose kit assemblies** provide all the necessary components to hook up a water-side system. Supply hose includes a ported ball valve with pressure temperature (P/T) plug ports, flexible stainless steel hose with swivel and nipple. Return hose includes a ball valve, preset automatic balancing valve (L/s) with two P/T ports, flexible stainless steel hose with a swivel and nipple, balancing valve, and low-pressure drop water control valve.

**Remote sensors** are available for Aquazone flush-mount thermostats and for wall (wired and wireless) or duct mounted applications.

LON wall sensors are available in 3 models: sensor only, sensor with status override indicator, and sensor with set point, status adjustment override, and digital LCD display.

**PremierLink™ accessories** are available for providing a fully integrated WSHP DDC system. Accessories include supply air temperature sensors (with override and/or setpoint adjustment), communicating room sensors, $CO_2$ sensors (for use in demand control ventilation), and linkage thermostats (to control multiple units from one thermostat).

*Teflon is a trademark of E. I. du Pont de Nemours and Company.

## AQUAZONE™ THERMOSTATS




**7-DAY PROGRAMMABLE/
LIGHT-ACTIVATED PROGRAMMABLE**




**7-DAY PROGRAMMABLE
FLUSH MOUNT**




**5-DAY PROGRAMMABLE/
NON-PROGRAMMABLE**

## LON WALL SENSORS



**SENSOR ONLY**



**SENSOR WITH OVERRIDE**



**SENSOR WITH SET POINT ADJUSTMENT,
OVERRIDE AND DIGITAL LCD**

# Dimensions

## 50VQP084-150 UNITS

### ALL CONFIGURATIONS REQUIRE SERVICE ACCESS AREA SHOWN BELOW




REAR RETURN TOP DISCHARGE




FRONT RETURN TOP DISCHARGE




REAR RETURN FRONT DISCHARGE




FRONT RETURN REAR DISCHARGE

LEGEND

**BSP** — Blower Service Panel
**CAP** — Control Access Panel
**CSP** — Compressor Service Panel
**MSP** — Motor Service Panel
**NRP** — Non-Removable Panel

NOTES:

1. All dimensions in centimeters.
2. Units require 0.9 m clearance for water connections, CAP, CSP, MSP, and BSP service access.
3. Overall cabinet height dimension does not include duct flange when in top discharge configuration.
4. Overall cabinet width dimension does not include filter rack and duct flange when on front or back discharge configuration.
5. Side service access must be 0.9 m on either side that connections are made. If no connections are made on a side, then service access can be 15 mm minimum.
6. While access to all removable panels is not required, installer should take care to comply with all building codes and allow adequate clearance for future field service.
7. Water inlet and water outlet connections are available on either side (left or right) of the unit. Two MPT plugs are shipped loose in a plastic bag tied to the water leg in front of the unit. Installer must plug water inlet/outlet side not being connected to.
8. Condensate drain is available on either side (left or right) of unit. Drain hose and drain connection will be tied inside the unit. Installer must untie the drain hose and connect to the condensate drain hole of installer's choice.
9. Electrical access is available on either side (left or right) of unit and is also available (left or right) in the front of the unit.
10. Overall depth — add 7.9 cm for 2.5 or 5 cm filter. Add 13 cm for 10 cm filter.

| CONNECTIONS | | 50VQP084-120 | 50VQP150 |
|---|---|---|---|
| ① | Water Inlet (See Note 7) | 1 1/2 in. FPT | 2 in. FPT |
| ② | Water Outlet (See Note 7) | 1 1/2 in. FPT | 2 in. FPT |
| ③ | Condensate Drain (See Note 8) | 1 in. FPT | 1 in. FPT |
| ④ | High Voltage Access (See Note 9) | 1 3/8 in. | 1 3/8 in. |
| ⑤ | Low Voltage Access (See Note 9) | 7/8 in. | 7/8 in. |

| UNIT 50VQP | OVERALL CABINET (cm) | | | DISCHARGE CONNECTIONS (cm) Duct Flange | | | WATER CONNECTIONS (cm) | | | | ELECTRICAL KNOCKOUTS (cm) | | | | | RETURN AIR CONNECTIONS (cm) (Using Return Air Opening) | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | A Depth | B Width | C Height | D Supply Width | E Supply Depth | F | K 1-Water Inlet | L 1-Water Outlet | M 3-Condensate | N | O1 | O2 | P | Q | R | S Return Depth | T Return Height | U | V |
| **084-120** | 86.4 | 134.9 | 200.7 | 44.5 | 44.6 | 45.1 | 78.7 | 7.6 | 68.6 | 65.1 | 78.7 | 96.4 | 87.7 | 2.5 | 7.6 | 121.9 | 82.2 | 113.3 | 6.9 |
| **150** | 86.4 | 134.9 | 200.7 | 54.4 | 44.6 | 45.1 | 78.7 | 7.6 | 68.6 | 65.1 | 78.7 | 96.4 | 87.7 | 2.5 | 7.6 | 121.9 | 82.2 | 113.3 | 6.9 |

## 50VQP168-300 UNITS

### ALL CONFIGURATIONS REQUIRE SERVICE ACCESS AREA SHOWN BELOW




REAR RETURN TOP DISCHARGE




FRONT RETURN TOP DISCHARGE




REAR RETURN FRONT DISCHARGE




FRONT RETURN REAR DISCHARGE

LEGEND

**BSP** — Blower Service Panel
**CAP** — Control Access Panel
**CSP** — Compressor Service Panel
**MSP** — Motor Service Panel
**NRP** — Non-Removable Panel

NOTES:

1. All dimensions in centimeters.
2. Units require 91 cm clearance for water connections, CAP, CSP, MSP, and BSP service access.
3. Overall cabinet height dimension does not include duct flange when in top discharge configuration.
4. Overall cabinet width dimension does not include filter rack and duct flange when on front or back discharge configuration.
5. Side service access must be 91 cm on either side that connections are made. If no connections are made on a side, then service access can be 15 mm minimum.
6. While access to all removable panels is not required, installer should take care to comply with all building codes and allow adequate clearance for future field service.
7. Water inlet and water outlet connections are available on either side (left or right) of the unit. Two MPT plugs are shipped loose in a plastic bag tied to the water leg in front of the unit. Installer must plug water inlet/outlet side not being connected to.
8. Condensate drain is available on either side (left or right) of unit. Drain hose and drain connection will be tied inside the unit. Installer must untie the drain hose and connect to the condensate drain hole of installer's choice.
9. Electrical access is available on either side (left or right) of unit and is also available (left or right) in the front of the unit.
10. Overall depth — add 7.9 cm for 2.5 or 5 cm filter. Add 13 cm for 10 cm filter.

| | CONNECTIONS | 50VQP168-240 | 50VQP300 |
|---|---|---|---|
| 1 | Water Inlet (See Note 7) | 2 in. FPT | $2^{1}/_{2}$ in. FPT |
| 2 | Water Outlet (See Note 7) | 2 in. FPT | $2^{1}/_{2}$ in. FPT |
| 3 | Condensate Drain (See Note 8) | 1 in. FPT | 1 in. FPT |
| 4 | High Voltage Access (See Note 9) | $1^{3}/_{8}$ in. | $1^{3}/_{8}$ in. |
| 5 | Low Voltage Access (See Note 9) | $^{7}/_{8}$ in. | $^{7}/_{8}$ in. |

| UNIT 50VQP | OVERALL CABINET (cm) | | | DISCHARGE CONNECTIONS (cm) Duct Flange | | | | WATER CONNECTIONS (cm) | | | | ELECTRICAL KNOCKOUTS (cm) | | | | | RETURN AIR CONNECTIONS (cm) (Using Return Air Opening) | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | A Depth | B Width | C Height | D Supply Width | E Supply Depth | F | G | K 1-Water Inlet | L 2-Water Outlet | M 3-Condensate | N | O1 | O2 | P | Q | R | S Return Depth | T Return Height | U | V |
| **168-240** | 86.4 | 270.9 | 200.7 | 44.5 | 44.6 | 45.1 | 79.4 | 78.7 | 7.6 | 68.6 | 65.1 | 78.1 | 96.4 | 87.8 | 2.5 | 7.6 | 121.9 | 82.2 | 113.3 | 6.9 |
| **300** | 86.4 | 270.9 | 200.7 | 54.4 | 44.6 | 45.1 | 59.4 | 78.7 | 7.6 | 68.6 | 65.1 | 78.1 | 96.4 | 87.8 | 2.5 | 7.6 | 121.9 | 82.2 | 113.3 | 6.9 |

# Selection procedure (50VQP096 unit example)

**I Determine the actual cooling and heating loads at the desired dry bulb and wet bulb conditions.**

Assume cooling load at desired dry bulb 27 C and wet bulb 18 C conditions are as follows:

Given:

Total Cooling (TC). . . . . .27.5 kW

Sensible Cooling (SC) . . . . . .19.0 kW

Entering-Air Temperature db . . . . . 27 C

Entering-Air Temperature wb . . . . . 18 C

**II Determine the following design parameters.**

Entering water temperature, water flow rate (L/s), airflow (L/s), water flow pressure drop and design wet and dry bulb temperatures. Airflow should be between 40 and 60 L/s per kW. Unit water pressure drop should be kept as close as possible to each other to make water balancing easier. Enter the appropriate Performance Data tables and find the proper indicated water flow and water temperature.

For example:

Entering Water Temp . . . . . 30 C

Water Flow . . . . . 0.95 L/s

Airflow. . . . . 1000 L/s

**III Select a unit based on total cooling and total sensible cooling conditions. Unit selected should be closest to but not larger than the actual cooling load.**

Enter tables at the design water flow and water temperature. Read the total and sensible cooling capacities.

NOTE: Interpolation is permissible, extrapolation is not.

For example:

Enter the 50VQP096 Performance Table at design water flow and water temperature. Read Total Cooling, Sensible Cooling and Heat of Rejection capacities:

Total Cooling . . . . . .24.86 kW

Sensible Cooling . . . . . .17.73 kW

Heat of Rejection . . . . . .31.14 kW

NOTE: It is quite normal for water source heat pumps to be selected on cooling capacity only since the heating output is usually greater than the cooling capacity.

**IV Determine the correction factors associated with the variable factors of dry bulb and wet bulb using the Corrections Factor tables found in this book.**

Using the following formulas to determine the correction factors of dry bulb and wet bulb:

a) Corrected Total Cooling = tabulated total cooling x wet bulb correction x airflow correction.

b) Corrected Sensible Cooling = tabulated sensible cooling x wet/dry bulb correction x airflow correction.

**V Determine entering air and airflow correction using the Corrections Factor tables found in this book.**

The nominal airflow for the 50VQP096 is 1133 L/s. The design parameter is 1000 L/s.

1000/1133 = 88% of nominal airflow:

Use the 88% row in the Airflow Correction Table.

Using the following formulas to determine the correction factors of entering air and airflow correction:

| | | Table | | Ent Air | | Airflow | | Corrected |
|---|---|---|---|---|---|---|---|---|
| Corrected Total Cooling | = | 24.86 | x | 0.988 | x | 0.982 | = | 24.1 |
| Corrected Sensible Cooling | = | 17.73 | x | 1.064 | x | 0.940 | = | 17.7 |
| Corrected Heat of Rejection | = | 31.14 | x | 0.990 | x | 0.980 | = | 30.2 |

Compare the corrected capacities to the load requirements established in Step I. If the capacities are within 10% of the load requirements, the equipment is acceptable. It is better to undersize than oversize as undersizing improves humidity control, reduces sound levels and extends the life of the equipment.

**VI Water temperature rise calculation and assessment.**

Calculate the water temperature rise and assess the selection using the following calculation:

$$\text{Actual Temperature Rise} = \frac{\text{Correction of Heat of Rejection}}{\text{L/s} \times 4.16}$$

For example, using the Corrected Heat of Rejection from the last step:

$$\text{Actual Temperature Rise} = \frac{30.2}{0.95 \times 4.16} = 7.6 \text{ C}$$

If the units selected are not within 10% of the load calculations, review what effect changing the water flow rate, water temperature and/or airflow will have on the corrected capacities. If the desired capacity cannot be achieved, select the next larger or smaller unit and repeat Steps I through VI.

# Performance data

**50VQP084**

**991 L/s NOMINAL AIRFLOW HEATING AND COOLING**

| WATER/BRINE | | | COOLING — EAT 27/19 C | | | | | | HEATING — EAT 20 C | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EWT (C) | FLOW (l/s) | WPD* (kPA) | TC (kW) | SC (kW) | S/T Ratio | PI (kW) | HR (kW) | EER (W/W) | HC (kW) | PI (kW) | HE (kW) | LAT (C) | COP |
| –5 | 1.10 | 48.98 | Operation Not Recommended | | | | | | 15.53 | 4.48 | 11.04 | 31.9 | 3.5 |
| | 0.55 | 11.65 | 21.59 | 14.40 | 0.67 | 3.23 | 24.81 | 6.7 | 16.57 | 4.57 | 12.00 | 32.8 | 3.6 |
| 0 | 0.83 | 26.68 | 20.50 | 13.58 | 0.66 | 2.98 | 23.48 | 6.9 | 17.28 | 4.63 | 12.65 | 33.4 | 3.7 |
| | 1.10 | 45.09 | 19.86 | 13.12 | 0.66 | 2.86 | 22.72 | 6.9 | 17.67 | 4.66 | 13.01 | 33.8 | 3.8 |
| | 0.55 | 10.36 | 22.64 | 15.26 | 0.67 | 3.59 | 26.23 | 6.3 | 18.93 | 4.77 | 14.16 | 34.9 | 4.0 |
| 5 | 0.83 | 24.23 | 22.07 | 14.77 | 0.67 | 3.36 | 25.43 | 6.6 | 19.86 | 4.85 | 15.01 | 35.7 | 4.1 |
| | 1.10 | 41.19 | 21.68 | 14.46 | 0.67 | 3.25 | 24.92 | 6.7 | 20.37 | 4.89 | 15.48 | 36.2 | 4.2 |
| | 0.55 | 9.62 | 22.97 | 15.63 | 0.68 | 3.89 | 26.86 | 5.9 | 21.12 | 4.96 | 16.16 | 36.9 | 4.3 |
| 10 | 0.83 | 22.66 | 22.79 | 15.38 | 0.68 | 3.66 | 26.45 | 6.2 | 22.22 | 5.05 | 17.17 | 37.8 | 4.4 |
| | 1.10 | 38.87 | 22.59 | 15.20 | 0.67 | 3.55 | 26.14 | 6.4 | 22.83 | 5.10 | 17.73 | 38.4 | 4.5 |
| | 0.55 | 6.51 | 22.75 | 15.62 | 0.69 | 4.18 | 26.93 | 5.4 | 23.38 | 5.15 | 18.22 | 38.9 | 4.5 |
| 15 | 0.83 | 17.54 | 22.86 | 15.56 | 0.68 | 3.95 | 26.81 | 5.8 | 24.63 | 5.26 | 19.37 | 40.0 | 4.7 |
| | 1.10 | 31.65 | 22.83 | 15.48 | 0.68 | 3.83 | 26.66 | 6.0 | 25.31 | 5.32 | 20.00 | 40.6 | 4.8 |
| | 0.55 | 5.99 | 22.25 | 15.50 | 0.70 | 4.53 | 26.78 | 4.9 | 25.99 | 5.38 | 20.61 | 41.2 | 4.8 |
| 20 | 0.83 | 16.45 | 22.63 | 15.60 | 0.69 | 4.29 | 26.91 | 5.3 | 27.37 | 5.50 | 21.87 | 42.4 | 5.0 |
| | 1.10 | 30.11 | 22.75 | 15.61 | 0.69 | 4.17 | 26.92 | 5.5 | 28.11 | 5.57 | 22.55 | 43.1 | 5.1 |
| | 0.55 | 5.48 | 21.64 | 15.28 | 0.71 | 4.87 | 26.50 | 4.4 | 28.26 | 5.58 | 22.68 | 43.2 | 5.1 |
| 25 | 0.83 | 15.36 | 22.17 | 15.47 | 0.70 | 4.61 | 26.78 | 4.8 | 29.69 | 5.71 | 23.98 | 44.5 | 5.2 |
| | 1.10 | 28.57 | 22.40 | 15.54 | 0.69 | 4.48 | 26.89 | 5.0 | 30.43 | 5.78 | 24.65 | 45.1 | 5.3 |
| | 0.55 | 5.16 | 20.74 | 14.92 | 0.72 | 5.27 | 26.02 | 3.9 | 30.56 | 5.79 | 24.76 | 45.3 | 5.3 |
| 30 | 0.83 | 14.83 | 21.40 | 15.18 | 0.71 | 4.99 | 26.38 | 4.3 | 31.93 | 5.93 | 26.01 | 46.5 | 5.4 |
| | 1.10 | 27.82 | 21.70 | 15.29 | 0.70 | 4.85 | 26.55 | 4.5 | 32.61 | 6.00 | 26.61 | 47.1 | 5.4 |
| | 0.55 | 4.84 | 19.76 | 14.52 | 0.74 | 5.71 | 25.47 | 3.5 | | | | | |
| 35 | 0.83 | 14.31 | 20.46 | 14.81 | 0.72 | 5.39 | 25.85 | 3.8 | | | | | |
| | 1.10 | 27.08 | 20.91 | 14.94 | 0.71 | 5.24 | 26.04 | 4.0 | | | | | |
| | 0.55 | 4.52 | 18.74 | 14.14 | 0.75 | 6.21 | 24.96 | 3.0 | | | | | |
| 40 | 0.83 | 13.78 | 19.45 | 14.41 | 0.74 | 5.86 | 25.30 | 3.3 | Operation Not Recommended | | | | |
| | 1.10 | 26.33 | 19.69 | 14.50 | 0.74 | 5.69 | 25.49 | 3.5 | | | | | |
| | Operation Not Recommended | | | | | | | | | | | | |
| 45 | 0.83 | 13.26 | 18.39 | 14.01 | 0.76 | 6.41 | 24.80 | 2.9 | | | | | |
| | 1.10 | 25.58 | 18.73 | 14.14 | 0.75 | 6.22 | 24.95 | 3.0 | | | | | |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**COP** — Coefficient of Performance
**Cv** — Coefficient of Velocity
**db** — Dry Bulb
**EAT** — Entering Air Temperature (C)
**EER** — Energy Efficiency Ratio
**EWT** — Entering Water Temperature (C)
**HC** — Heating Capacity (kW)
**HE** — Heat of Extraction (kW)
**HR** — Heat of Rejection (kW)
**ISO** — International Standards Organization
**kW** — Total Power (kW)
**MOPD** — Maximum Opening Pressure Difference
**LAT** — Leaving Air Temperature (C)
**PI** — Power Input
**SC** — Sensible Cooling Capacity (kW)
**S/T** — Sensible/Total Ratio
**TC** — Total Cooling Capacity (kW)
**wb** — Wet Bulb
**WPD** — Water Pressure Differential

***WPD ADDER FOR MOTORIZED WATER VALVE, 50VQP084 UNIT (Cv = 37, MOPD = 1034 kPa)**

| L/s | WPD Adder (kPa) |
|---|---|
| **0.55** | 0.55 |
| **0.83** | 1.24 |
| **1.10** | 2.21 |

NOTES:
1. Interpolation is permissible; extrapolation is not.
2. All entering air conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
3. AHRI/ISO certified conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
4. Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
5. All performance data is based upon the lower voltage of dual voltage rated units.
6. Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
7. Operation below 4 C EWT is based upon a 15% methanol antifreeze solution.
8. Operation below 16 C EWT requires optional insulated water/refrigerant circuit.
9. See performance correction tables for operating conditions other than those listed above.
10. For operation in the shaded area when water is used in lieu of an antifreeze solution, the LWT (leaving water temperature) must be calculated. Flow must be maintained to a level so that the LWT is maintained above 5.6 C when the JW3 jumper is not clipped. Because the refrigerant temperature can potentially reach as low as 0° C with 4.4 C LWT, a nuisance cutout could occur due to the activation of the low temperature protection. The JW3 jumper should never be clipped for standard range equipment or systems without antifreeze.

# Performance data (cont)

**50VQP096**

**1133 L/s NOMINAL AIRFLOW HEATING AND COOLING**

| WATER/BRINE | | | COOLING — EAT 27/19 C | | | | | | HEATING — EAT 20 C | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EWT (C) | FLOW (l/s) | WPD* (kPA) | TC (kW) | SC (kW) | S/T Ratio | PI (kW) | HR (kW) | EER (W/W) | HC (kW) | PI (kW) | HE (kW) | LAT (C) | COP |
| –5 | 1.26 | 49.8 | Operation Not Recommended | | | | | | 18.05 | 5.54 | 12.51 | 33.3 | 3.3 |
| | 0.63 | 10.5 | 28.56 | 19.36 | 0.68 | 4.12 | 32.68 | 6.9 | 19.31 | 5.62 | 13.69 | 34.5 | 3.4 |
| 0 | 0.95 | 25.7 | 28.55 | 19.39 | 0.68 | 3.94 | 32.48 | 7.2 | 20.20 | 5.68 | 14.52 | 35.3 | 3.6 |
| | 1.26 | 45.3 | 28.46 | 19.38 | 0.68 | 3.86 | 32.32 | 7.4 | 20.70 | 5.71 | 14.99 | 35.7 | 3.6 |
| | 0.63 | 9.3 | 28.30 | 19.19 | 0.68 | 4.43 | 32.73 | 6.4 | 22.14 | 5.80 | 16.34 | 37.0 | 3.8 |
| 5 | 0.95 | 23.3 | 28.53 | 19.33 | 0.68 | 4.20 | 32.73 | 6.8 | 23.27 | 5.87 | 17.41 | 38.1 | 4.0 |
| | 1.26 | 40.9 | 28.58 | 19.37 | 0.68 | 4.10 | 32.67 | 7.0 | 23.91 | 5.90 | 18.00 | 38.7 | 4.0 |
| | 0.63 | 8.5 | 27.85 | 18.97 | 0.68 | 4.75 | 32.60 | 5.9 | 24.69 | 5.95 | 18.74 | 39.4 | 4.1 |
| 10 | 0.95 | 21.8 | 28.26 | 19.17 | 0.68 | 4.47 | 32.74 | 6.3 | 26.04 | 6.03 | 20.00 | 40.6 | 4.3 |
| | 1.26 | 38.6 | 28.41 | 19.25 | 0.68 | 4.35 | 32.76 | 6.5 | 26.78 | 6.08 | 20.71 | 41.3 | 4.4 |
| | 0.63 | 7.2 | 27.18 | 18.68 | 0.69 | 5.12 | 32.30 | 5.3 | 27.32 | 6.11 | 21.21 | 41.8 | 4.5 |
| 15 | 0.95 | 18.7 | 27.74 | 18.92 | 0.68 | 4.81 | 32.55 | 5.8 | 28.85 | 6.20 | 22.64 | 43.2 | 4.7 |
| | 1.26 | 33.5 | 27.98 | 19.03 | 0.68 | 4.66 | 32.64 | 6.0 | 29.69 | 6.25 | 23.43 | 44.0 | 4.7 |
| | 0.63 | 6.6 | 26.22 | 18.27 | 0.70 | 5.62 | 31.83 | 4.7 | 30.36 | 6.29 | 24.06 | 44.6 | 4.8 |
| 20 | 0.95 | 17.8 | 26.93 | 18.57 | 0.69 | 5.26 | 32.18 | 5.1 | 32.06 | 6.40 | 25.66 | 46.1 | 5.0 |
| | 1.26 | 32.1 | 27.25 | 18.70 | 0.69 | 5.09 | 32.33 | 5.4 | 32.97 | 6.46 | 26.52 | 47.0 | 5.1 |
| | 0.63 | 5.9 | 25.19 | 17.86 | 0.71 | 6.12 | 31.31 | 4.1 | 33.02 | 6.46 | 26.56 | 47.0 | 5.1 |
| 25 | 0.95 | 16.8 | 26.01 | 18.19 | 0.70 | 5.72 | 31.73 | 4.5 | 34.81 | 6.58 | 28.23 | 48.6 | 5.3 |
| | 1.26 | 30.7 | 26.39 | 18.35 | 0.70 | 5.53 | 31.92 | 4.8 | 35.75 | 6.64 | 29.11 | 49.5 | 5.4 |
| | 0.63 | 5.4 | 23.95 | 17.37 | 0.73 | 6.72 | 30.68 | 3.6 | 35.75 | 6.64 | 29.11 | 49.5 | 5.4 |
| 30 | 0.95 | 16.0 | 24.86 | 17.73 | 0.71 | 6.28 | 31.14 | 4.0 | 37.54 | 6.77 | 30.77 | 51.1 | 5.5 |
| | 1.26 | 29.7 | 25.29 | 17.90 | 0.71 | 6.07 | 31.36 | 4.2 | 38.46 | 6.84 | 31.62 | 51.9 | 5.6 |
| | 0.63 | 4.8 | 22.65 | 16.86 | 0.74 | 7.37 | 30.03 | 3.1 | | | | | |
| 35 | 0.95 | 15.3 | 23.62 | 17.24 | 0.73 | 6.89 | 30.51 | 3.4 | | | | | |
| | 1.26 | 28.7 | 24.23 | 17.43 | 0.72 | 6.66 | 30.75 | 3.6 | | | | | |
| | 0.63 | 4.3 | 21.27 | 16.31 | 0.77 | 8.09 | 29.35 | 2.6 | | | | | |
| 40 | 0.95 | 14.5 | 22.27 | 16.71 | 0.75 | 7.57 | 29.84 | 2.9 | Operation Not Recommended | | | | |
| | 1.26 | 27.7 | 22.61 | 16.85 | 0.74 | 7.31 | 30.08 | 3.1 | | | | | |
| | Operation Not Recommended | | | | | | | | | | | | |
| 45 | 0.95 | 13.7 | 20.79 | 16.12 | 0.78 | 8.34 | 29.13 | 2.5 | | | | | |
| | 1.26 | 26.7 | 21.30 | 16.33 | 0.77 | 8.07 | 29.37 | 2.6 | | | | | |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**COP** — Coefficient of Performance
**Cv** — Coefficient of Velocity
**db** — Dry Bulb
**EAT** — Entering Air Temperature (C)
**EER** — Energy Efficiency Ratio
**EWT** — Entering Water Temperature (C)
**HC** — Heating Capacity (kW)
**HE** — Heat of Extraction (kW)
**HR** — Heat of Rejection (kW)
**ISO** — International Standards Organization
**kW** — Total Power (kW)
**MOPD** — Maximum Opening Pressure Difference
**LAT** — Leaving Air Temperature (C)
**PI** — Power Input
**SC** — Sensible Cooling Capacity (kW)
**S/T** — Sensible/Total Ratio
**TC** — Total Cooling Capacity (kW)
**wb** — Wet Bulb
**WPD** — Water Pressure Differential

***WPD ADDER FOR MOTORIZED WATER VALVE, 50VQP096 UNIT (Cv = 37, MOPD = 1034 kPa)**

| L/s | WPD Adder (kPa) |
|---|---|
| **0.63** | 0.76 |
| **0.95** | 1.65 |
| **1.26** | 2.90 |

NOTES:
1. Interpolation is permissible; extrapolation is not.
2. All entering air conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
3. AHRI/ISO certified conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
4. Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
5. All performance data is based upon the lower voltage of dual voltage rated units.
6. Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
7. Operation below 4 C EWT is based upon a 15% methanol antifreeze solution.
8. Operation below 16 C EWT requires optional insulated water/refrigerant circuit.
9. See performance correction tables for operating conditions other than those listed above.
10. For operation in the shaded area when water is used in lieu of an antifreeze solution, the LWT (leaving water temperature) must be calculated. Flow must be maintained to a level so that the LWT is maintained above 5.6 C when the JW3 jumper is not clipped. Because the refrigerant temperature can potentially reach as low as 0° C with 4.4 C LWT, a nuisance cutout could occur due to the activation of the low temperature protection. The JW3 jumper should never be clipped for standard range equipment or systems without antifreeze.

## 50VQP120
### 1416 L/s NOMINAL AIRFLOW HEATING AND COOLING

| WATER/BRINE | | | COOLING — EAT 27/19 C | | | | | | HEATING — EAT 20 C | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EWT (C) | FLOW (l/s) | WPD* (kPA) | TC (kW) | SC (kW) | S/T Ratio | PI (kW) | HR (kW) | EER (W/W) | HC (kW) | PI (kW) | HE (kW) | LAT (C) | COP |
| –5 | 1.58 | 49.69 | Operation Not Recommended | | | | | | 21.82 | 6.42 | 15.40 | 31.6 | 3.4 |
| | 0.79 | 10.25 | 36.96 | 24.10 | 0.65 | 5.20 | 42.16 | 7.1 | 23.16 | 6.51 | 16.66 | 32.5 | 3.6 |
| 0 | 1.18 | 25.84 | 37.52 | 24.14 | 0.64 | 4.98 | 42.50 | 7.5 | 24.08 | 6.57 | 17.50 | 33.1 | 3.7 |
| | 1.58 | 45.83 | 37.73 | 24.08 | 0.64 | 4.88 | 42.60 | 7.7 | 24.58 | 6.61 | 17.97 | 33.4 | 3.7 |
| | 0.79 | 9.13 | 35.99 | 23.82 | 0.66 | 5.53 | 41.51 | 6.5 | 26.26 | 6.74 | 19.52 | 34.4 | 3.9 |
| 5 | 1.18 | 23.49 | 36.77 | 24.06 | 0.65 | 5.27 | 42.05 | 7.0 | 27.45 | 6.81 | 20.64 | 35.2 | 4.0 |
| | 1.58 | 41.97 | 37.11 | 24.13 | 0.65 | 5.16 | 42.27 | 7.2 | 28.11 | 6.85 | 21.26 | 35.6 | 4.1 |
| | 0.79 | 8.42 | 34.96 | 23.41 | 0.67 | 5.84 | 40.80 | 6.0 | 29.16 | 6.95 | 22.21 | 36.3 | 4.2 |
| 10 | 1.18 | 21.41 | 35.89 | 23.78 | 0.66 | 5.56 | 41.45 | 6.5 | 30.60 | 7.04 | 23.57 | 37.2 | 4.3 |
| | 1.58 | 39.81 | 36.32 | 23.94 | 0.66 | 5.43 | 41.75 | 6.7 | 31.41 | 7.09 | 24.32 | 37.7 | 4.4 |
| | 0.79 | 6.28 | 33.76 | 22.85 | 0.68 | 6.20 | 39.96 | 5.4 | 32.44 | 7.17 | 25.26 | 38.4 | 4.5 |
| 15 | 1.18 | 18.21 | 34.79 | 23.31 | 0.67 | 5.89 | 40.68 | 5.9 | 34.13 | 7.28 | 26.86 | 39.4 | 4.7 |
| | 1.58 | 34.30 | 35.28 | 23.52 | 0.67 | 5.75 | 41.03 | 6.1 | 35.07 | 7.33 | 27.74 | 40.0 | 4.8 |
| | 0.79 | 5.72 | 32.21 | 22.11 | 0.69 | 6.68 | 38.88 | 4.8 | 36.37 | 7.44 | 28.93 | 40.9 | 4.9 |
| 20 | 1.18 | 17.16 | 33.31 | 22.62 | 0.68 | 6.33 | 39.64 | 5.3 | 38.34 | 7.57 | 30.77 | 42.1 | 5.1 |
| | 1.58 | 32.71 | 33.85 | 22.87 | 0.68 | 6.17 | 40.02 | 5.5 | 39.43 | 7.64 | 31.78 | 42.8 | 5.2 |
| | 0.79 | 5.15 | 30.71 | 21.42 | 0.70 | 7.16 | 37.87 | 4.3 | 39.76 | 7.67 | 32.09 | 43.0 | 5.2 |
| 25 | 1.18 | 16.11 | 31.82 | 21.93 | 0.69 | 6.78 | 38.61 | 4.7 | 41.93 | 7.83 | 34.10 | 44.4 | 5.4 |
| | 1.58 | 31.12 | 32.38 | 22.19 | 0.69 | 6.60 | 38.98 | 4.9 | 43.11 | 7.92 | 35.19 | 45.1 | 5.4 |
| | 0.79 | 4.88 | 29.04 | 20.69 | 0.71 | 7.75 | 36.79 | 3.7 | 43.98 | 8.03 | 35.95 | 45.6 | 5.5 |
| 30 | 1.18 | 15.64 | 30.15 | 21.19 | 0.70 | 7.33 | 37.48 | 4.1 | 44.99 | 7.83 | 37.17 | 46.5 | 5.7 |
| | 1.58 | 30.22 | 30.71 | 21.45 | 0.70 | 7.13 | 37.85 | 4.3 | 45.55 | 7.74 | 37.82 | 46.9 | 5.9 |
| | 0.79 | 4.61 | 27.49 | 20.06 | 0.73 | 8.39 | 35.88 | 3.3 | | | | | |
| 35 | 1.18 | 15.17 | 28.56 | 20.50 | 0.72 | 7.93 | 36.50 | 3.6 | | | | | |
| | 1.58 | 29.33 | 29.29 | 20.74 | 0.71 | 7.71 | 36.83 | 3.8 | | | | | |
| | 0.79 | 4.34 | 26.03 | 19.53 | 0.75 | 9.11 | 35.14 | 2.9 | | | | | |
| 40 | 1.18 | 14.70 | 27.04 | 19.89 | 0.74 | 8.61 | 35.65 | 3.1 | Operation Not Recommended | | | | |
| | 1.58 | 28.44 | 27.40 | 20.03 | 0.73 | 8.37 | 35.93 | 3.3 | | | | | |
| | Operation Not Recommended | | | | | | | | | | | | |
| 45 | 1.18 | 14.23 | 25.52 | 19.36 | 0.76 | 9.40 | 34.92 | 2.7 | | | | | |
| | 1.58 | 27.54 | 26.01 | 19.52 | 0.75 | 9.13 | 35.14 | 2.8 | | | | | |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**COP** — Coefficient of Performance
**Cv** — Coefficient of Velocity
**db** — Dry Bulb
**EAT** — Entering Air Temperature (C)
**EER** — Energy Efficiency Ratio
**EWT** — Entering Water Temperature (C)
**HC** — Heating Capacity (kW)
**HE** — Heat of Extraction (kW)
**HR** — Heat of Rejection (kW)
**ISO** — International Standards Organization
**kW** — Total Power (kW)
**MOPD** — Maximum Opening Pressure Difference
**LAT** — Leaving Air Temperature (C)
**PI** — Power Input
**SC** — Sensible Cooling Capacity (kW)
**S/T** — Sensible/Total Ratio
**TC** — Total Cooling Capacity (kW)
**wb** — Wet Bulb
**WPD** — Water Pressure Differential

***WPD ADDER FOR MOTORIZED WATER VALVE, 50VQP120 UNIT (Cv = 37, MOPD = 1034 kPa)**

| L/s | WPD Adder (kPa) |
|---|---|
| **0.79** | 1.10 |
| **1.18** | 2.55 |
| **1.58** | 4.55 |

NOTES:
1. Interpolation is permissible; extrapolation is not.
2. All entering air conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
3. AHRI/ISO certified conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
4. Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
5. All performance data is based upon the lower voltage of dual voltage rated units.
6. Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
7. Operation below 4 C EWT is based upon a 15% methanol antifreeze solution.
8. Operation below 16 C EWT requires optional insulated water/refrigerant circuit.
9. See performance correction tables for operating conditions other than those listed above.
10. For operation in the shaded area when water is used in lieu of an antifreeze solution, the LWT (leaving water temperature) must be calculated. Flow must be maintained to a level so that the LWT is maintained above 5.6 C when the JW3 jumper is not clipped. Because the refrigerant temperature can potentially reach as low as 0° C with 4.4 C LWT, a nuisance cutout could occur due to the activation of the low temperature protection. The JW3 jumper should never be clipped for standard range equipment or systems without antifreeze.

# Performance data (cont)

**50VQP150**

**1770 L/s NOMINAL AIRFLOW HEATING AND COOLING**

| WATER/BRINE | | | COOLING — EAT 27/19 C | | | | | | HEATING — EAT 20 C | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EWT (C) | FLOW (l/s) | WPD* (kPA) | TC (kW) | SC (kW) | S/T Ratio | PI (kW) | HR (kW) | EER (W/W) | HC (kW) | PI (kW) | HE (kW) | LAT (C) | COP |
| –5 | 2.00 | 58.50 | Operation Not Recommended | | | | | | 28.12 | 8.52 | 19.60 | 31.8 | 3.3 |
| | 1.00 | 13.27 | 45.62 | 32.40 | 0.71 | 6.91 | 52.53 | 6.6 | 29.99 | 8.69 | 21.30 | 32.7 | 3.5 |
| 0 | 1.47 | 30.25 | 45.43 | 33.90 | 0.75 | 6.58 | 52.01 | 6.9 | 31.19 | 8.79 | 22.40 | 33.3 | 3.5 |
| | 2.00 | 53.80 | 45.12 | 34.78 | 0.77 | 6.39 | 51.51 | 7.1 | 31.93 | 8.86 | 23.08 | 33.7 | 3.6 |
| | 1.00 | 11.36 | 45.13 | 30.57 | 0.68 | 7.38 | 52.50 | 6.1 | 34.13 | 9.03 | 25.10 | 34.8 | 3.8 |
| 5 | 1.47 | 27.17 | 45.54 | 31.80 | 0.70 | 7.03 | 52.58 | 6.5 | 35.66 | 9.14 | 26.51 | 35.6 | 3.9 |
| | 2.00 | 49.10 | 45.61 | 32.57 | 0.71 | 6.85 | 52.45 | 6.7 | 36.60 | 9.21 | 27.38 | 36.1 | 4.0 |
| | 1.00 | 10.48 | 44.19 | 29.27 | 0.66 | 7.79 | 51.98 | 5.7 | 37.90 | 9.31 | 28.59 | 36.7 | 4.1 |
| 10 | 1.47 | 25.50 | 45.01 | 30.28 | 0.67 | 7.43 | 52.44 | 6.1 | 39.71 | 9.43 | 30.27 | 37.6 | 4.2 |
| | 2.00 | 46.44 | 45.34 | 30.91 | 0.68 | 7.24 | 52.58 | 6.3 | 40.81 | 9.51 | 31.30 | 38.2 | 4.3 |
| | 1.00 | 8.13 | 42.82 | 28.24 | 0.66 | 8.24 | 51.06 | 5.2 | 41.96 | 9.61 | 32.35 | 38.8 | 4.4 |
| 15 | 1.47 | 20.98 | 43.91 | 29.06 | 0.66 | 7.86 | 51.77 | 5.6 | 44.04 | 9.76 | 34.28 | 39.8 | 4.5 |
| | 2.00 | 39.27 | 44.43 | 29.59 | 0.67 | 7.66 | 52.09 | 5.8 | 45.30 | 9.85 | 35.45 | 40.5 | 4.6 |
| | 1.00 | 7.44 | 40.99 | 27.21 | 0.66 | 8.83 | 49.82 | 4.6 | 46.74 | 9.98 | 36.76 | 41.2 | 4.7 |
| 20 | 1.47 | 19.81 | 42.28 | 27.87 | 0.66 | 8.42 | 50.71 | 5.0 | 49.07 | 10.15 | 38.91 | 42.4 | 4.8 |
| | 2.00 | 37.67 | 42.96 | 28.29 | 0.66 | 8.20 | 51.16 | 5.2 | 50.47 | 10.26 | 40.21 | 43.1 | 4.9 |
| | 1.00 | 6.75 | 39.15 | 26.40 | 0.67 | 9.44 | 48.59 | 4.1 | 50.84 | 10.30 | 40.54 | 43.2 | 4.9 |
| 25 | 1.47 | 18.65 | 40.54 | 26.97 | 0.67 | 8.99 | 49.53 | 4.5 | 53.32 | 10.50 | 42.82 | 44.5 | 5.1 |
| | 2.00 | 36.06 | 41.30 | 27.32 | 0.66 | 8.75 | 50.04 | 4.7 | 54.79 | 10.63 | 44.15 | 45.2 | 5.2 |
| | 1.00 | 6.40 | 37.08 | 25.61 | 0.69 | 10.18 | 47.26 | 3.6 | 55.06 | 10.66 | 44.40 | 45.4 | 5.2 |
| 30 | 1.47 | 18.04 | 38.48 | 26.12 | 0.68 | 9.68 | 48.16 | 4.0 | 57.60 | 10.91 | 46.69 | 46.6 | 5.3 |
| | 2.00 | 35.05 | 39.27 | 26.42 | 0.67 | 9.42 | 48.68 | 4.2 | 59.05 | 11.07 | 47.98 | 47.3 | 5.3 |
| | 1.00 | 6.06 | 35.10 | 24.89 | 0.71 | 10.98 | 46.09 | 3.2 | | | | | |
| 35 | 1.47 | 17.44 | 36.44 | 25.37 | 0.70 | 10.43 | 46.87 | 3.5 | | | | | |
| | 2.00 | 34.05 | 37.45 | 25.65 | 0.68 | 10.14 | 47.35 | 3.7 | | | | | |
| | 1.00 | 5.71 | 33.27 | 24.21 | 0.73 | 11.90 | 45.16 | 2.8 | | | | | |
| 40 | 1.47 | 16.83 | 34.47 | 24.66 | 0.72 | 11.27 | 45.75 | 3.1 | Operation Not Recommended | | | | |
| | 2.00 | 33.04 | 34.97 | 24.84 | 0.71 | 10.95 | 46.14 | 3.2 | | | | | |
| | Operation Not Recommended | | | | | | | | | | | | |
| 45 | 1.47 | 16.23 | 32.62 | 23.96 | 0.73 | 12.28 | 44.90 | 2.7 | | | | | |
| | 2.00 | 32.03 | 33.24 | 24.20 | 0.73 | 11.91 | 45.15 | 2.8 | | | | | |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**COP** — Coefficient of Performance
**Cv** — Coefficient of Velocity
**db** — Dry Bulb
**EAT** — Entering Air Temperature (C)
**EER** — Energy Efficiency Ratio
**EWT** — Entering Water Temperature (C)
**HC** — Heating Capacity (kW)
**HE** — Heat of Extraction (kW)
**HR** — Heat of Rejection (kW)
**ISO** — International Standards Organization
**kW** — Total Power (kW)
**MOPD** — Maximum Opening Pressure Difference
**LAT** — Leaving Air Temperature (C)
**PI** — Power Input
**SC** — Sensible Cooling Capacity (kW)
**S/T** — Sensible/Total Ratio
**TC** — Total Cooling Capacity (kW)
**wb** — Wet Bulb
**WPD** — Water Pressure Differential

***WPD ADDER FOR MOTORIZED WATER VALVE, 50VQP150 UNIT (Cv = 57, MOPD = 1034 kPa)**

| L/s | WPD Adder (kPa) |
|---|---|
| **1.00** | 0.76 |
| **1.47** | 1.65 |
| **2.00** | 3.03 |

NOTES:
1. Interpolation is permissible; extrapolation is not.
2. All entering air conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
3. AHRI/ISO certified conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
4. Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
5. All performance data is based upon the lower voltage of dual voltage rated units.
6. Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
7. Operation below 4 C EWT is based upon a 15% methanol antifreeze solution.
8. Operation below 16 C EWT requires optional insulated water/refrigerant circuit.
9. See performance correction tables for operating conditions other than those listed above.
10. For operation in the shaded area when water is used in lieu of an antifreeze solution, the LWT (leaving water temperature) must be calculated. Flow must be maintained to a level so that the LWT is maintained above 5.6 C when the JW3 jumper is not clipped. Because the refrigerant temperature can potentially reach as low as 0° C with 4.4 C LWT, a nuisance cutout could occur due to the activation of the low temperature protection. The JW3 jumper should never be clipped for standard range equipment or systems without antifreeze.

## 50VQP168

### 1882 L/s NOMINAL AIRFLOW HEATING AND COOLING

| WATER/BRINE | | | COOLING — EAT 27/19 C | | | | | | HEATING — EAT 20 C | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EWT (C) | FLOW (l/s) | WPD* (kPA) | TC (kW) | SC (kW) | S/T Ratio | PI (kW) | HR (kW) | EER (W/W) | HC (kW) | PI (kW) | HE (kW) | LAT (C) | COP |
| –5 | 2.21 | 55.11 | Operation Not Recommended | | | | | | 31.06 | 8.97 | 22.09 | 31.9 | 3.5 |
| | 1.10 | 13.11 | 43.17 | 28.79 | 0.67 | 6.45 | 49.62 | 6.7 | 33.14 | 9.14 | 24.00 | 32.8 | 3.6 |
| 0 | 1.66 | 30.02 | 40.99 | 27.17 | 0.66 | 5.96 | 46.96 | 6.9 | 34.56 | 9.26 | 25.30 | 33.4 | 3.7 |
| | 2.21 | 50.72 | 39.72 | 26.25 | 0.66 | 5.72 | 45.45 | 6.9 | 35.35 | 9.33 | 26.02 | 33.8 | 3.8 |
| | 1.10 | 11.65 | 45.27 | 30.51 | 0.67 | 7.19 | 52.46 | 6.3 | 37.87 | 9.55 | 28.32 | 34.9 | 4.0 |
| 5 | 1.66 | 27.25 | 44.14 | 29.54 | 0.67 | 6.72 | 50.86 | 6.6 | 39.71 | 9.70 | 30.01 | 35.7 | 4.1 |
| | 2.21 | 46.34 | 43.35 | 28.92 | 0.67 | 6.49 | 49.85 | 6.7 | 40.74 | 9.78 | 30.96 | 36.2 | 4.2 |
| | 1.10 | 10.83 | 45.94 | 31.26 | 0.68 | 7.78 | 53.72 | 5.9 | 42.23 | 9.92 | 32.31 | 36.9 | 4.3 |
| 10 | 1.66 | 25.49 | 45.57 | 30.77 | 0.68 | 7.33 | 52.90 | 6.2 | 44.44 | 10.10 | 34.34 | 37.8 | 4.4 |
| | 2.21 | 43.73 | 45.18 | 30.40 | 0.67 | 7.10 | 52.28 | 6.4 | 45.65 | 10.20 | 35.45 | 38.4 | 4.5 |
| | 1.10 | 7.32 | 45.50 | 31.25 | 0.69 | 8.36 | 53.86 | 5.4 | 46.75 | 10.31 | 36.45 | 38.9 | 4.5 |
| 15 | 1.66 | 19.73 | 45.72 | 31.12 | 0.68 | 7.89 | 53.61 | 5.8 | 49.26 | 10.52 | 38.74 | 40.0 | 4.7 |
| | 2.21 | 35.61 | 45.66 | 30.95 | 0.68 | 7.67 | 53.33 | 6.0 | 50.63 | 10.63 | 40.00 | 40.6 | 4.8 |
| | 1.10 | 6.74 | 44.51 | 31.00 | 0.70 | 9.06 | 53.56 | 4.9 | 51.98 | 10.76 | 41.22 | 41.2 | 4.8 |
| 20 | 1.66 | 18.50 | 45.25 | 31.19 | 0.69 | 8.57 | 53.82 | 5.3 | 54.74 | 11.00 | 43.74 | 42.4 | 5.0 |
| | 2.21 | 33.87 | 45.50 | 31.21 | 0.69 | 8.34 | 53.84 | 5.5 | 56.22 | 11.13 | 45.09 | 43.1 | 5.1 |
| | 1.10 | 6.16 | 43.27 | 30.55 | 0.71 | 9.74 | 53.01 | 4.4 | 56.53 | 11.16 | 45.37 | 43.2 | 5.1 |
| 25 | 1.66 | 17.28 | 44.35 | 30.94 | 0.70 | 9.22 | 53.57 | 4.8 | 59.38 | 11.42 | 47.96 | 44.5 | 5.2 |
| | 2.21 | 32.14 | 44.80 | 31.08 | 0.69 | 8.97 | 53.77 | 5.0 | 60.86 | 11.56 | 49.30 | 45.1 | 5.3 |
| | 1.10 | 5.81 | 41.49 | 29.84 | 0.72 | 10.54 | 52.03 | 3.9 | 61.11 | 11.58 | 49.53 | 45.3 | 5.3 |
| 30 | 1.66 | 16.69 | 42.79 | 30.36 | 0.71 | 9.97 | 52.77 | 4.3 | 63.87 | 11.85 | 52.01 | 46.5 | 5.4 |
| | 2.21 | 31.30 | 43.40 | 30.59 | 0.70 | 9.70 | 53.10 | 4.5 | 65.22 | 12.00 | 53.23 | 47.1 | 5.4 |
| | 1.10 | 5.45 | 39.51 | 29.05 | 0.74 | 11.42 | 50.93 | 3.5 | | | | | |
| 35 | 1.66 | 16.10 | 40.91 | 29.61 | 0.72 | 10.79 | 51.70 | 3.8 | | | | | |
| | 2.21 | 30.46 | 41.81 | 29.88 | 0.71 | 10.49 | 52.09 | 4.0 | | | | | |
| | 1.10 | 5.09 | 37.49 | 28.27 | 0.75 | 12.43 | 49.91 | 3.0 | | | | | |
| 40 | 1.66 | 15.51 | 38.89 | 28.81 | 0.74 | 11.72 | 50.61 | 3.3 | Operation Not Recommended | | | | |
| | 2.21 | 29.62 | 39.37 | 29.00 | 0.74 | 11.38 | 50.98 | 3.5 | | | | | |
| | Operation Not Recommended | | | | | | | | | | | | |
| 45 | 1.66 | 14.91 | 36.77 | 28.02 | 0.76 | 12.83 | 49.60 | 2.9 | | | | | |
| | 2.21 | 28.78 | 37.47 | 28.27 | 0.75 | 12.44 | 49.91 | 3.0 | | | | | |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**COP** — Coefficient of Performance
**Cv** — Coefficient of Velocity
**db** — Dry Bulb
**EAT** — Entering Air Temperature (C)
**EER** — Energy Efficiency Ratio
**EWT** — Entering Water Temperature (C)
**HC** — Heating Capacity (kW)
**HE** — Heat of Extraction (kW)
**HR** — Heat of Rejection (kW)
**ISO** — International Standards Organization
**kW** — Total Power (kW)
**MOPD** — Maximum Opening Pressure Difference
**LAT** — Leaving Air Temperature (C)
**PI** — Power Input
**SC** — Sensible Cooling Capacity (kW)
**S/T** — Sensible/Total Ratio
**TC** — Total Cooling Capacity (kW)
**wb** — Wet Bulb
**WPD** — Water Pressure Differential

***WPD ADDER FOR MOTORIZED WATER VALVE, 50VQP168 UNIT (Cv = 37, MOPD = 1034 kPa)**

| L/s | WPD Adder (kPa) |
|---|---|
| **1.10** | 0.55 |
| **1.66** | 1.24 |
| **2.21** | 2.21 |

NOTES:
1. Interpolation is permissible; extrapolation is not.
2. All entering air conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
3. AHRI/ISO certified conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
4. Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
5. All performance data is based upon the lower voltage of dual voltage rated units.
6. Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
7. Operation below 4 C EWT is based upon a 15% methanol antifreeze solution.
8. Operation below 16 C EWT requires optional insulated water/refrigerant circuit.
9. See performance correction tables for operating conditions other than those listed above.
10. For operation in the shaded area when water is used in lieu of an antifreeze solution, the LWT (leaving water temperature) must be calculated. Flow must be maintained to a level so that the LWT is maintained above 5.6 C when the JW3 jumper is not clipped. Because the refrigerant temperature can potentially reach as low as 0° C with 4.4 C LWT, a nuisance cutout could occur due to the activation of the low temperature protection. The JW3 jumper should never be clipped for standard range equipment or systems without antifreeze.

# Performance data (cont)

**50VQP192**

**2265 L/s NOMINAL AIRFLOW HEATING AND COOLING**

| WATER/BRINE | | | COOLING — EAT 27/19 C | | | | | | HEATING — EAT 20 C | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EWT (C) | FLOW (l/s) | WPD* (kPA) | TC (kW) | SC (kW) | S/T Ratio | PI (kW) | HR (kW) | EER (W/W) | HC (kW) | PI (kW) | HE (kW) | LAT (C) | COP |
| –5 | 2.52 | 77.75 | Operation Not Recommended | | | | | | 34.61 | 10.35 | 24.25 | 31.5 | 3.3 |
| | 1.26 | 20.65 | 47.66 | 31.70 | 0.67 | 6.71 | 54.37 | 7.1 | 37.15 | 10.56 | 26.59 | 32.5 | 3.5 |
| 0 | 1.89 | 44.24 | 42.92 | 28.44 | 0.66 | 5.62 | 48.53 | 7.6 | 38.81 | 10.71 | 28.10 | 33.1 | 3.6 |
| | 2.52 | 71.32 | 40.32 | 26.67 | 0.66 | 5.07 | 45.39 | 7.9 | 39.72 | 10.79 | 28.94 | 33.5 | 3.7 |
| | 1.26 | 18.47 | 52.39 | 34.96 | 0.67 | 8.12 | 60.51 | 6.5 | 42.67 | 11.07 | 31.60 | 34.6 | 3.9 |
| 5 | 1.89 | 39.71 | 50.03 | 33.30 | 0.67 | 7.31 | 57.34 | 6.8 | 44.77 | 11.24 | 33.53 | 35.4 | 4.0 |
| | 2.52 | 64.90 | 48.42 | 32.19 | 0.66 | 6.86 | 55.29 | 7.1 | 45.93 | 11.34 | 34.59 | 35.9 | 4.1 |
| | 1.26 | 17.10 | 53.83 | 36.00 | 0.67 | 8.98 | 62.80 | 6.0 | 47.67 | 11.52 | 36.15 | 36.5 | 4.1 |
| 10 | 1.89 | 37.25 | 53.07 | 35.40 | 0.67 | 8.34 | 61.41 | 6.4 | 50.15 | 11.72 | 38.43 | 37.5 | 4.3 |
| | 2.52 | 61.60 | 52.29 | 34.84 | 0.67 | 7.98 | 60.27 | 6.6 | 51.53 | 11.83 | 39.70 | 38.0 | 4.4 |
| | 1.26 | 13.43 | 53.44 | 35.88 | 0.67 | 9.64 | 63.08 | 5.5 | 52.91 | 12.00 | 40.91 | 38.6 | 4.4 |
| 15 | 1.89 | 30.80 | 53.77 | 35.96 | 0.67 | 9.09 | 62.86 | 5.9 | 55.78 | 12.23 | 43.54 | 39.7 | 4.6 |
| | 2.52 | 52.78 | 53.62 | 35.81 | 0.67 | 8.80 | 62.42 | 6.1 | 57.36 | 12.36 | 45.00 | 40.3 | 4.6 |
| | 1.26 | 12.49 | 51.90 | 35.10 | 0.68 | 10.34 | 62.25 | 5.0 | 59.06 | 12.56 | 46.50 | 40.9 | 4.7 |
| 20 | 1.89 | 29.13 | 53.08 | 35.68 | 0.67 | 9.85 | 62.93 | 5.4 | 62.33 | 12.84 | 49.49 | 42.2 | 4.9 |
| | 2.52 | 50.45 | 53.48 | 35.86 | 0.67 | 9.59 | 63.07 | 5.6 | 64.12 | 12.99 | 51.13 | 42.9 | 4.9 |
| | 1.26 | 11.54 | 49.80 | 34.06 | 0.68 | 10.99 | 60.79 | 4.5 | 64.50 | 13.04 | 51.46 | 43.1 | 4.9 |
| 25 | 1.89 | 27.47 | 51.39 | 34.84 | 0.68 | 10.49 | 61.88 | 4.9 | 68.07 | 13.36 | 54.71 | 44.4 | 5.1 |
| | 2.52 | 48.13 | 52.09 | 35.19 | 0.68 | 10.24 | 62.33 | 5.1 | 70.00 | 13.54 | 56.46 | 45.2 | 5.2 |
| | 1.26 | 11.13 | 47.19 | 32.88 | 0.70 | 11.78 | 58.97 | 4.0 | 70.25 | 13.56 | 56.68 | 45.3 | 5.2 |
| 30 | 1.89 | 26.68 | 48.95 | 33.69 | 0.69 | 11.22 | 60.16 | 4.4 | 74.05 | 13.94 | 60.11 | 46.7 | 5.3 |
| | 2.52 | 47.13 | 49.81 | 34.10 | 0.68 | 10.95 | 60.76 | 4.5 | 76.07 | 14.15 | 61.92 | 47.5 | 5.4 |
| | 1.26 | 10.71 | 44.74 | 31.91 | 0.71 | 12.72 | 57.46 | 3.5 | | | | | |
| 35 | 1.89 | 25.89 | 46.42 | 32.57 | 0.70 | 12.04 | 58.46 | 3.9 | | | | | |
| | 2.52 | 46.14 | 47.59 | 32.96 | 0.69 | 11.73 | 59.04 | 4.1 | | | | | |
| | 1.26 | 10.30 | 42.68 | 31.35 | 0.73 | 13.92 | 56.60 | 3.1 | | | | | |
| 40 | 1.89 | 25.10 | 44.06 | 31.68 | 0.72 | 13.06 | 57.12 | 3.4 | Operation Not Recommended | | | | |
| | 2.52 | 45.14 | 44.59 | 31.86 | 0.71 | 12.68 | 57.53 | 3.5 | | | | | |
| | Operation Not Recommended | | | | | | | | | | | | |
| 45 | 1.89 | 24.32 | 42.11 | 31.32 | 0.74 | 14.43 | 56.53 | 2.9 | | | | | |
| | 2.52 | 44.15 | 42.67 | 31.35 | 0.73 | 13.94 | 56.61 | 3.1 | | | | | |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**COP** — Coefficient of Performance
**Cv** — Coefficient of Velocity
**db** — Dry Bulb
**EAT** — Entering Air Temperature (C)
**EER** — Energy Efficiency Ratio
**EWT** — Entering Water Temperature (C)
**HC** — Heating Capacity (kW)
**HE** — Heat of Extraction (kW)
**HR** — Heat of Rejection (kW)
**ISO** — International Standards Organization
**kW** — Total Power (kW)
**MOPD** — Maximum Opening Pressure Difference
**LAT** — Leaving Air Temperature (C)
**PI** — Power Input
**SC** — Sensible Cooling Capacity (kW)
**S/T** — Sensible/Total Ratio
**TC** — Total Cooling Capacity (kW)
**wb** — Wet Bulb
**WPD** — Water Pressure Differential

***WPD ADDER FOR MOTORIZED WATER VALVE, 50VQP192 UNIT (Cv = 37, MOPD = 1034 kPa)**

| L/s | WPD Adder (kPa) |
|---|---|
| **1.26** | 0.76 |
| **1.89** | 1.65 |
| **2.52** | 2.90 |

NOTES:
1. Interpolation is permissible; extrapolation is not.
2. All entering air conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
3. AHRI/ISO certified conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
4. Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
5. All performance data is based upon the lower voltage of dual voltage rated units.
6. Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
7. Operation below 4 C EWT is based upon a 15% methanol antifreeze solution.
8. Operation below 16 C EWT requires optional insulated water/refrigerant circuit.
9. See performance correction tables for operating conditions other than those listed above.
10. For operation in the shaded area when water is used in lieu of an antifreeze solution, the LWT (leaving water temperature) must be calculated. Flow must be maintained to a level so that the LWT is maintained above 5.6 C when the JW3 jumper is not clipped. Because the refrigerant temperature can potentially reach as low as 0° C with 4.4 C LWT, a nuisance cutout could occur due to the activation of the low temperature protection. The JW3 jumper should never be clipped for standard range equipment or systems without antifreeze.

## 50VQP240

### 2832 L/s NOMINAL AIRFLOW HEATING AND COOLING

| WATER/BRINE | | | COOLING — EAT 27/19 C | | | | | | HEATING — EAT 20 C | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EWT (C) | FLOW (l/s) | WPD* (kPA) | TC (kW) | SC (kW) | S/T Ratio | PI (kW) | HR (kW) | EER (W/W) | HC (kW) | PI (kW) | HE (kW) | LAT (C) | COP |
| –5 | 3.15 | 55.90 | Operation Not Recommended | | | | | | 43.64 | 12.84 | 30.80 | 31.6 | 3.4 |
| | 1.58 | 11.53 | 73.91 | 48.21 | 0.65 | 10.40 | 84.31 | 7.1 | 46.33 | 13.01 | 33.31 | 32.5 | 3.6 |
| 0 | 2.37 | 29.07 | 75.04 | 48.28 | 0.64 | 9.96 | 85.00 | 7.5 | 48.15 | 13.15 | 35.00 | 33.1 | 3.7 |
| | 3.15 | 51.55 | 75.46 | 48.16 | 0.64 | 9.75 | 85.21 | 7.7 | 49.17 | 13.22 | 35.95 | 33.4 | 3.7 |
| | 1.58 | 10.27 | 71.97 | 47.64 | 0.66 | 11.05 | 83.02 | 6.5 | 52.52 | 13.47 | 39.05 | 34.4 | 3.9 |
| 5 | 2.37 | 26.43 | 73.55 | 48.13 | 0.65 | 10.55 | 84.10 | 7.0 | 54.90 | 13.63 | 41.28 | 35.2 | 4.0 |
| | 3.15 | 47.21 | 74.23 | 48.26 | 0.65 | 10.31 | 84.54 | 7.2 | 56.23 | 13.71 | 42.52 | 35.6 | 4.1 |
| | 1.58 | 9.47 | 69.92 | 46.81 | 0.67 | 11.68 | 81.60 | 6.0 | 58.33 | 13.90 | 44.43 | 36.3 | 4.2 |
| 10 | 2.37 | 24.09 | 71.79 | 47.57 | 0.66 | 11.12 | 82.91 | 6.5 | 61.21 | 14.08 | 47.13 | 37.2 | 4.3 |
| | 3.15 | 44.78 | 72.65 | 47.87 | 0.66 | 10.86 | 83.51 | 6.7 | 62.81 | 14.17 | 48.64 | 37.7 | 4.4 |
| | 1.58 | 7.07 | 67.51 | 45.71 | 0.68 | 12.40 | 79.91 | 5.4 | 64.87 | 14.35 | 50.53 | 38.4 | 4.5 |
| 15 | 2.37 | 20.49 | 69.57 | 46.63 | 0.67 | 11.79 | 81.36 | 5.9 | 68.26 | 14.55 | 53.71 | 39.4 | 4.7 |
| | 3.15 | 38.58 | 70.56 | 47.04 | 0.67 | 11.50 | 82.05 | 6.1 | 70.14 | 14.67 | 55.47 | 40.0 | 4.8 |
| | 1.58 | 6.43 | 64.42 | 44.23 | 0.69 | 13.35 | 77.77 | 4.8 | 72.74 | 14.89 | 57.86 | 40.9 | 4.9 |
| 20 | 2.37 | 19.30 | 66.62 | 45.25 | 0.68 | 12.67 | 79.29 | 5.3 | 76.69 | 15.14 | 61.54 | 42.1 | 5.1 |
| | 3.15 | 36.80 | 67.70 | 45.74 | 0.68 | 12.34 | 80.04 | 5.5 | 78.85 | 15.29 | 63.56 | 42.8 | 5.2 |
| | 1.58 | 5.79 | 61.42 | 42.83 | 0.70 | 14.32 | 75.74 | 4.3 | 79.52 | 15.34 | 64.18 | 43.0 | 5.2 |
| 25 | 2.37 | 18.12 | 63.64 | 43.87 | 0.69 | 13.57 | 77.21 | 4.7 | 83.86 | 15.66 | 68.21 | 44.4 | 5.4 |
| | 3.15 | 35.01 | 64.75 | 44.39 | 0.69 | 13.21 | 77.96 | 4.9 | 86.22 | 15.84 | 70.38 | 45.1 | 5.4 |
| | 1.58 | 5.49 | 58.08 | 41.39 | 0.71 | 15.50 | 73.58 | 3.7 | 87.95 | 16.05 | 71.90 | 45.6 | 5.5 |
| 30 | 2.37 | 17.59 | 60.30 | 42.37 | 0.70 | 14.67 | 74.96 | 4.1 | 89.98 | 15.65 | 74.33 | 46.5 | 5.7 |
| | 3.15 | 34.00 | 61.43 | 42.89 | 0.70 | 14.27 | 75.69 | 4.3 | 91.11 | 15.47 | 75.64 | 46.9 | 5.9 |
| | 1.58 | 5.19 | 54.98 | 40.12 | 0.73 | 16.78 | 71.76 | 3.3 | | | | | |
| 35 | 2.37 | 17.06 | 57.12 | 41.01 | 0.72 | 15.87 | 72.99 | 3.6 | | | | | |
| | 3.15 | 33.00 | 58.59 | 41.48 | 0.71 | 15.43 | 73.66 | 3.8 | | | | | |
| | 1.58 | 4.88 | 52.06 | 39.05 | 0.75 | 18.23 | 70.29 | 2.9 | | | | | |
| 40 | 2.37 | 16.54 | 54.07 | 39.78 | 0.74 | 17.22 | 71.29 | 3.1 | Operation Not Recommended | | | | |
| | 3.15 | 31.99 | 54.79 | 40.05 | 0.73 | 16.74 | 71.87 | 3.3 | | | | | |
| | Operation Not Recommended | | | | | | | | | | | | |
| 45 | 2.37 | 16.01 | 51.05 | 38.73 | 0.76 | 18.80 | 69.85 | 2.7 | | | | | |
| | 3.15 | 30.98 | 52.02 | 39.04 | 0.75 | 18.26 | 70.28 | 2.8 | | | | | |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**COP** — Coefficient of Performance
**Cv** — Coefficient of Velocity
**db** — Dry Bulb
**EAT** — Entering Air Temperature (C)
**EER** — Energy Efficiency Ratio
**EWT** — Entering Water Temperature (C)
**HC** — Heating Capacity (kW)
**HE** — Heat of Extraction (kW)
**HR** — Heat of Rejection (kW)
**ISO** — International Standards Organization
**kW** — Total Power (kW)
**MOPD** — Maximum Opening Pressure Difference
**LAT** — Leaving Air Temperature (C)
**PI** — Power Input
**SC** — Sensible Cooling Capacity (kW)
**S/T** — Sensible/Total Ratio
**TC** — Total Cooling Capacity (kW)
**wb** — Wet Bulb
**WPD** — Water Pressure Differential

***WPD ADDER FOR MOTORIZED WATER VALVE, 50VQP240 UNIT (Cv = 37, MOPD = 1034 kPa)**

| L/s | WPD Adder (kPa) |
|---|---|
| **1.58** | 1.10 |
| **2.37** | 2.55 |
| **3.15** | 4.55 |

NOTES:
1. Interpolation is permissible; extrapolation is not.
2. All entering air conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
3. AHRI/ISO certified conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
4. Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
5. All performance data is based upon the lower voltage of dual voltage rated units.
6. Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
7. Operation below 4 C EWT is based upon a 15% methanol antifreeze solution.
8. Operation below 16 C EWT requires optional insulated water/refrigerant circuit.
9. See performance correction tables for operating conditions other than those listed above.
10. For operation in the shaded area when water is used in lieu of an antifreeze solution, the LWT (leaving water temperature) must be calculated. Flow must be maintained to a level so that the LWT is maintained above 5.6 C when the JW3 jumper is not clipped. Because the refrigerant temperature can potentially reach as low as 0° C with 4.4 C LWT, a nuisance cutout could occur due to the activation of the low temperature protection. The JW3 jumper should never be clipped for standard range equipment or systems without antifreeze.

# Performance data (cont)

**50VQP300**

**3540 L/s NOMINAL AIRFLOW HEATING AND COOLING**

| WATER/BRINE | | | COOLING — EAT 27/19 C | | | | | | HEATING — EAT 20 C | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| EWT (C) | FLOW (l/s) | WPD* (kPA) | TC (kW) | SC (kW) | S/T Ratio | PI (kW) | HR (kW) | EER (W/W) | HC (kW) | PI (kW) | HE (kW) | LAT (C) | COP |
| –5 | 4.00 | 65.99 | Operation Not Recommended | | | | | | 56.24 | 17.03 | 39.20 | 31.8 | 3.3 |
| | 2.00 | 14.97 | 91.23 | 64.80 | 0.71 | 13.83 | 105.06 | 6.6 | 59.99 | 17.38 | 42.61 | 32.7 | 3.5 |
| 0 | 2.94 | 34.12 | 90.87 | 67.80 | 0.75 | 13.15 | 104.02 | 6.9 | 62.39 | 17.59 | 44.80 | 33.3 | 3.5 |
| | 4.00 | 60.68 | 90.24 | 69.57 | 0.77 | 12.78 | 103.02 | 7.1 | 63.86 | 17.71 | 46.15 | 33.7 | 3.6 |
| | 2.00 | 12.82 | 90.25 | 61.13 | 0.68 | 14.76 | 105.01 | 6.1 | 68.26 | 18.06 | 50.20 | 34.8 | 3.8 |
| 5 | 2.94 | 30.65 | 91.09 | 63.61 | 0.70 | 14.07 | 105.16 | 6.5 | 71.32 | 18.29 | 53.03 | 35.6 | 3.9 |
| | 4.00 | 55.38 | 91.22 | 65.14 | 0.71 | 13.69 | 104.91 | 6.7 | 73.19 | 18.42 | 54.77 | 36.1 | 4.0 |
| | 2.00 | 11.82 | 88.38 | 58.54 | 0.66 | 15.59 | 103.97 | 5.7 | 75.80 | 18.61 | 57.18 | 36.7 | 4.1 |
| 10 | 2.94 | 28.76 | 90.02 | 60.55 | 0.67 | 14.87 | 104.89 | 6.1 | 79.41 | 18.87 | 60.54 | 37.6 | 4.2 |
| | 4.00 | 52.38 | 90.67 | 61.83 | 0.68 | 14.48 | 105.15 | 6.3 | 81.63 | 19.02 | 62.60 | 38.2 | 4.3 |
| | 2.00 | 9.17 | 85.64 | 56.49 | 0.66 | 16.48 | 102.13 | 5.2 | 83.93 | 19.23 | 64.70 | 38.8 | 4.4 |
| 15 | 2.94 | 23.67 | 87.82 | 58.13 | 0.66 | 15.73 | 103.55 | 5.6 | 88.07 | 19.52 | 68.55 | 39.8 | 4.5 |
| | 4.00 | 44.30 | 88.86 | 59.17 | 0.67 | 15.32 | 104.17 | 5.8 | 90.59 | 19.70 | 70.89 | 40.5 | 4.6 |
| | 2.00 | 8.39 | 81.98 | 54.42 | 0.66 | 17.67 | 99.64 | 4.6 | 93.47 | 19.96 | 73.51 | 41.2 | 4.7 |
| 20 | 2.94 | 22.35 | 84.57 | 55.75 | 0.66 | 16.84 | 101.41 | 5.0 | 98.14 | 20.31 | 77.83 | 42.4 | 4.8 |
| | 4.00 | 42.49 | 85.92 | 56.57 | 0.66 | 16.40 | 102.32 | 5.2 | 100.94 | 20.52 | 80.41 | 43.1 | 4.9 |
| | 2.00 | 7.61 | 78.31 | 52.80 | 0.67 | 18.87 | 97.18 | 4.1 | 101.68 | 20.60 | 81.09 | 43.2 | 4.9 |
| 25 | 2.94 | 21.03 | 81.08 | 53.95 | 0.67 | 17.98 | 99.06 | 4.5 | 106.65 | 21.01 | 85.64 | 44.5 | 5.1 |
| | 4.00 | 40.68 | 82.59 | 54.65 | 0.66 | 17.50 | 100.09 | 4.7 | 109.57 | 21.27 | 88.30 | 45.2 | 5.2 |
| | 2.00 | 7.22 | 74.16 | 51.21 | 0.69 | 20.35 | 94.52 | 3.6 | 110.12 | 21.32 | 88.80 | 45.4 | 5.2 |
| 30 | 2.94 | 20.35 | 76.96 | 52.24 | 0.68 | 19.36 | 96.32 | 4.0 | 115.20 | 21.82 | 93.38 | 46.6 | 5.3 |
| | 4.00 | 39.54 | 78.54 | 52.85 | 0.67 | 18.83 | 97.37 | 4.2 | 118.11 | 22.14 | 95.96 | 47.3 | 5.3 |
| | 2.00 | 6.83 | 70.21 | 49.78 | 0.71 | 21.97 | 92.18 | 3.2 | | | | | |
| 35 | 2.94 | 19.67 | 72.88 | 50.74 | 0.70 | 20.86 | 93.74 | 3.5 | | | | | |
| | 4.00 | 38.40 | 74.89 | 51.30 | 0.68 | 20.27 | 94.70 | 3.7 | | | | | |
| | 2.00 | 6.44 | 66.53 | 48.42 | 0.73 | 23.79 | 90.32 | 2.8 | | | | | |
| 40 | 2.94 | 18.99 | 68.94 | 49.32 | 0.72 | 22.55 | 91.49 | 3.1 | Operation Not Recommended | | | | |
| | 4.00 | 37.27 | 69.95 | 49.68 | 0.71 | 21.89 | 92.28 | 3.2 | | | | | |
| | Operation Not Recommended | | | | | | | | | | | | |
| 45 | 2.94 | 18.31 | 65.24 | 47.93 | 0.73 | 24.56 | 89.80 | 2.7 | | | | | |
| | 4.00 | 36.13 | 66.49 | 48.41 | 0.73 | 23.82 | 90.30 | 2.8 | | | | | |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**COP** — Coefficient of Performance
**Cv** — Coefficient of Velocity
**db** — Dry Bulb
**EAT** — Entering Air Temperature (C)
**EER** — Energy Efficiency Ratio
**EWT** — Entering Water Temperature (C)
**HC** — Heating Capacity (kW)
**HE** — Heat of Extraction (kW)
**HR** — Heat of Rejection (kW)
**ISO** — International Standards Organization
**kW** — Total Power (kW)
**MOPD** — Maximum Opening Pressure Difference
**LAT** — Leaving Air Temperature (C)
**PI** — Power Input
**SC** — Sensible Cooling Capacity (kW)
**S/T** — Sensible/Total Ratio
**TC** — Total Cooling Capacity (kW)
**wb** — Wet Bulb
**WPD** — Water Pressure Differential

| *WPD ADDER FOR MOTORIZED WATER VALVE, 50VQP240 UNIT (Cv = 57, MOPD = 1034 kPa) | |
|---|---|
| **L/s** | **WPD Adder (kPa)** |
| **2.00** | 0.76 |
| **2.94** | 1.65 |
| **4.00** | 3.03 |

NOTES:
1. Interpolation is permissible; extrapolation is not.
2. All entering air conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
3. AHRI/ISO certified conditions are 27 C DB and 19 C WB in cooling and 20 C DB in heating.
4. Table does not reflect fan or pump power corrections for AHRI/ISO conditions.
5. All performance data is based upon the lower voltage of dual voltage rated units.
6. Performance stated is at the rated power supply; performance may vary as the power supply varies from the rated.
7. Operation below 4 C EWT is based upon a 15% methanol antifreeze solution.
8. Operation below 16 C EWT requires optional insulated water/refrigerant circuit.
9. See performance correction tables for operating conditions other than those listed above.
10. For operation in the shaded area when water is used in lieu of an antifreeze solution, the LWT (leaving water temperature) must be calculated. Flow must be maintained to a level so that the LWT is maintained above 5.6 C when the JW3 jumper is not clipped. Because the refrigerant temperature can potentially reach as low as 0° C with 4.4 C LWT, a nuisance cutout could occur due to the activation of the low temperature protection. The JW3 jumper should never be clipped for standard range equipment or systems without antifreeze.

## AIRFLOW CORRECTION TABLE

| PERCENTAGE OF RATE AIRFLOW | COOLING | | | | HEATING | | |
|---|---|---|---|---|---|---|---|
| | TC | SC | kW | HR | HC | kW | HE |
| **75** | 0.957 | 0.868 | 0.944 | 0.954 | 0.960 | 1.045 | 0.938 |
| **81** | 0.970 | 0.901 | 0.957 | 0.967 | 0.971 | 1.027 | 0.956 |
| **88** | 0.982 | 0.940 | 0.971 | 0.980 | 0.983 | 1.015 | 0.974 |
| **94** | 0.991 | 0.970 | 0.985 | 0.990 | 0.991 | 1.007 | 0.987 |
| **100** | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 | 1.000 |
| **106** | 1.002 | 1.025 | 1.013 | 1.004 | 1.006 | 0.999 | 1.009 |
| **113** | 1.004 | 1.050 | 1.026 | 1.009 | 1.013 | 0.998 | 1.019 |
| **119** | 1.008 | 1.073 | 1.042 | 1.015 | 1.021 | 0.997 | 1.028 |
| **125** | 1.013 | 1.095 | 1.058 | 1.022 | 1.029 | 0.996 | 1.038 |

LEGEND

**HC** — Heating Capacity
**HE** — Heat of Extraction
**HR** — Heat of Rejection
**kW** — Total Power
**SC** — Sensible Cooling Capacity
**TC** — Total Cooling Capacity

## ENTERING AIR CORRECTION TABLE — HEATING

| EAT (db, C) | HC | kW | HE |
|---|---|---|---|
| **10.0** | 1.034 | 0.843 | 1.087 |
| **12.8** | 1.027 | 0.877 | 1.068 |
| **15.6** | 1.022 | 0.916 | 1.051 |
| **18.3** | 1.010 | 0.957 | 1.025 |
| **20.0** | 1.004 | 0.982 | 1.010 |
| **21.1** | 1.000 | 1.000 | 1.000 |
| **23.9** | 0.991 | 1.045 | 0.976 |
| **26.7** | 0.982 | 1.101 | 0.948 |

LEGEND

**db** — Dry Bulb
**EAT** — Entering Air Temperature
**HC** — Heating Capacity
**HE** — Heat of Extraction
**kW** — Total Power

## ENTERING AIR CORRECTION TABLE — COOLING

| EAT (wb, C) | TC | SENSIBLE COOLING CAPACITY MULTIPLIER, ENTERING (db, C) | | | | | | | | kW | HR |
|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 18.3 | 21.1 | 23.9 | 26.7 | 27.0 | 29.4 | 32.2 | 35.0 | | |
| **12.8** | 0.953 | 0.909 | * | * | * | * | * | * | * | 0.988 | 0.960 |
| **15.6** | 0.954 | 0.760 | 0.810 | 1.076 | 1.209 | 1.233 | * | * | * | 0.991 | 0.962 |
| **18.3** | 0.975 | — | 0.644 | 0.872 | 1.089 | 1.115 | 1.238 | * | * | 0.995 | 0.979 |
| **19.0** | 0.988 | — | 0.594 | 0.818 | 1.036 | 1.064 | 1.198 | * | * | 0.998 | 0.990 |
| **19.4** | 1.000 | — | 0.568 | 0.782 | 1.000 | 1.027 | 1.164 | 1.350 | 1.421 | 1.000 | 1.000 |
| **21.1** | 1.045 | — | — | 0.647 | 0.864 | 0.889 | 1.034 | 1.295 | 1.421 | 1.009 | 1.037 |
| **23.9** | 1.122 | — | — | — | 0.638 | 0.658 | 0.806 | 1.076 | 1.294 | 1.025 | 1.103 |

LEGEND

**AHRI** — Air Conditioning, Heating, and Refrigeration Institute
**ASHRAE** — American Society of Heating, Refrigerating and Air Conditioning Engineers
**db** — Dry Bulb
**EAT** — Entering Air Temperature
**HR** — Heat of Rejection
**ISO** — International Organization for Standardization
**kW** — Total Power
**TC** — Total Capacity
**wb** — Wet Bulb

*Sensible capacity equals total capacity.
NOTE: AHRI/ISO/ASHRAE 13256-1 uses entering air conditions of cooling - 80.6 F db/66.2 F wb, and heating - 68 F db/59 F wb entering air temperature.

# Performance data (cont)

**ANTIFREEZE CORRECTION TABLE**

| ANTIFREEZE TYPE | ANTIFREEZE PERCENTAGE | COOLING EWT 32 C | | | HEATING EWT –1 C | | WATER PRESSURE DROP, EWT –1 C |
|---|---|---|---|---|---|---|---|
| | | Total Capacity | Sensible Capacity | kW | Heating Capacity | kW | |
| Water | 0 | 1.000 | 1.000 | 1.000 | — | — | 1.00 |
| Propylene Glycol | 5 | 0.995 | 0.995 | 1.003 | 0.989 | 0.997 | 1.07 |
| | 15 | 0.986 | 0.986 | 1.009 | 0.968 | 0.990 | 1.21 |
| | 25 | 0.978 | 0.978 | 1.014 | 0.947 | 0.983 | 1.36 |
| Methanol | 5 | 0.997 | 0.997 | 1.002 | 0.989 | 0.997 | 1.07 |
| | 15 | 0.990 | 0.990 | 1.007 | 0.968 | 0.990 | 1.16 |
| | 25 | 0.982 | 0.982 | 1.012 | 0.949 | 0.984 | 1.22 |
| Ethanol | 5 | 0.998 | 0.998 | 1.002 | 0.981 | 0.994 | 1.14 |
| | 15 | 0.994 | 0.994 | 1.005 | 0.944 | 0.983 | 1.30 |
| | 25 | 0.986 | 0.986 | 1.009 | 0.917 | 0.974 | 1.36 |
| Ethylene Glycol | 5 | 0.998 | 0.998 | 1.002 | 0.993 | 0.998 | 1.04 |
| | 15 | 0.994 | 0.994 | 1.004 | 0.980 | 0.994 | 1.12 |
| | 25 | 0.988 | 0.988 | 1.008 | 0.966 | 0.990 | 1.20 |

LEGEND

**EWT —** Entering Water Temperature

## 50VQP084 BLOWER PERFORMANCE DATA

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 755.2 | BkW | — | — | 0.12 | 0.15 | 0.13 | 0.19 | 0.22 | 0.24 | 0.26 | 0.30 | 0.31 | 0.33 | 0.37 | 0.39 | — | — |
| | Sheave/Mtr | — | — | B | B | A | A | A | A | C | C | C | C | C | C | — | — |
| | RPM | — | — | 388 | 437 | 482 | 527 | 564 | 599 | 630 | 663 | 690 | 716 | 744 | 767 | — | — |
| | Turns Open | — | — | 3.5 | 1.5 | 5 | 3.5 | 2.5 | 1.5 | 5.5 | 4.5 | 3.5 | 2.5 | 2 | 1 | — | — |
| 802.4 | BkW | — | — | 0.13 | 0.16 | 0.15 | 0.20 | 0.24 | 0.25 | 0.28 | 0.32 | 0.34 | 0.36 | 0.40 | 0.42 | — | — |
| | Sheave/Mtr | — | — | B | B | A | A | A | A | C | C | C | C | C | C | — | — |
| | RPM | — | — | 392 | 440 | 485 | 529 | 566 | 601 | 633 | 666 | 693 | 720 | 747 | 771 | — | — |
| | Turns Open | — | — | 3 | 1.5 | 5 | 3.5 | 2 | 1.5 | 5.5 | 4.5 | 3 | 2.5 | 2 | 1 | — | — |
| 849.6 | BkW | — | — | 0.14 | 0.17 | 0.17 | 0.22 | 0.25 | 0.27 | 0.29 | 0.33 | 0.36 | 0.38 | 0.42 | — | — | — |
| | Sheave/Mtr | — | — | B | B | A | A | A | A | C | C | C | C | C | — | — | — |
| | RPM | — | — | 395 | 444 | 488 | 530 | 568 | 603 | 636 | 668 | 697 | 723 | 751 | — | — | — |
| | Turns Open | — | — | 2.5 | 1 | 5 | 3.5 | 2 | 1 | 5 | 4 | 3 | 2 | 1.5 | — | — | — |
| 896.8 | BkW | — | — | 0.15 | 0.18 | 0.19 | 0.23 | 0.27 | 0.28 | 0.31 | 0.35 | 0.38 | 0.41 | 0.45 | — | — | — |
| | Sheave/Mtr | — | — | B | B | A | A | A | C | C | C | C | C | C | — | — | — |
| | RPM | — | — | 399 | 447 | 491 | 532 | 571 | 606 | 639 | 671 | 700 | 727 | 754 | — | — | — |
| | Turns Open | — | — | 2.5 | 1 | 4.5 | 3 | 2 | 5.5 | 5 | 4 | 3 | 2 | 1.5 | — | — | — |
| 944.0 | BkW | — | 0.11 | 0.16 | 0.19 | 0.21 | 0.25 | 0.28 | 0.30 | 0.33 | 0.37 | 0.40 | 0.43 | 0.47 | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | C | C | C | C | C | C | — | — | — |
| | RPM | — | 352 | 403 | 450 | 493 | 534 | 573 | 608 | 641 | 673 | 703 | 730 | 757 | — | — | — |
| | Turns Open | — | 4.5 | 2.5 | 5.5 | 4.5 | 3 | 2 | 5.5 | 4.5 | 4 | 2.5 | 2 | 1.5 | — | — | — |
| 991.2 | BkW | — | 0.12 | 0.18 | 0.22 | 0.25 | 0.28 | 0.31 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | C | C | C | C | C | C | — | — | — |
| | RPM | — | 362 | 410 | 457 | 499 | 537 | 577 | 612 | 647 | 678 | 710 | 737 | 764 | — | — | — |
| | Turns Open | — | 4.5 | 2 | 5.5 | 4.5 | 3 | 1.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | — | — | — |
| 1038.4 | BkW | — | 0.17 | 0.21 | 0.24 | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | C | C | C | C | C | C | — | — | — |
| | RPM | — | 375 | 424 | 467 | 507 | 548 | 584 | 621 | 653 | 684 | 716 | 743 | 772 | — | — | — |
| | Turns Open | — | 4 | 2 | 5 | 4 | 2.5 | 1.5 | 5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | — | — | — |
| 1085.6 | BkW | — | 0.18 | 0.22 | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | — | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | C | C | C | C | C | — | — | — | — |
| | RPM | — | 387 | 435 | 476 | 518 | 555 | 590 | 627 | 659 | 692 | 721 | 751 | — | — | — | — |
| | Turns Open | — | 3.5 | 1.5 | 5 | 4 | 2.5 | 1.5 | 5 | 4 | 3 | 2 | 1.5 | — | — | — | — |
| 1132.8 | BkW | 0.18 | 0.22 | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.59 | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | C | C | C | C | C | — | — | — | — |
| | RPM | 353 | 403 | 446 | 485 | 527 | 563 | 600 | 633 | 665 | 697 | 726 | 756 | — | — | — | — |
| | Turns Open | 4..5 | 3 | 1.5 | 4.5 | 3.5 | 2.5 | 1 | 5 | 4 | 3 | 2 | 1.5 | — | — | — | — |
| 1180.0 | BkW | 0.21 | 0.23 | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.55 | 0.59 | 0.63 | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | C | C | C | C | C | — | — | — | — |
| | RPM | 362 | 411 | 452 | 495 | 532 | 567 | 604 | 636 | 670 | 700 | 729 | 759 | — | — | — | — |
| | Turns Open | 4 | 2.5 | 1 | 4.5 | 3.5 | 2 | 1 | 4.5 | 4 | 3 | 2 | 1 | — | — | — | — |
| 1227.2 | BkW | 0.22 | 0.25 | 0.32 | 0.36 | 0.40 | 0.43 | 0.47 | 0.51 | 0.55 | 0.58 | 0.62 | 0.66 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | C | C | C | C | C | C | — | — | — | — |
| | RPM | 377 | 420 | 460 | 500 | 536 | 570 | 606 | 638 | 671 | 701 | 729 | 759 | — | — | — | — |
| | Turns Open | 3.5 | 2 | 5.5 | 4 | 3 | 2 | 5.5 | 4.5 | 3.5 | 2.5 | 2 | 1 | — | — | — | — |
| 1274.4 | BkW | 0.25 | 0.28 | 0.32 | 0.36 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.59 | 0.63 | 0.67 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | C | C | C | C | C | C | — | — | — | — |
| | RPM | 381 | 423 | 463 | 504 | 539 | 576 | 609 | 641 | 674 | 703 | 734 | 762 | — | — | — | — |
| | Turns Open | 3.5 | 2 | 5.5 | 4 | 3 | 1.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | — | — | — | — |
| 1321.6 | BkW | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.48 | 0.52 | 0.55 | 0.59 | 0.63 | 0.67 | 0.70 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | C | C | C | C | C | C | — | — | — | — |
| | RPM | 390 | 431 | 474 | 510 | 545 | 581 | 613 | 647 | 677 | 706 | 737 | 764 | — | — | — | — |
| | Turns Open | 3 | 1.5 | 5 | 3.5 | 2.5 | 1.5 | 5.5 | 4 | 3.5 | 2.5 | 1.5 | 1 | — | — | — | — |
| 1368.8 | BkW | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.55 | 0.59 | 0.63 | 0.67 | 0.70 | 0.78 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | C | C | C | C | C | E | — | — | — | — |
| | RPM | 399 | 440 | 481 | 517 | 551 | 586 | 618 | 651 | 681 | 710 | 740 | 767 | — | — | — | — |
| | Turns Open | 2.5 | 1.5 | 5 | 3.5 | 2 | 1 | 5 | 4 | 3 | 2 | 1.5 | 1 | — | — | — | — |
| 1416.0 | BkW | 0.32 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.82 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | C | C | C | C | E | E | — | — | — | — |
| | RPM | 412 | 455 | 492 | 526 | 563 | 595 | 628 | 658 | 687 | 718 | 745 | 774 | — | — | — | — |
| | Turns Open | 2.5 | 1 | 4.5 | 3 | 2 | 1 | 5 | 4 | 3 | 2 | 1.5 | 1 | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**E** — High rpm/Large Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor, E = High rpm/Large Motor.

# Performance data (cont)

## 50VQP096 BLOWER PERFORMANCE DATA

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 849.6 | BkW | — | 0.10 | 0.14 | 0.17 | 0.17 | 0.22 | 0.25 | 0.27 | 0.29 | 0.33 | 0.36 | 0.38 | 0.42 | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — |
| | RPM | — | 343 | 395 | 444 | 488 | 530 | 568 | 603 | 636 | 668 | 697 | 723 | 751 | — | — | — |
| | Turns Open | — | 5 | 3 | 6 | 5 | 3.5 | 2.5 | 1.5 | 5 | 4 | 3 | 2.5 | 1.5 | — | — | — |
| 896.8 | BkW | — | 0.11 | 0.15 | 0.18 | 0.19 | 0.23 | 0.27 | 0.28 | 0.31 | 0.35 | 0.38 | 0.41 | 0.45 | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — |
| | RPM | — | 348 | 399 | 447 | 491 | 532 | 571 | 606 | 639 | 671 | 700 | 727 | 754 | — | — | — |
| | Turns Open | — | 4.5 | 3 | 6 | 5 | 3.5 | 2 | 1.5 | 5 | 4 | 3 | 2.5 | 1.5 | — | — | — |
| 944.0 | BkW | — | 0.11 | 0.16 | 0.19 | 0.21 | 0.25 | 0.28 | 0.30 | 0.33 | 0.37 | 0.40 | 0.43 | 0.47 | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — |
| | RPM | — | 352 | 403 | 450 | 493 | 534 | 573 | 608 | 641 | 673 | 703 | 730 | 757 | — | — | — |
| | Turns Open | — | 4.5 | 3 | 5.5 | 4.5 | 3 | 2 | 1 | 5 | 4 | 2.5 | 2 | 1.5 | — | — | — |
| 991.2 | BkW | — | 0.12 | 0.18 | 0.22 | 0.25 | 0.28 | 0.31 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — |
| | RPM | — | 362 | 410 | 457 | 499 | 537 | 577 | 612 | 647 | 678 | 710 | 737 | 764 | — | — | — |
| | Turns Open | — | 4 | 2.5 | 5.5 | 4.5 | 3 | 2 | 1 | 4.5 | 3.5 | 2.5 | 2 | 1 | — | — | — |
| 1038.4 | BkW | — | 0.17 | 0.21 | 0.24 | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | — | — | — |
| | Sheave/Mtr | — | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — |
| | RPM | — | 375 | 424 | 467 | 507 | 548 | 584 | 621 | 653 | 684 | 716 | 743 | 772 | — | — | — |
| | Turns Open | — | 4 | 2 | 5 | 4.5 | 3 | 1.5 | 1 | 4.5 | 3.5 | 2.5 | 2 | 1 | — | — | — |
| 1085.6 | BkW | 0.16 | 0.18 | 0.22 | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — | — |
| | RPM | 339 | 387 | 435 | 476 | 518 | 555 | 590 | 627 | 659 | 692 | 721 | 751 | — | — | — | — |
| | Turns Open | 5 | 3.5 | 6 | 5 | 4 | 2.5 | 1.5 | 5.5 | 4.5 | 3 | 2.5 | 1.5 | — | — | — | — |
| 1132.8 | BkW | 0.18 | 0.22 | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.59 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — | — |
| | RPM | 353 | 403 | 446 | 485 | 527 | 563 | 600 | 633 | 665 | 697 | 726 | 756 | — | — | — | — |
| | Turns Open | 4.5 | 3 | 6 | 5 | 3.5 | 2.5 | 1.5 | 5.5 | 4 | 3 | 2 | 1.5 | — | — | — | — |
| 1180.0 | BkW | 0.21 | 0.23 | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.55 | 0.59 | 0.63 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — | — |
| | RPM | 362 | 411 | 452 | 495 | 532 | 567 | 604 | 636 | 670 | 700 | 729 | 759 | — | — | — | — |
| | Turns Open | 4.0 | 2.5 | 5.5 | 4.5 | 3.5 | 2 | 1 | 5 | 4 | 3 | 2 | 1 | — | — | — | — |
| 1227.2 | BkW | 0.22 | 0.25 | 0.32 | 0.36 | 0.40 | 0.43 | 0.47 | 0.51 | 0.55 | 0.58 | 0.62 | 0.66 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — | — |
| | RPM | 377 | 420 | 460 | 500 | 536 | 570 | 606 | 638 | 671 | 701 | 729 | 759 | — | — | — | — |
| | Turns Open | 3.5 | 2 | 5.5 | 4.5 | 3 | 2 | 1 | 5 | 3.5 | 2.5 | 2 | 1 | — | — | — | — |
| 1274.4 | BkW | 0.25 | 0.28 | 0.32 | 0.36 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.59 | 0.63 | 0.67 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | C | — | — | — | — |
| | RPM | 381 | 423 | 463 | 504 | 539 | 576 | 609 | 641 | 674 | 703 | 734 | 762 | — | — | — | — |
| | Turns Open | 3.5 | 2 | 5 | 4 | 3 | 1.5 | 1 | 5 | 3.5 | 2.5 | 2 | 1 | — | — | — | — |
| 1321.6 | BkW | 0.25 | 0.29 | 0.33 | 0.37 | 0.40 | 0.48 | 0.52 | 0.55 | 0.59 | 0.63 | 0.67 | — | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | — | — | — | — | — |
| | RPM | 390 | 431 | 474 | 510 | 545 | 581 | 613 | 647 | 677 | 706 | 737 | — | — | — | — | — |
| | Turns Open | 3 | 2 | 5 | 4 | 3 | 1.5 | 1 | 4.5 | 3.5 | 2.5 | 2 | — | — | — | — | — |
| 1368.8 | BkW | 0.29 | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.55 | 0.59 | 0.63 | 0.67 | 0.70 | — | — | — | — | — |
| | Sheave/Mtr | B | A | A | A | A | A | C | C | C | C | C | — | — | — | — | — |
| | RPM | 399 | 440 | 481 | 517 | 551 | 586 | 618 | 651 | 681 | 710 | 740 | — | — | — | — | — |
| | Turns Open | 3 | 6 | 4.5 | 3.5 | 2.5 | 1.5 | 5.5 | 4.5 | 3 | 2.5 | 1.5 | — | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor.

## 50VQP096 BLOWER PERFORMANCE DATA (cont)

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 1416.0 | BkW | 0.32 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | — | — | — | — | — |
| | Sheave/Mtr | B | A | A | A | A | A | C | C | C | C | C | — | — | — | — | — |
| | RPM | 412 | 455 | 492 | 526 | 563 | 595 | 628 | 658 | 687 | 718 | 745 | — | — | — | — | — |
| | Turns Open | 2.5 | 5.5 | 4.5 | 3.5 | 2 | 1 | 5 | 4 | 3 | 2 | 1.5 | — | — | — | — | — |
| 1463.2 | BkW | 0.33 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.74 | 0.78 | — | — | — | — | — |
| | Sheave/Mtr | B | A | A | A | A | A | C | C | C | C | C | — | — | — | — | — |
| | RPM | 421 | 459 | 499 | 533 | 569 | 600 | 633 | 663 | 691 | 722 | 749 | — | — | — | — | — |
| | Turns Open | 2 | 5.5 | 4 | 3 | 2 | 1 | 5 | 4 | 3 | 2 | 1.5 | — | — | — | — | — |
| 1510.4 | BkW | 0.37 | 0.40 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.74 | 0.78 | 0.85 | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | C | C | C | — | — | — | — | — |
| | RPM | 441 | 478 | 513 | 549 | 581 | 614 | 644 | 672 | 703 | 730 | 759 | — | — | — | — | — |
| | Turns Open | 6 | 5 | 4 | 2.5 | 1.5 | 1 | 4.5 | 3.5 | 2.5 | 2 | 1.5 | — | — | — | — | — |
| 1557.6 | BkW | 0.40 | 0.48 | 0.52 | 0.55 | 0.62 | 0.67 | 0.70 | 0.74 | 0.78 | 0.85 | 0.92 | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | C | C | C | C | — | — | — | — | — |
| | RPM | 456 | 495 | 529 | 561 | 595 | 625 | 656 | 685 | 712 | 741 | 767 | — | — | — | — | — |
| | Turns Open | 5.5 | 4.5 | 3.5 | 2 | 1 | 5.5 | 4 | 3 | 2.5 | 2 | 1 | — | — | — | — | — |
| 1604.8 | BkW | 0.47 | 0.52 | 0.55 | 0.59 | 0.63 | 0.70 | 0.74 | 0.78 | 0.85 | 0.89 | 0.93 | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | C | C | C | C | — | — | — | — | — |
| | RPM | 471 | 506 | 539 | 574 | 604 | 633 | 664 | 692 | 721 | 747 | 773 | — | — | — | — | — |
| | Turns Open | 5.5 | 4 | 3 | 1.5 | 1 | 5 | 4 | 3 | 2 | 1.5 | 1 | — | — | — | — | — |
| 1652.0 | BkW | 0.48 | 0.55 | 0.59 | 0.63 | 0.70 | 0.74 | 0.78 | 0.85 | 0.92 | 0.96 | — | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | C | C | C | C | C | C | — | — | — | — | — | — |
| | RPM | 486 | 520 | 555 | 586 | 615 | 647 | 674 | 704 | 730 | 756 | — | — | — | — | — | — |
| | Turns Open | 5 | 3.5 | 2.5 | 1 | 5.5 | 4.5 | 4 | 3 | 2 | 1.5 | — | — | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor.

# Performance data (cont)

## 50VQP120 BLOWER PERFORMANCE DATA

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 1085.6 | BkW | — | — | 0.18 | 0.19 | 0.22 | 0.27 | 0.30 | 0.34 | 0.37 | 0.42 | 0.45 | 0.48 | 0.52 | 0.55 | 0.60 | 0.63 |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | A | C | C | C | C | C |
| | RPM | — | — | 376 | 423 | 466 | 503 | 543 | 580 | 616 | 649 | 682 | 712 | 742 | 770 | 797 | 822 |
| | Turns Open | — | — | 6 | 4.5 | 3 | 6 | 5 | 4 | 3 | 2 | 1 | 5.5 | 4.5 | 4 | 3 | 2.5 |
| 1132.8 | BkW | — | — | 0.19 | 0.22 | 0.27 | 0.30 | 0.34 | 0.37 | 0.42 | 0.45 | 0.52 | 0.52 | 0.57 | 0.60 | 0.67 | 0.70 |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | — | 395 | 439 | 481 | 517 | 555 | 592 | 626 | 659 | 691 | 722 | 751 | 779 | 805 | 831 |
| | Turns Open | — | — | 5.5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 6 | 5.5 | 4.5 | 3.5 | 3 | 2 |
| 1180.0 | BkW | — | — | 0.22 | 0.25 | 0.30 | 0.33 | 0.37 | 0.40 | 0.45 | 0.48 | 0.55 | 0.60 | 0.63 | 0.67 | 0.70 | 0.75 |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | — | 412 | 455 | 496 | 530 | 567 | 603 | 637 | 669 | 701 | 730 | 759 | 787 | 813 | 839 |
| | Turns Open | — | — | 5 | 3 | 1.5 | 5.5 | 4 | 3 | 2 | 1 | 6 | 5 | 4 | 3.5 | 2.5 | 1.5 |
| 1227.2 | BkW | — | 0.22 | 0.25 | 0.30 | 0.33 | 0.37 | 0.40 | 0.45 | 0.48 | 0.55 | 0.60 | 0.63 | 0.67 | 0.70 | 0.75 | 0.78 |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | 385 | 430 | 471 | 506 | 544 | 579 | 614 | 647 | 679 | 710 | 739 | 768 | 795 | 822 | 847 |
| | Turns Open | — | 6 | 4 | 2.5 | 6 | 5 | 3.5 | 2.5 | 1.5 | 1 | 5.5 | 4.5 | 4 | 3 | 2 | 1.5 |
| 1274.4 | BkW | — | 0.25 | 0.30 | 0.33 | 0.37 | 0.40 | 0.45 | 0.48 | 0.55 | 0.60 | 0.63 | 0.67 | 0.70 | 0.75 | 0.78 | 0.82 |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | — | 403 | 446 | 486 | 520 | 556 | 591 | 625 | 657 | 689 | 719 | 748 | 776 | 803 | 830 | 855 |
| | Turns Open | — | 5 | 3.5 | 2 | 5.5 | 4.5 | 3.5 | 2.5 | 1 | 6 | 5.5 | 4.5 | 3.5 | 3 | 2 | 1 |
| 1321.6 | BkW | 0.25 | 0.30 | 0.33 | 0.37 | 0.40 | 0.45 | 0.48 | 0.52 | 0.60 | 0.63 | 0.67 | 0.70 | 0.75 | 0.78 | 0.82 | 0.90 |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | 377 | 421 | 462 | 501 | 534 | 569 | 603 | 636 | 668 | 698 | 728 | 757 | 785 | 812 | 838 | 860 |
| | Turns Open | 6 | 4.5 | 3 | 6 | 5 | 4 | 3 | 2 | 1 | 6 | 5 | 4 | 3.5 | 2.5 | 1.5 | 1 |
| 1368.8 | BkW | 0.30 | 0.33 | 0.37 | 0.40 | 0.45 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.75 | 0.78 | 0.85 | 0.90 | 0.93 |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | 395 | 438 | 478 | 515 | 547 | 582 | 615 | 647 | 678 | 708 | 737 | 765 | 793 | 819 | 845 | 868 |
| | Turns Open | 5.5 | 4 | 2.5 | 6 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 5.5 | 5 | 4 | 3 | 2.5 | 1.5 | 0.5 |
| 1416.0 | BkW | 0.33 | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.82 | 0.85 | 0.89 | 0.93 | 1.00 |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | C | C | C | C | C | C | C | C |
| | RPM | 414 | 453 | 491 | 529 | 563 | 595 | 626 | 659 | 689 | 717 | 745 | 774 | 801 | 826 | 851 | 877 |
| | Turns Open | 4.5 | 3.5 | 2 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 6 | 5.5 | 4.5 | 3.5 | 3 | 2 | 1 | 0.5 |
| 1463.2 | BkW | 0.37 | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.82 | 0.85 | 0.89 | 0.93 | 1.00 | 1.08 |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C | C |
| | RPM | 431 | 469 | 504 | 542 | 575 | 607 | 637 | 670 | 699 | 726 | 754 | 783 | 809 | 834 | 859 | 884 |
| | Turns Open | 4 | 3 | 6 | 5 | 4 | 3 | 2 | 1 | 6 | 5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 0.5 |
| 1510.4 | BkW | 0.40 | 0.44 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.82 | 0.85 | 0.93 | 0.96 | 1.00 | 1.08 | 1.14 |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C | C |
| | RPM | 448 | 485 | 520 | 556 | 588 | 619 | 649 | 680 | 708 | 736 | 765 | 791 | 817 | 841 | 868 | 891 |
| | Turns Open | 3.5 | 2 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 5.5 | 5 | 4 | 3 | 2.5 | 1.5 | 0.5 | 0 |
| 1557.6 | BkW | 0.44 | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.82 | 0.85 | 0.93 | 0.96 | 1.00 | 1.08 | 1.11 | 1.15 |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | C | C | C | C | C |
| | RPM | 464 | 500 | 537 | 570 | 601 | 631 | 662 | 691 | 718 | 745 | 774 | 799 | 824 | 849 | 875 | 898 |
| | Turns Open | 3 | 1.5 | 5 | 4 | 3 | 2 | 1.5 | 6 | 5.5 | 4.5 | 4 | 3 | 2 | 1.5 | 0.5 | 0 |
| 1604.8 | BkW | 0.48 | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.82 | 0.85 | 0.93 | 0.96 | 1.00 | 1.08 | 1.11 | 1.15 | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | C | C | C | C | C | C | C | C | — |
| | RPM | 480 | 515 | 551 | 583 | 613 | 642 | 674 | 701 | 728 | 754 | 783 | 808 | 833 | 857 | 882 | — |
| | Turns Open | 2.5 | 6 | 4.5 | 3.5 | 3 | 2 | 1 | 6 | 5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 0 | — |
| 1652.0 | BkW | 0.52 | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.82 | 0.85 | 0.93 | 0.96 | 1.00 | 1.08 | 1.15 | 1.19 | 1.23 | — |
| | Sheave/Mtr | B | A | A | A | A | A | C | C | C | C | C | C | C | C | C | — |
| | RPM | 496 | 530 | 565 | 596 | 625 | 654 | 684 | 711 | 738 | 766 | 792 | 816 | 841 | 867 | 890 | — |
| | Turns Open | 2 | 5.5 | 4 | 3.5 | 2.5 | 1.5 | 6 | 5.5 | 4.5 | 4 | 3 | 2.5 | 1.5 | 1 | 0 | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**E** — High rpm/Large Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor, E = High rpm/Large Motor.

## 50VQP120 BLOWER PERFORMANCE DATA (cont)

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 1699.2 | BkW | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.82 | 0.85 | 0.93 | 1.00 | 1.04 | 1.08 | 1.15 | 1.19 | 1.23 | 1.30 | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | C | C | C | C | C | C | C | — |
| | RPM | 511 | 544 | 578 | 608 | 637 | 668 | 695 | 722 | 748 | 776 | 800 | 825 | 849 | 874 | 897 | — |
| | Turns Open | 6 | 5 | 3.5 | 3 | 2 | 1 | 6 | 5 | 4.5 | 3.5 | 3 | 2 | 1.5 | 0.5 | 0 | — |
| 1746.4 | BkW | 0.63 | 0.67 | 0.70 | 0.78 | 0.85 | 0.89 | 0.93 | 1.00 | 1.04 | 1.08 | 1.15 | 1.23 | 1.26 | 1.30 | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | C | C | C | C | C | C | — | — |
| | RPM | 526 | 561 | 592 | 621 | 649 | 679 | 706 | 732 | 758 | 785 | 809 | 833 | 857 | 882 | — | — |
| | Turns Open | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 5.5 | 5 | 4 | 3.5 | 2.5 | 2 | 1 | 0.5 | — | — |
| 1793.6 | BkW | 0.67 | 0.70 | 0.78 | 0.82 | 0.85 | 0.93 | 1.00 | 1.04 | 1.08 | 1.15 | 1.23 | 1.26 | 1.30 | 1.38 | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | C | C | C | C | C | C | C | — | — |
| | RPM | 544 | 575 | 605 | 633 | 661 | 691 | 717 | 742 | 767 | 794 | 818 | 842 | 867 | 890 | — | — |
| | Turns Open | 5 | 4 | 3 | 2 | 1 | 6 | 5.5 | 4.5 | 4 | 3 | 2 | 1.5 | 0.5 | 0 | — | — |
| 1840.8 | BkW | 0.70 | 0.78 | 0.85 | 0.89 | 0.93 | 1.00 | 1.08 | 1.11 | 1.15 | 1.23 | 1.30 | 1.34 | 1.38 | 1.45 | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | C | C | C | C | C | C | E | — | — |
| | RPM | 555 | 589 | 618 | 646 | 676 | 702 | 728 | 753 | 779 | 803 | 827 | 850 | 875 | 898 | — | — |
| | Turns Open | 4.5 | 3.5 | 2.5 | 1.5 | 6 | 6 | 5 | 4 | 3.5 | 2.5 | 2 | 1 | 0.5 | 0 | — | — |
| 1888.0 | BkW | 0.78 | 0.82 | 0.85 | 0.93 | 1.00 | 1.08 | 1.11 | 1.15 | 1.23 | 1.30 | 1.34 | 1.38 | 1.50 | 1.53 | — | — |
| | Sheave/Mtr | A | A | A | A | C | C | C | C | C | C | C | C | E | E | — | — |
| | RPM | 572 | 601 | 630 | 657 | 686 | 712 | 737 | 762 | 789 | 812 | 836 | 859 | 883 | 905 | — | — |
| | Turns Open | 4 | 3 | 2 | 1 | 6 | 5.5 | 4.5 | 4 | 3 | 2.5 | 1.5 | 1 | 0 | 0 | — | — |
| 1935.2 | BkW | 0.85 | 0.89 | 0.93 | 1.00 | 1.08 | 1.11 | 1.15 | 1.23 | 1.30 | 1.38 | 1.41 | 1.50 | 1.53 | — | — | — |
| | Sheave/Mtr | A | A | A | A | C | C | C | C | C | C | C | E | E | — | — | — |
| | RPM | 589 | 617 | 645 | 672 | 700 | 726 | 751 | 775 | 801 | 824 | 847 | 872 | 894 | — | — | — |
| | Turns Open | 3.5 | 2.5 | 1.5 | 1 | 6 | 5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 0.5 | 0 | — | — | — |
| 1982.4 | BkW | 0.93 | 0.96 | 1.00 | 1.08 | 1.15 | 1.19 | 1.23 | 1.30 | 1.38 | 1.50 | 1.53 | 1.56 | — | — | — | — |
| | Sheave/Mtr | A | A | A | C | C | C | C | C | C | E | E | E | — | — | — | — |
| | RPM | 605 | 633 | 660 | 689 | 714 | 739 | 763 | 790 | 813 | 836 | 858 | 882 | — | — | — | — |
| | Turns Open | 3 | 2 | 1 | 6 | 5.5 | 4.5 | 4 | 3 | 2 | 1.5 | 1 | 0.5 | — | — | — | — |
| 2029.6 | BkW | 0.96 | 1.00 | 1.08 | 1.15 | 1.23 | 1.26 | 1.30 | 1.38 | 1.50 | 1.53 | 1.60 | 1.68 | — | — | — | — |
| | Sheave/Mtr | A | A | A | C | C | C | C | C | E | E | E | E | — | — | — | — |
| | RPM | 621 | 649 | 675 | 703 | 728 | 752 | 776 | 802 | 827 | 847 | 869 | 893 | — | — | — | — |
| | Turns Open | 2.5 | 1.5 | 1 | 6 | 5 | 4 | 3.5 | 2.5 | 2 | 1.5 | 1 | 0 | — | — | — | — |
| 2076.8 | BkW | 1.040 | 1.08 | 1.15 | 1.23 | 1.30 | 1.38 | 1.41 | 1.50 | 1.53 | 1.60 | 1.68 | 1.75 | — | — | — | — |
| | Sheave/Mtr | A | A | C | C | C | C | C | E | C | E | E | E | — | — | — | — |
| | RPM | 637 | 664 | 690 | 717 | 742 | 766 | 791 | 814 | 836 | 858 | 882 | 904 | — | — | — | — |
| | Turns Open | 2 | 1 | 6 | 5.5 | 4.5 | 4 | 3 | 2 | 2 | 1 | 0.5 | 0 | — | — | — | — |
| 2124.0 | BkW | 1.11 | 1.15 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.56 | 1.60 | 1.68 | 1.75 | — | — | — | — | — |
| | Sheave/Mtr | A | A | C | C | C | C | E | E | C | E | E | — | — | — | — | — |
| | RPM | 653 | 679 | 707 | 731 | 755 | 779 | 804 | 826 | 848 | 870 | 893 | — | — | — | — | — |
| | Turns Open | 1.5 | 1 | 5.5 | 5 | 4 | 3.5 | 3 | 2 | 1.5 | 1 | 0 | — | — | — | — | — |
| 2029.6 | BkW | 0.96 | 1.00 | 1.08 | 1.15 | 1.23 | 1.26 | 1.30 | 1.38 | 1.50 | 1.53 | 1.60 | 1.68 | — | — | — | — |
| | Sheave/Mtr | A | A | A | C | C | C | C | C | E | E | E | E | — | — | — | — |
| | RPM | 621 | 649 | 675 | 703 | 728 | 752 | 776 | 802 | 827 | 847 | 869 | 893 | — | — | — | — |
| | Turns Open | 2.5 | 1.5 | 1 | 6 | 5 | 4 | 3.5 | 2.5 | 2 | 1.5 | 1 | 0 | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**E** — High rpm/Large Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor, E = High rpm/Large Motor.

# Performance data (cont)

## 50VQP150 BLOWER PERFORMANCE DATA

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 1321.6 | BkW | — | — | — | — | — | 0.34 | 0.37 | 0.42 | 0.49 | 0.52 | 0.57 | 0.64 | 0.72 | 0.79 | 0.87 | 0.94 |
| | Sheave/Mtr | — | — | — | — | — | B | B | A | A | A | A | A | A | C | C | C |
| | RPM | — | — | — | — | — | 533 | 572 | 606 | 640 | 676 | 712 | 746 | 783 | 821 | 859 | 901 |
| | Turns Open | — | — | — | — | — | 5.5 | 4 | 6 | 5 | 4 | 3 | 2 | 1 | 5.5 | 4.5 | 3 |
| 1368.8 | BkW | — | — | — | — | — | 0.37 | 0.42 | 0.45 | 0.52 | 0.57 | 0.60 | 0.67 | 0.75 | 0.81 | 0.90 | 0.97 |
| | Sheave/Mtr | — | — | — | — | — | B | B | A | A | A | A | A | A | C | C | C |
| | RPM | — | — | — | — | — | 544 | 582 | 619 | 652 | 686 | 719 | 754 | 789 | 823 | 860 | 902 |
| | Turns Open | — | — | — | — | — | 5 | 4 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 5.5 | 4 | 3 |
| 1416.0 | BkW | — | — | — | — | 0.37 | 0.42 | 0.45 | 0.52 | 0.57 | 0.60 | 0.67 | 0.75 | 0.79 | 0.82 | 0.94 | 1.02 |
| | Sheave/Mtr | — | — | — | — | B | B | B | A | A | A | A | A | C | C | C | C |
| | RPM | — | — | — | — | 521 | 558 | 595 | 628 | 663 | 697 | 728 | 762 | 796 | 828 | 863 | 903 |
| | Turns Open | — | — | — | — | 6 | 4.5 | 3.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 6 | 5 | 4 | 3 |
| 1463.2 | BkW | — | — | — | — | 0.42 | 0.45 | 0.52 | 0.55 | 0.60 | 0.64 | 0.72 | 0.78 | 0.82 | 0.90 | 0.97 | 1.05 |
| | Sheave/Mtr | — | — | — | — | B | B | A | A | A | A | A | A | C | C | C | C |
| | RPM | — | — | — | — | 536 | 572 | 608 | 640 | 674 | 705 | 737 | 769 | 799 | 832 | 866 | 904 |
| | Turns Open | — | — | — | — | 5.5 | 4 | 6 | 5 | 4 | 3 | 2 | 1 | 6 | 5 | 4 | 3 |
| 1510.4 | BkW | — | — | — | — | 0.45 | 0.49 | 0.55 | 0.60 | 0.67 | 0.70 | 0.75 | 0.85 | 0.90 | 0.97 | 1.05 | 1.12 |
| | Sheave/Mtr | — | — | — | — | B | B | A | A | A | A | A | A | C | C | C | C |
| | RPM | — | — | — | — | 548 | 585 | 618 | 652 | 685 | 715 | 747 | 778 | 807 | 836 | 868 | 905 |
| | Turns Open | — | — | — | — | 5 | 3.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 5.5 | 5 | 3.5 | 3 |
| 1557.6 | BkW | — | — | — | 0.45 | 0.48 | 0.52 | 0.60 | 0.64 | 0.70 | 0.78 | 0.82 | 0.90 | 0.93 | 1.00 | 1.08 | 1.15 |
| | Sheave/Mtr | — | — | — | B | B | A | A | A | A | A | A | A | C | C | C | C |
| | RPM | — | — | — | 522 | 562 | 599 | 631 | 664 | 694 | 725 | 756 | 784 | 815 | 845 | 874 | 906 |
| | Turns Open | — | — | — | 6 | 4.5 | 6 | 5.5 | 4 | 3 | 2.5 | 1.5 | 1 | 5.5 | 4.5 | 3.5 | 3 |
| 1604.8 | BkW | — | — | — | 0.48 | 0.52 | 0.57 | 0.63 | 0.67 | 0.75 | 0.82 | 0.85 | 0.93 | 1.00 | 1.08 | 1.15 | 1.20 |
| | Sheave/Mtr | — | — | — | B | B | A | A | A | A | A | A | C | C | C | C | C |
| | RPM | — | — | — | 537 | 576 | 612 | 643 | 676 | 705 | 736 | 763 | 793 | 823 | 850 | 880 | 908 |
| | Turns Open | — | — | — | 5.5 | 4 | 5.5 | 5 | 4 | 3 | 2 | 1 | 6 | 5 | 4.5 | 3.5 | 2.5 |
| 1652.0 | BkW | — | — | — | 0.52 | 0.57 | 0.60 | 0.67 | 0.75 | 0.78 | 0.85 | 0.93 | 1.00 | 1.05 | 1.12 | 1.20 | 1.23 |
| | Sheave/Mtr | — | — | — | B | B | A | A | A | A | A | A | C | C | C | C | C |
| | RPM | — | — | — | 551 | 589 | 622 | 655 | 685 | 716 | 746 | 776 | 802 | 829 | 858 | 886 | 913 |
| | Turns Open | — | — | — | 5 | 3.5 | 5.5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 6 | 5 | 4 | 3 | 2.5 |
| 1699.2 | BkW | — | — | 0.52 | 0.55 | 0.60 | 0.67 | 0.75 | 0.78 | 0.85 | 0.93 | 0.97 | 1.05 | 1.08 | 1.15 | 1.23 | 1.30 |
| | Sheave/Mtr | — | — | B | B | A | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | — | 526 | 565 | 600 | 634 | 665 | 696 | 727 | 754 | 783 | 809 | 837 | 865 | 891 | 919 |
| | Turns Open | — | — | 6 | 4.5 | 6 | 5 | 4 | 3 | 2 | 1.5 | 6 | 5.5 | 4.5 | 4 | 3 | 2.5 |
| 1746.4 | BkW | — | — | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.85 | 0.93 | 0.97 | 1.00 | 1.08 | 1.15 | 1.23 | 1.30 | 1.38 |
| | Sheave/Mtr | — | — | B | B | A | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | — | 541 | 579 | 613 | 647 | 677 | 707 | 737 | 764 | 793 | 818 | 846 | 871 | 898 | 926 |
| | Turns Open | — | — | 5.5 | 4 | 5.5 | 4.5 | 4 | 3 | 2 | 1.5 | 6 | 5.5 | 4.5 | 3.5 | 3 | 2 |
| 1793.6 | BkW | — | 0.55 | 0.63 | 0.67 | 0.70 | 0.78 | 0.85 | 0.93 | 0.96 | 1.00 | 1.08 | 1.15 | 1.23 | 1.30 | 1.38 | 1.45 |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | 519 | 554 | 591 | 626 | 659 | 688 | 718 | 746 | 774 | 802 | 829 | 855 | 879 | 905 | 931 |
| | Turns Open | — | 6 | 5 | 3.5 | 5.5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 5.5 | 5 | 4.5 | 3.5 | 2.5 | 2 |
| 1840.8 | BkW | — | 0.59 | 0.63 | 0.70 | 0.78 | 0.85 | 0.89 | 0.93 | 1.00 | 1.08 | 1.15 | 1.23 | 1.30 | 1.38 | 1.45 | 1.52 |
| | Sheave/Mtr | — | B | B | A | A | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | 531 | 569 | 605 | 639 | 669 | 702 | 729 | 757 | 785 | 811 | 838 | 862 | 887 | 913 | 938 |
| | Turns Open | — | 5.5 | 4.5 | 6 | 5 | 4 | 3 | 2.5 | 1.5 | 1 | 5.5 | 5 | 4 | 3.5 | 2.5 | 2 |
| 1888.0 | BkW | — | 0.63 | 0.70 | 0.78 | 0.85 | 0.89 | 0.93 | 1.00 | 1.08 | 1.15 | 1.23 | 1.26 | 1.30 | 1.38 | 1.45 | 1.53 |
| | Sheave/Mtr | — | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | — | 545 | 582 | 618 | 651 | 683 | 710 | 739 | 767 | 794 | 821 | 845 | 870 | 895 | 920 | 945 |
| | Turns Open | — | 5 | 4 | 5.5 | 4.5 | 4 | 3 | 2 | 1.5 | 6 | 5.5 | 4.5 | 4 | 3 | 2.5 | 2 |
| 1935.2 | BkW | 0.63 | 0.70 | 0.78 | 0.82 | 0.85 | 0.93 | 1.00 | 1.08 | 1.15 | 1.23 | 1.26 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | 523 | 560 | 596 | 631 | 661 | 692 | 722 | 750 | 778 | 804 | 831 | 854 | 879 | 904 | 928 | 951 |
| | Turns Open | 6 | 4.5 | 3.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 6 | 5 | 4.5 | 3.5 | 3 | 2 | 1.5 |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**E** — High rpm/Large Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor, E = High rpm/Large Motor.

## 50VQP150 BLOWER PERFORMANCE DATA (cont)

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 1982.4 | BkW | 0.70 | 0.74 | 0.78 | 0.85 | 0.93 | 1.00 | 1.08 | 1.15 | 1.19 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | 538 | 574 | 609 | 640 | 673 | 703 | 733 | 761 | 788 | 812 | 838 | 863 | 888 | 912 | 934 | 958 |
| | Turns Open | 5.5 | 4 | 6 | 5 | 4 | 3 | 2 | 1.5 | 1 | 5.5 | 5 | 4 | 3.5 | 2.5 | 2 | 1.5 |
| 2029.6 | BkW | 0.70 | 0.78 | 0.85 | 0.93 | 1.00 | 1.08 | 1.15 | 1.19 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C | C |
| | RPM | 553 | 588 | 620 | 653 | 685 | 715 | 744 | 771 | 796 | 822 | 847 | 872 | 896 | 919 | 942 | 966 |
| | Turns Open | 5 | 3.5 | 5.5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 6 | 5.5 | 4.5 | 4 | 3 | 2.5 | 1.5 | 1 |
| 2076.8 | BkW | 0.78 | 0.85 | 0.93 | 1.00 | 1.08 | 1.15 | 1.19 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C | C |
| | RPM | 568 | 602 | 633 | 666 | 697 | 726 | 755 | 782 | 806 | 832 | 857 | 881 | 904 | 927 | 950 | 973 |
| | Turns Open | 4.5 | 3 | 5 | 4 | 3.5 | 2.5 | 1.5 | 1 | 6 | 5 | 4.5 | 3.5 | 3 | 2 | 1.5 | 1 |
| 2124.0 | BkW | 0.85 | 0.90 | 0.97 | 1.05 | 1.12 | 1.20 | 1.27 | 1.35 | 1.42 | 1.50 | 1.57 | 1.65 | 1.72 | 1.80 | 1.87 | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | C | C | C | C | C | C | C | C | — |
| | RPM | 581 | 613 | 646 | 678 | 706 | 735 | 763 | 791 | 817 | 842 | 867 | 889 | 912 | 935 | 958 | — |
| | Turns Open | 4 | 6 | 4.5 | 4 | 3 | 2 | 1.5 | 6 | 5.5 | 4.5 | 4 | 3 | 2.5 | 2 | 1.5 | — |
| 2171.2 | BkW | 0.89 | 0.93 | 1.00 | 1.08 | 1.15 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | C | C | C | C | C | C | C | C | — |
| | RPM | 598 | 623 | 656 | 687 | 715 | 744 | 772 | 799 | 825 | 850 | 872 | 896 | 919 | 942 | 963 | — |
| | Turns Open | 3.5 | 5.5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 6 | 5.5 | 4.5 | 3.5 | 3 | 2 | 1.5 | 1 | — |
| 2218.4 | BkW | 0.93 | 1.00 | 1.08 | 1.15 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | — |
| | Sheave/Mtr | A | A | A | A | A | A | A | C | C | C | C | C | C | C | C | — |
| | RPM | 605 | 637 | 666 | 697 | 727 | 755 | 783 | 809 | 835 | 858 | 882 | 905 | 928 | 951 | 973 | — |
| | Turns Open | 6 | 5 | 4 | 3 | 2.5 | 1.5 | 1 | 5.5 | 5 | 4 | 3.5 | 2.5 | 2 | 1.5 | 1 | — |
| 2265.6 | BkW | 1.00 | 1.08 | 1.15 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | 2.05 | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | C | C | C | C | C | C | C | — |
| | RPM | 618 | 647 | 678 | 708 | 738 | 766 | 793 | 819 | 844 | 867 | 891 | 914 | 937 | 959 | 980 | — |
| | Turns Open | 5.5 | 4.5 | 4 | 3 | 2 | 1 | 6 | 5.5 | 4.5 | 4 | 3 | 2.5 | 1.5 | 1.5 | 1 | — |
| 2312.8 | BkW | 1.08 | 1.15 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | 2.05 | 2.12 | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | C | C | C | C | C | C | C | — |
| | RPM | 631 | 662 | 690 | 720 | 749 | 777 | 803 | 827 | 852 | 877 | 900 | 923 | 946 | 966 | 988 | — |
| | Turns Open | 5.5 | 4 | 3.5 | 2.5 | 1.5 | 1 | 6 | 5 | 4.5 | 3.5 | 3 | 2 | 1.5 | 1 | 1 | — |
| 2360.0 | BkW | 1.15 | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | 2.05 | 2.12 | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | C | C | C | C | C | C | C | — | — |
| | RPM | 642 | 672 | 702 | 731 | 760 | 785 | 811 | 837 | 862 | 886 | 909 | 932 | 953 | 975 | — | — |
| | Turns Open | 5 | 4 | 3 | 2 | 1.5 | 6 | 5.5 | 4.5 | 4 | 3 | 2.5 | 1.5 | 1 | 1 | — | — |
| 2407.2 | BkW | 1.23 | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | 2.05 | 2.12 | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | C | C | C | C | C | C | — | — | — |
| | RPM | 655 | 685 | 714 | 743 | 769 | 798 | 822 | 847 | 872 | 896 | 917 | 940 | 962 | — | — | — |
| | Turns Open | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 6 | 5 | 4.5 | 3.5 | 3 | 2.5 | 1.5 | 1 | — | — | — |
| 2454.4 | BkW | 1.30 | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | 2.05 | 2.12 | 2.24 | — | — | — |
| | Sheave/Mtr | A | A | A | A | C | C | C | C | C | C | C | C | E | — | — | — |
| | RPM | 668 | 697 | 726 | 752 | 782 | 806 | 832 | 857 | 882 | 903 | 926 | 949 | 971 | — | — | — |
| | Turns Open | 4 | 3 | 2.5 | 1.5 | 6 | 5.5 | 5 | 4 | 3.5 | 2.5 | 2 | 1 | 0 | — | — | — |
| 2501.6 | BkW | 1.38 | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | 2.05 | 2.12 | 2.20 | 2.31 | — | — | — |
| | Sheave/Mtr | A | A | A | A | C | C | C | C | C | C | C | C | E | — | — | — |
| | RPM | 680 | 709 | 737 | 763 | 790 | 817 | 842 | 867 | 889 | 912 | 935 | 957 | 979 | — | — | — |
| | Turns Open | 3.5 | 3 | 2 | 1 | 6 | 5.5 | 4.5 | 4 | 3 | 2 | 2 | C | 0 | — | — | — |
| 2548.8 | BkW | 1.45 | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | 2.05 | 2.12 | 2.20 | 2.31 | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | C | C | C | C | C | C | C | E | — | — | — | — |
| | RPM | 691 | 717 | 745 | 772 | 799 | 825 | 850 | 873 | 897 | 920 | 943 | 965 | — | — | — | — |
| | Turns Open | 3.5 | 2.5 | 1.5 | 1 | 5.5 | 5 | 4.5 | 3.5 | 3 | 2 | 1.5 | 0 | — | — | — | — |
| 2596.0 | BkW | 1.53 | 1.60 | 1.68 | 1.75 | 1.83 | 1.90 | 1.97 | 2.05 | 2.12 | 2.31 | 2.35 | 2.42 | — | — | — | — |
| | Sheave/Mtr | A | A | A | C | C | C | C | C | C | E | E | E | — | — | — | — |
| | RPM | 704 | 729 | 756 | 783 | 810 | 836 | 859 | 883 | 907 | 929 | 952 | 972 | — | — | — | — |
| | Turns Open | 3 | 2 | 1.5 | 6 | 5.5 | 5 | 4 | 3.5 | 2.5 | 1 | 0.5 | 0 | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**E** — High rpm/Large Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor, E = High rpm/Large Motor.

# Performance data (cont)

## 50VQP168 BLOWER PERFORMANCE DATA

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 1510.4 | BkW | — | — | 0.23 | 0.30 | 0.26 | 0.38 | 0.45 | 0.48 | 0.51 | 0.60 | 0.63 | 0.66 | 0.75 | 0.78 | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | C | — | — |
| | RPM | — | — | 388 | 437 | 482 | 527 | 564 | 599 | 630 | 663 | 690 | 716 | 744 | 767 | — | — |
| | Turns Open | — | — | 6 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 3.5 | 2.5 | 2 | 1 | — | — |
| 1604.8 | BkW | — | — | 0.25 | 0.32 | 0.30 | 0.41 | 0.48 | 0.51 | 0.55 | 0.63 | 0.67 | 0.71 | 0.80 | 0.84 | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | C | — | — |
| | RPM | — | — | 392 | 440 | 485 | 529 | 566 | 601 | 633 | 666 | 693 | 720 | 747 | 771 | — | — |
| | Turns Open | — | — | 5.5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 3 | 2.5 | 2 | 1 | — | — |
| 1699.2 | BkW | — | — | 0.27 | 0.34 | 0.34 | 0.44 | 0.50 | 0.54 | 0.59 | 0.67 | 0.71 | 0.76 | 0.84 | — | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — |
| | RPM | — | — | 395 | 444 | 488 | 530 | 568 | 603 | 636 | 668 | 697 | 723 | 751 | — | — | — |
| | Turns Open | — | — | 5.5 | 4 | 2.5 | 5.5 | 4 | 3.5 | 2.5 | 1 | 3 | 2.5 | 1.5 | — | — | — |
| 1793.6 | BkW | — | — | 0.29 | 0.37 | 0.39 | 0.47 | 0.53 | 0.57 | 0.62 | 0.70 | 0.76 | 0.81 | 0.89 | — | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — |
| | RPM | — | — | 399 | 447 | 491 | 532 | 571 | 606 | 639 | 671 | 700 | 727 | 754 | — | — | — |
| | Turns Open | — | — | 5.5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 1 | 3 | 2 | 1.5 | — | — | — |
| 1888.0 | BkW | — | — | 0.32 | 0.39 | 0.43 | 0.50 | 0.56 | 0.60 | 0.66 | 0.74 | 0.80 | 0.86 | 0.94 | — | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — |
| | RPM | — | — | 403 | 450 | 493 | 534 | 573 | 608 | 641 | 673 | 703 | 730 | 757 | — | — | — |
| | Turns Open | — | — | 5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 1 | 2.5 | 2 | 1.5 | — | — | — |
| 1982.4 | BkW | — | 0.24 | 0.36 | 0.43 | 0.51 | 0.55 | 0.61 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | — | — | — |
| | Sheave/Mtr | — | B | B | B | B | A | A | A | A | A | C | C | C | — | — | — |
| | RPM | — | 362 | 410 | 457 | 499 | 537 | 577 | 612 | 647 | 678 | 710 | 737 | 764 | — | — | — |
| | Turns Open | — | 6 | 5 | 3.5 | 2 | 5 | 3.5 | 3 | 2 | 1 | 2.5 | 2 | 1 | — | — | — |
| 2076.8 | BkW | — | 0.34 | 0.42 | 0.47 | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | — | — | — |
| | Sheave/Mtr | — | B | B | B | B | A | A | A | A | C | C | C | C | — | — | — |
| | RPM | — | 375 | 424 | 467 | 507 | 548 | 584 | 621 | 653 | 684 | 716 | 743 | 772 | — | — | — |
| | Turns Open | — | 6 | 4.5 | 3 | 1.5 | 4.5 | 3.5 | 2.5 | 1.5 | 3.5 | 2.5 | 1.5 | 1 | — | — | — |
| 2171.2 | BkW | — | 0.36 | 0.43 | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | — | — | — | — |
| | Sheave/Mtr | — | B | B | B | B | A | A | A | A | C | C | C | — | — | — | — |
| | RPM | — | 387 | 435 | 476 | 518 | 555 | 590 | 627 | 659 | 692 | 721 | 751 | — | — | — | — |
| | Turns Open | — | 5.5 | 4 | 3 | 1.5 | 4.5 | 3.5 | 2.5 | 1.5 | 3 | 2.5 | 1.5 | — | — | — | — |
| 2265.6 | BkW | — | 0.43 | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | 1.18 | — | — | — | — |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — |
| | RPM | — | 403 | 446 | 485 | 527 | 563 | 600 | 633 | 665 | 697 | 726 | 756 | — | — | — | — |
| | Turns Open | — | 5.5 | 4 | 2.5 | 5.5 | 4.5 | 3 | 2.5 | 1 | 3 | 2 | 1.5 | — | — | — | — |
| 2360.0 | BkW | 0.42 | 0.46 | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.11 | 1.18 | 1.26 | — | — | — | — |
| | Sheave/Mtr | B | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — |
| | RPM | 362 | 411 | 452 | 495 | 532 | 567 | 604 | 636 | 670 | 700 | 729 | 759 | — | — | — | — |
| | Turns Open | 6 | 5 | 3.5 | 2 | 5.5 | 4 | 3 | 2 | 1 | 3 | 2 | 1 | — | — | — | — |
| 2454.4 | BkW | 0.43 | 0.51 | 0.64 | 0.72 | 0.79 | 0.87 | 0.94 | 1.02 | 1.09 | 1.17 | 1.24 | 1.32 | — | — | — | — |
| | Sheave/Mtr | B | B | B | B | A | A | A | A | C | C | C | C | — | — | — | — |
| | RPM | 377 | 420 | 460 | 500 | 536 | 570 | 606 | 638 | 671 | 701 | 729 | 759 | — | — | — | — |
| | Turns Open | 6 | 4.5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 4 | 2.5 | 2 | 1 | — | — | — | — |
| 2548.8 | BkW | 0.49 | 0.57 | 0.64 | 0.72 | 0.79 | 0.88 | 0.96 | 1.03 | 1.11 | 1.18 | 1.26 | 1.33 | — | — | — | — |
| | Sheave/Mtr | B | B | B | B | A | A | A | A | C | C | C | C | — | — | — | — |
| | RPM | 381 | 423 | 463 | 504 | 539 | 576 | 609 | 641 | 674 | 703 | 734 | 762 | — | — | — | — |
| | Turns Open | 5.5 | 4.5 | 3 | 1.5 | 5 | 3.5 | 2.5 | 2 | 3.5 | 2.5 | 1.5 | 1 | — | — | — | — |
| 2643.2 | BkW | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.96 | 1.03 | 1.11 | 1.18 | 1.26 | 1.33 | — | — | — | — | — |
| | Sheave/Mtr | B | B | B | B | A | A | A | A | C | C | C | — | — | — | — | — |
| | RPM | 390 | 431 | 474 | 510 | 545 | 581 | 613 | 647 | 677 | 706 | 737 | — | — | — | — | — |
| | Turns Open | 5.5 | 4 | 3 | 1.5 | 5 | 3.5 | 2.5 | 1.5 | 3.5 | 2.5 | 1.5 | — | — | — | — | — |
| 2737.6 | BkW | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.11 | 1.18 | 1.26 | 1.33 | 1.41 | — | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — | — |
| | RPM | 399 | 440 | 481 | 517 | 551 | 586 | 618 | 651 | 681 | 710 | 740 | — | — | — | — | — |
| | Turns Open | 5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 3.5 | 2 | 1.5 | — | — | — | — | — |
| 2832.0 | BkW | 0.64 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | — | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — | — |
| | RPM | 412 | 455 | 492 | 526 | 563 | 595 | 628 | 658 | 687 | 718 | 745 | — | — | — | — | — |
| | Turns Open | 5 | 3.5 | 2 | 5.5 | 4 | 3 | 2 | 1 | 3 | 2 | 1 | — | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor.

## 50VQP192 BLOWER PERFORMANCE DATA

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 1699.2 | BkW | — | — | 0.27 | 0.34 | 0.34 | 0.44 | 0.50 | 0.54 | 0.59 | 0.67 | 0.71 | 0.76 | 0.84 | — | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — |
| | RPM | — | — | 395 | 444 | 488 | 530 | 568 | 603 | 636 | 668 | 697 | 723 | 751 | — | — | — |
| | Turns Open | — | — | 5.5 | 4 | 2.5 | 5.5 | 4 | 3.5 | 2 | 1 | 3 | 2.5 | 1.5 | — | — | — |
| 1793.6 | BkW | — | — | 0.29 | 0.37 | 0.39 | 0.47 | 0.53 | 0.57 | 0.62 | 0.70 | 0.76 | 0.81 | 0.89 | — | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — |
| | RPM | — | — | 399 | 447 | 491 | 532 | 571 | 606 | 639 | 671 | 700 | 727 | 754 | — | — | — |
| | Turns Open | — | — | 5.5 | 4 | 2.5 | 5.5 | 4 | 3 | 2 | 1 | 3 | 2 | 1.5 | — | — | — |
| 1888.0 | BkW | — | — | 0.32 | 0.39 | 0.43 | 0.50 | 0.56 | 0.60 | 0.66 | 0.74 | 0.80 | 0.86 | 0.94 | — | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — |
| | RPM | — | — | 403 | 450 | 493 | 534 | 573 | 608 | 641 | 673 | 703 | 730 | 757 | — | — | — |
| | Turns Open | — | — | 5.5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 1 | 2.5 | 2 | 1.5 | — | — | — |
| 1982.4 | BkW | — | — | 0.36 | 0.43 | 0.51 | 0.55 | 0.61 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | — | — | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — |
| | RPM | — | — | 410 | 457 | 499 | 537 | 577 | 612 | 647 | 678 | 710 | 737 | 764 | — | — | — |
| | Turns Open | — | — | 5 | 3.5 | 2 | 5 | 3.5 | 3 | 1.5 | 1 | 2.5 | 2 | 1 | — | — | — |
| 2076.8 | BkW | — | 0.34 | 0.42 | 0.47 | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | — | — | — |
| | Sheave/Mtr | — | B | B | B | B | A | A | A | A | C | C | C | C | — | — | — |
| | RPM | — | 375 | 424 | 467 | 507 | 548 | 584 | 621 | 653 | 684 | 716 | 743 | 772 | — | — | — |
| | Turns Open | — | 6 | 4.5 | 3 | 1.5 | 5 | 3.5 | 2.5 | 1.5 | 3.5 | 2.5 | 1.5 | 1 | — | — | — |
| 2171.2 | BkW | — | 0.36 | 0.43 | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | — | — | — | — |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — |
| | RPM | — | 387 | 435 | 476 | 518 | 555 | 590 | 627 | 659 | 692 | 721 | 751 | — | — | — | — |
| | Turns Open | — | 6 | 4 | 3 | 6 | 4.5 | 3.5 | 2.5 | 1.5 | 3 | 2.5 | 1.5 | — | — | — | — |
| 2265.6 | BkW | — | 0.43 | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | 1.18 | — | — | — | — |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — |
| | RPM | — | 403 | 446 | 485 | 527 | 563 | 600 | 633 | 665 | 697 | 726 | 756 | — | — | — | — |
| | Turns Open | — | 5.5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1 | 3 | 2 | 1.5 | — | — | — | — |
| 2360.0 | BkW | 0.42 | 0.46 | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.11 | 1.18 | 1.26 | — | — | — | — |
| | Sheave/Mtr | B | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — |
| | RPM | 362 | 411 | 452 | 495 | 532 | 567 | 604 | 636 | 670 | 700 | 729 | 759 | — | — | — | — |
| | Turns Open | 6 | 5 | 3.5 | 2 | 5.5 | 4 | 3 | 2 | 1 | 3 | 2 | 1 | — | — | — | — |
| 2454.4 | BkW | 0.43 | 0.51 | 0.64 | 0.72 | 0.79 | 0.87 | 0.94 | 1.02 | 1.09 | 1.17 | 1.24 | 1.32 | — | — | — | — |
| | Sheave/Mtr | B | B | B | B | A | A | A | A | C | C | C | C | — | — | — | — |
| | RPM | 377 | 420 | 460 | 500 | 536 | 570 | 606 | 638 | 671 | 701 | 729 | 759 | — | — | — | — |
| | Turns Open | 6 | 4.5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 3.5 | 2.5 | 2 | 1 | — | — | — | — |
| 2548.8 | BkW | 0.49 | 0.57 | 0.64 | 0.72 | 0.79 | 0.88 | 0.96 | 1.03 | 1.11 | 1.18 | 1.26 | 1.33 | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | C | C | C | C | — | — | — | — |
| | RPM | 381 | 423 | 463 | 504 | 539 | 576 | 609 | 641 | 674 | 703 | 734 | 762 | — | — | — | — |
| | Turns Open | 6 | 4.5 | 3 | 6 | 5 | 3.5 | 3 | 2 | 3.5 | 2.5 | 2 | 1 | — | — | — | — |
| 2643.2 | BkW | 0.51 | 0.58 | 0.66 | 0.73 | 0.81 | 0.96 | 1.03 | 1.11 | 1.18 | 1.26 | 1.33 | — | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — | — |
| | RPM | 390 | 431 | 474 | 510 | 545 | 581 | 613 | 647 | 677 | 706 | 737 | — | — | — | — | — |
| | Turns Open | 5.5 | 4.5 | 3 | 6 | 4.5 | 3.5 | 3 | 1.5 | 3.5 | 2.5 | 1.5 | — | — | — | — | — |
| 2737.6 | BkW | 0.58 | 0.66 | 0.73 | 0.81 | 0.88 | 0.96 | 1.11 | 1.18 | 1.26 | 1.33 | 1.41 | — | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — | — |
| | RPM | 399 | 440 | 481 | 517 | 551 | 586 | 618 | 651 | 681 | 710 | 740 | — | — | — | — | — |
| | Turns Open | 5.5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 3 | 2.5 | 1.5 | — | — | — | — | — |
| 2832.0 | BkW | 0.64 | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | — | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | C | C | C | — | — | — | — | — |
| | RPM | 412 | 455 | 492 | 526 | 563 | 595 | 628 | 658 | 687 | 718 | 745 | — | — | — | — | — |
| | Turns Open | 5 | 3.5 | 2 | 5.5 | 4 | 3 | 2 | 1 | 3 | 2 | 1.5 | — | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor.

# Performance data (cont)

## 50VQP192 BLOWER PERFORMANCE DATA (cont)

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 2926.4 | BkW | 0.66 | 0.79 | 0.88 | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.48 | 1.56 | — | — | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | C | C | 0 | — | — | — | — | — |
| | RPM | 421 | 459 | 499 | 533 | 569 | 600 | 633 | 663 | 691 | 722 | 749 | — | — | — | — | — |
| | Turns Open | 4.5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 1 | 2.5 | 2 | 1.5 | — | — | — | — | — |
| 3020.8 | BkW | 0.73 | 0.81 | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.48 | 1.56 | 1.71 | — | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | — | — | — | — | — |
| | RPM | 441 | 478 | 513 | 549 | 581 | 614 | 644 | 672 | 703 | 730 | 759 | — | — | — | — | — |
| | Turns Open | 4 | 2.5 | 6 | 4.5 | 3.5 | 3 | 1.5 | 3.5 | 2.5 | 2 | 1 | — | — | — | — | — |
| 3115.2 | BkW | 0.81 | 0.96 | 1.03 | 1.11 | 1.24 | 1.33 | 1.41 | 1.48 | 1.56 | 1.71 | 1.84 | — | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | C | C | C | C | — | — | — | — | — |
| | RPM | 456 | 495 | 529 | 561 | 595 | 625 | 656 | 685 | 712 | 741 | 767 | — | — | — | — | — |
| | Turns Open | 3.5 | 2 | 5.5 | 4 | 3 | 2.5 | 1 | 3.5 | 2.5 | 2 | 1 | — | — | — | — | — |
| 3209.6 | BkW | 0.94 | 1.03 | 1.11 | 1.18 | 1.26 | 1.41 | 1.48 | 1.56 | 1.71 | 1.78 | 1.86 | — | — | — | — | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | C | C | C | C | — | — | — | — | — |
| | RPM | 471 | 506 | 539 | 574 | 604 | 633 | 664 | 692 | 721 | 747 | 773 | — | — | — | — | — |
| | Turns Open | 3 | 6 | 5 | 3.5 | 3 | 2 | 1 | 3 | 2 | 2 | 1 | — | — | — | — | — |
| 3304.0 | BkW | 0.96 | 1.11 | 1.18 | 1.26 | 1.41 | 1.48 | 1.56 | 1.71 | 1.84 | 1.93 | — | — | — | — | — | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | C | C | C | — | — | — | — | — | — |
| | RPM | 486 | 520 | 555 | 586 | 615 | 647 | 674 | 704 | 730 | 756 | — | — | — | — | — | — |
| | Turns Open | 2.5 | 5.5 | 4.5 | 3 | 2.5 | 1.5 | 1 | 3 | 2 | 1.5 | — | — | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor.

## 50VQP240 BLOWER PERFORMANCE DATA

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 2171.2 | BkW | — | — | — | 0.39 | 0.45 | 0.54 | 0.60 | 0.69 | 0.75 | 0.84 | 0.90 | 0.96 | 1.05 | 1.11 | 1.20 | 1.26 |
| | Sheave/Mtr | — | — | — | B | B | B | A | A | A | A | A | A | C | C | C | C |
| | RPM | — | — | — | 423 | 466 | 503 | 543 | 580 | 616 | 649 | 682 | 712 | 742 | 770 | 797 | 822 |
| | Turns Open | — | — | — | 6 | 5 | 3.5 | 6 | 5 | 4 | 3 | 2 | 1 | 4.5 | 4 | 3 | 2.5 |
| 2265.6 | BkW | — | — | — | 0.45 | 0.54 | 0.60 | 0.69 | 0.75 | 0.84 | 0.90 | 1.05 | 1.05 | 1.14 | 1.20 | 1.35 | 1.41 |
| | Sheave/Mtr | — | — | — | B | B | B | A | A | A | A | A | A | C | C | C | C |
| | RPM | — | — | — | 439 | 481 | 517 | 555 | 592 | 626 | 659 | 691 | 722 | 751 | 779 | 805 | 831 |
| | Turns Open | — | — | — | 6 | 4.5 | 3 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 4.5 | 3.5 | 3 | 2 |
| 2360.0 | BkW | — | — | — | 0.51 | 0.60 | 0.66 | 0.75 | 0.81 | 0.90 | 0.96 | 1.11 | 1.20 | 1.26 | 1.35 | 1.41 | 1.50 |
| | Sheave/Mtr | — | — | — | B | B | A | A | A | A | A | A | C | C | C | C | C |
| | RPM | — | — | — | 455 | 496 | 530 | 567 | 603 | 637 | 669 | 701 | 730 | 759 | 787 | 813 | 839 |
| | Turns Open | — | — | — | 5.5 | 4 | 6 | 5 | 4 | 3 | 2 | 1.5 | 5 | 4 | 3.5 | 2.5 | 1.5 |
| 2454.4 | BkW | — | — | 0.51 | 0.60 | 0.66 | 0.75 | 0.81 | 0.90 | 0.96 | 1.11 | 1.20 | 1.26 | 1.35 | 1.41 | 1.50 | 1.56 |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | A | C | C | C | C | C |
| | RPM | — | — | 430 | 471 | 506 | 544 | 579 | 614 | 647 | 679 | 710 | 739 | 768 | 795 | 822 | 847 |
| | Turns Open | — | — | 6 | 4.5 | 3.5 | 6 | 5 | 3.5 | 3 | 2 | 1 | 5 | 4 | 3 | 2 | 1.5 |
| 2548.8 | BkW | — | — | 0.60 | 0.66 | 0.75 | 0.81 | 0.90 | 0.96 | 1.11 | 1.20 | 1.26 | 1.35 | 1.41 | 1.50 | 1.56 | 1.65 |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | — | 446 | 486 | 520 | 556 | 591 | 625 | 657 | 689 | 719 | 748 | 776 | 803 | 830 | 855 |
| | Turns Open | — | — | 6 | 4 | 3 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 5.5 | 4.5 | 3.5 | 3 | 2 | 1 |
| 2643.2 | BkW | — | 0.60 | 0.66 | 0.75 | 0.81 | 0.90 | 0.96 | 1.05 | 1.20 | 1.26 | 1.35 | 1.41 | 2.00 | 2.08 | 2.20 | 2.40 |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | 421 | 462 | 501 | 534 | 569 | 603 | 636 | 668 | 698 | 728 | 757 | 785 | 812 | 838 | 860 |
| | Turns Open | — | 6 | 5 | 3.5 | 6 | 5 | 4 | 3 | 2 | 1.5 | 5 | 4 | 2.618 | 1.87 | 1.122 | 0.748 |
| 2737.6 | BkW | — | 0.66 | 0.75 | 0.81 | 0.90 | 0.96 | 1.05 | 1.11 | 1.26 | 1.35 | 1.41 | 1.50 | 2.08 | 2.28 | 2.40 | 2.48 |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | 438 | 478 | 515 | 547 | 582 | 615 | 647 | 678 | 708 | 737 | 765 | 793 | 819 | 845 | 868 |
| | Turns Open | — | 6 | 4.5 | 3 | 5.5 | 4.5 | 3.5 | 3 | 2 | 1 | 5 | 4 | 2.244 | 1.87 | 1.122 | 0.748 |
| 2832.0 | BkW | — | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | 1.63 | 2.28 | 2.38 | 2.48 | 2.68 |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C |
| | RPM | — | 453 | 491 | 529 | 563 | 595 | 626 | 659 | 689 | 717 | 745 | 774 | 801 | 826 | 851 | 877 |
| | Turns Open | — | 5.5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 4.5 | 3.5 | 2.244 | 1.496 | 1.122 | 0.374 |
| 2926.4 | BkW | 0.73 | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | 1.63 | 1.71 | 2.38 | 2.48 | 2.68 | 2.88 |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | 431 | 469 | 504 | 542 | 575 | 607 | 637 | 670 | 699 | 726 | 754 | 783 | 809 | 834 | 859 | 884 |
| | Turns Open | 6 | 4 | 3.5 | 6 | 5 | 4 | 3 | 2 | 1.5 | 5.5 | 4.5 | 3.5 | 1.87 | 1.496 | 0.748 | 0.374 |
| 3020.8 | BkW | 0.81 | 0.88 | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | 1.63 | 1.71 | 1.86 | 2.58 | 2.68 | 2.88 | 3.06 |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | 448 | 485 | 520 | 556 | 588 | 619 | 649 | 680 | 708 | 736 | 765 | 791 | 817 | 841 | 868 | 891 |
| | Turns Open | 5.5 | 4.5 | 3 | 5.5 | 4.5 | 3.5 | 3 | 2 | 1 | 5 | 4 | 3 | 2.5 | 1.5 | 1 | 0.5 |
| 3115.2 | BkW | 0.88 | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | 1.63 | 1.71 | 1.86 | 1.93 | 2.68 | 2.88 | 2.98 | 3.08 |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | A | C | C | C | C | C | C | C |
| | RPM | 464 | 500 | 537 | 570 | 601 | 631 | 662 | 691 | 718 | 745 | 774 | 799 | 616 | 635 | 654 | 671 |
| | Turns Open | 5 | 4 | 6 | 5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 4.5 | 3.5 | 3 | 2 | 1.5 | 0.5 | 0 |
| 3209.6 | BkW | 0.96 | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | 1.63 | 1.71 | 1.86 | 1.93 | 2.00 | 2.88 | 2.98 | 3.08 | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C | — |
| | RPM | 480 | 515 | 551 | 583 | 613 | 642 | 674 | 701 | 728 | 754 | 783 | 808 | 623 | 641 | 660 | — |
| | Turns Open | 4.5 | 3 | 5.5 | 4.5 | 4 | 3 | 2 | 1.5 | 5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 0.5 | — |
| 3304.0 | BkW | 1.03 | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | 1.63 | 1.71 | 1.86 | 1.93 | 2.00 | 2.15 | 3.08 | 3.18 | 3.28 | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | C | C | C | C | C | C | C | — |
| | RPM | 496 | 530 | 565 | 596 | 625 | 654 | 684 | 711 | 738 | 766 | 792 | 816 | 629 | 649 | 666 | — |
| | Turns Open | 4 | 2.5 | 5.5 | 4 | 3.5 | 2.5 | 1.5 | 1 | 5 | 4 | 3 | 2.5 | 1.5 | 1 | 0 | — |
| 3398.4 | BkW | 1.11 | 1.26 | 1.33 | 1.41 | 1.56 | 1.63 | 1.71 | 1.86 | 2.00 | 2.08 | 2.15 | 2.30 | 3.18 | 3.28 | 3.48 | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | C | C | C | C | C | C | C | C | — |
| | RPM | 511 | 544 | 578 | 608 | 637 | 668 | 695 | 722 | 748 | 776 | 800 | 825 | 635 | 654 | 671 | — |
| | Turns Open | 3.5 | 6 | 5 | 4 | 3 | 2 | 1.5 | 5.5 | 4.5 | 3.5 | 3 | 2 | 1.5 | 0.5 | 0 | — |
| 3492.8 | BkW | 1.26 | 1.33 | 1.41 | 1.56 | 1.71 | 1.78 | 1.86 | 2.00 | 2.08 | 2.15 | 2.30 | 2.45 | 3.38 | 3.48 | — | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | C | C | C | C | C | C | C | — | — |
| | RPM | 526 | 561 | 592 | 621 | 649 | 679 | 706 | 732 | 758 | 785 | 809 | 833 | 857 | 882 | — | — |
| | Turns Open | 3 | 5.5 | 4.5 | 3.5 | 3 | 2 | 1 | 5 | 4 | 3.5 | 2.5 | 2 | 1 | 0.5 | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor.

# Performance data (cont)

## 50VQP240 BLOWER PERFORMANCE DATA (cont)

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 3587.2 | BkW | 1.33 | 1.41 | 1.56 | 1.63 | 1.71 | 1.86 | 2.00 | 2.08 | 2.15 | 2.30 | 2.45 | 2.53 | 2.60 | 2.75 | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | A | C | C | C | C | C | C | C | — | — |
| | RPM | 544 | 575 | 605 | 633 | 661 | 691 | 717 | 742 | 767 | 794 | 818 | 842 | 867 | 890 | — | — |
| | Turns Open | 6 | 5 | 4 | 3 | 2.5 | 1.5 | 1 | 4.5 | 4 | 3 | 2.5 | 1.5 | 1 | 0 | — | — |
| 3681.6 | BkW | 1.41 | 1.56 | 1.71 | 1.78 | 1.86 | 2.00 | 2.15 | 2.23 | 2.30 | 2.45 | 2.60 | 2.68 | 2.75 | 2.90 | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | C | C | C | C | C | C | — | — |
| | RPM | 555 | 589 | 618 | 646 | 676 | 702 | 728 | 753 | 779 | 803 | 827 | 850 | 875 | 898 | — | — |
| | Turns Open | 5.5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 5 | 4.5 | 3.5 | 2.5 | 2 | 1 | 0.5 | 0 | — | — |
| 3776.0 | BkW | 1.56 | 1.63 | 1.71 | 1.86 | 2.00 | 2.15 | 2.23 | 2.30 | 2.45 | 2.60 | 2.68 | 2.75 | 2.90 | 3.05 | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | C | C | C | C | C | C | — | — |
| | RPM | 572 | 601 | 630 | 657 | 686 | 712 | 737 | 762 | 789 | 812 | 836 | 859 | 883 | 905 | — | — |
| | Turns Open | 5 | 4 | 3 | 2.5 | 1.5 | 1 | 4.5 | 4 | 3 | 2.5 | 1.5 | 1 | 0.5 | 0 | — | — |
| 3870.4 | BkW | 1.71 | 1.78 | 1.86 | 2.00 | 2.15 | 2.23 | 2.30 | 2.45 | 2.60 | 2.75 | 2.83 | 2.90 | 3.05 | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | C | C | C | C | C | C | — | — | — |
| | RPM | 589 | 617 | 645 | 672 | 700 | 726 | 751 | 775 | 801 | 824 | 847 | 872 | 894 | — | — | — |
| | Turns Open | 4.5 | 3.5 | 3 | 2 | 1 | 5 | 4.5 | 3.5 | 2.5 | 2 | 1.5 | 0.5 | 0 | — | — | — |
| 3964.8 | BkW | 1.86 | 1.93 | 2.00 | 2.15 | 2.30 | 2.38 | 2.45 | 2.60 | 2.75 | 2.99 | 3.05 | 3.13 | 3.20 | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | C | C | C | C | C | C | — | — | — |
| | RPM | 605 | 633 | 660 | 689 | 714 | 739 | 763 | 790 | 813 | 836 | 858 | 882 | 904 | — | — | — |
| | Turns Open | 4 | 3 | 2.5 | 1.5 | 1 | 5 | 4 | 3 | 2.5 | 1.5 | 1 | 0.5 | 0 | — | — | — |
| 4059.2 | BkW | 1.93 | 2.00 | 2.15 | 2.30 | 2.45 | 2.53 | 2.60 | 2.75 | 2.99 | 3.05 | 3.20 | 3.35 | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | C | C | C | C | C | C | C | C | — | — | — | — |
| | RPM | 621 | 649 | 675 | 703 | 728 | 752 | 776 | 802 | 827 | 847 | 869 | 893 | — | — | — | — |
| | Turns Open | 3.5 | 2.5 | 2 | 1 | 5 | 4.5 | 3.5 | 2.5 | 2 | 1.5 | 1 | 0 | — | — | — | — |
| 4153.6 | BkW | 2.08 | 2.15 | 2.30 | 2.45 | 2.60 | 2.75 | 2.83 | 2.99 | 3.05 | 3.20 | 3.35 | 3.50 | — | — | — | — |
| | Sheave/Mtr | A | A | A | C | C | C | C | C | C | C | C | C | — | — | — | — |
| | RPM | 637 | 664 | 690 | 717 | 742 | 766 | 791 | 814 | 836 | 858 | 882 | 904 | — | — | — | — |
| | Turns Open | 3 | 2 | 1.5 | 5.5 | 4.5 | 4 | 3 | 2.5 | 2 | 1 | 0.5 | 0 | — | — | — | — |
| 4248.0 | BkW | 2.23 | 2.30 | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | 3.13 | 3.20 | 3.35 | 3.50 | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | C | C | C | C | C | C | C | C | — | — | — | — | — |
| | RPM | 653 | 679 | 707 | 731 | 755 | 779 | 804 | 826 | 848 | 870 | 893 | — | — | — | — | — |
| | Turns Open | 2.5 | 1.5 | 1 | 5 | 4 | 3.5 | 3 | 2 | 1.5 | 1 | 0 | — | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor.

## 50VQP300 BLOWER PERFORMANCE DATA

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 2643.2 | BkW | — | — | — | — | — | 0.69 | 0.75 | 0.84 | 0.99 | 1.05 | 1.14 | 1.29 | 1.44 | 1.59 | 1.74 | 1.88 |
| | Sheave/Mtr | — | — | — | — | — | B | B | B | A | A | A | A | A | A | C | C |
| | RPM | — | — | — | — | — | 533 | 572 | 606 | 640 | 676 | 712 | 746 | 783 | 821 | 859 | 901 |
| | Turns Open | — | — | — | — | — | 5.5 | 4 | 3 | 6 | 4.5 | 3.5 | 2 | 1 | 0 | 1.5 | 0.5 |
| 2737.6 | BkW | — | — | — | — | — | 0.75 | 0.84 | 0.90 | 1.05 | 1.14 | 1.20 | 1.35 | 1.50 | 1.62 | 1.80 | 1.94 |
| | Sheave/Mtr | — | — | — | — | — | B | B | B | A | A | A | A | A | C | C | C |
| | RPM | — | — | — | — | — | 544 | 582 | 619 | 652 | 686 | 719 | 754 | 789 | 823 | 860 | 902 |
| | Turns Open | — | — | — | — | — | 5 | 4 | 2.5 | 5.5 | 4 | 3 | 2 | 0.5 | 2.5 | 1.5 | 0 |
| 2832.0 | BkW | — | — | — | — | 0.75 | 0.84 | 0.90 | 1.05 | 1.14 | 1.20 | 1.35 | 1.50 | 1.59 | 1.65 | 1.88 | 2.03 |
| | Sheave/Mtr | — | — | — | — | B | B | B | B | A | A | A | A | A | C | C | C |
| | RPM | — | — | — | — | 521 | 558 | 595 | 628 | 663 | 697 | 728 | 762 | 796 | 828 | 863 | 903 |
| | Turns Open | — | — | — | — | 6 | 4.5 | 3 | 2 | 5 | 4 | 2.5 | 1.5 | 0.5 | 2 | 1 | 0 |
| 2926.4 | BkW | — | — | — | — | 0.84 | 0.90 | 1.05 | 1.11 | 1.20 | 1.29 | 1.44 | 1.56 | 1.65 | 1.80 | 1.94 | 2.09 |
| | Sheave/Mtr | — | — | — | — | B | B | B | A | A | A | A | A | A | C | C | C |
| | RPM | — | — | — | — | 536 | 572 | 608 | 640 | 674 | 705 | 737 | 769 | 799 | 832 | 866 | 904 |
| | Turns Open | — | — | — | — | 5.5 | 4 | 3 | 6 | 4.5 | 3.5 | 2.5 | 1.5 | 0 | 2 | 1 | 0 |
| 3020.8 | BkW | — | — | — | — | 0.90 | 0.99 | 1.11 | 1.20 | 1.35 | 1.41 | 1.50 | 1.71 | 1.80 | 1.94 | 2.09 | — |
| | Sheave/Mtr | — | — | — | — | B | B | B | A | A | A | A | A | A | C | C | — |
| | RPM | — | — | — | — | 548 | 585 | 618 | 652 | 685 | 715 | 747 | 778 | 807 | 836 | 868 | — |
| | Turns Open | — | — | — | — | 5 | 3.5 | 2.5 | 5.5 | 4 | 3 | 2 | 1 | 0 | 2 | 1 | — |
| 3115.2 | BkW | — | — | — | 0.90 | 0.96 | 1.05 | 1.20 | 1.29 | 1.41 | 1.56 | 1.65 | 1.80 | 2.48 | 2.68 | 2.88 | — |
| | Sheave/Mtr | — | — | — | B | B | B | A | A | A | A | A | A | C | C | C | — |
| | RPM | — | — | — | 522 | 562 | 599 | 631 | 664 | 694 | 725 | 756 | 784 | 815 | 845 | 874 | — |
| | Turns Open | — | — | — | 6 | 4.5 | 3 | 6 | 5 | 4 | 3 | 1.5 | 1 | 2 | 1 | 0.5 | — |
| 3209.6 | BkW | — | — | — | 0.96 | 1.05 | 1.14 | 1.26 | 1.35 | 1.50 | 1.65 | 1.71 | 1.86 | 2.68 | 2.88 | 3.08 | — |
| | Sheave/Mtr | — | — | — | B | B | B | A | A | A | A | A | A | C | C | C | — |
| | RPM | — | — | — | 537 | 576 | 612 | 643 | 676 | 705 | 736 | 763 | 793 | 823 | 850 | 880 | — |
| | Turns Open | — | — | — | 5.5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 0.5 | 2 | 1 | 0.5 | — |
| 3304.0 | BkW | — | — | — | 1.05 | 1.14 | 1.20 | 1.35 | 1.50 | 1.56 | 1.71 | 1.86 | 2.00 | 2.80 | 3.00 | 3.20 | — |
| | Sheave/Mtr | — | — | — | B | B | B | A | A | A | A | A | A | C | C | C | — |
| | RPM | — | — | — | 551 | 589 | 622 | 655 | 685 | 716 | 746 | 776 | 802 | 829 | 858 | 886 | — |
| | Turns Open | — | — | — | 5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 1 | 0 | 1.5 | 1 | 0 | — |
| 3398.4 | BkW | — | — | 1.05 | 1.11 | 1.20 | 1.35 | 1.50 | 1.56 | 1.71 | 1.86 | 1.94 | 2.09 | 2.88 | 3.08 | 3.28 | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | A | A | C | C | C | — |
| | RPM | — | — | 526 | 565 | 600 | 634 | 665 | 696 | 727 | 754 | 783 | 809 | 837 | 865 | 891 | — |
| | Turns Open | — | — | 6 | 4.5 | 3 | 6 | 5 | 4 | 3 | 2 | 1 | 0 | 1.5 | 1 | 0 | — |
| 3492.8 | BkW | — | — | 1.11 | 1.26 | 1.35 | 1.41 | 1.56 | 1.71 | 1.86 | 1.94 | 2.00 | 2.15 | 3.08 | 3.28 | 3.48 | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | A | C | C | C | C | — |
| | RPM | — | — | 541 | 579 | 613 | 647 | 677 | 707 | 737 | 764 | 793 | 818 | 846 | 871 | 898 | — |
| | Turns Open | — | — | 5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 0.5 | 2.5 | 1.5 | 0.5 | 0 | — |
| 3587.2 | BkW | — | — | 1.26 | 1.33 | 1.41 | 1.56 | 1.71 | 1.86 | 1.93 | 2.00 | 2.15 | 2.30 | 3.28 | 3.48 | 3.68 | — |
| | Sheave/Mtr | — | — | B | B | B | A | A | A | A | A | A | C | C | C | C | — |
| | RPM | — | — | 554 | 591 | 626 | 659 | 688 | 718 | 746 | 774 | 802 | 829 | 640 | 657 | 677 | — |
| | Turns Open | — | — | 5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 1 | 0 | 2 | 1.5 | 0.5 | 0 | — |
| 3681.6 | BkW | — | 1.18 | 1.26 | 1.41 | 1.56 | 1.71 | 1.78 | 1.86 | 2.00 | 2.15 | 2.30 | 2.45 | 3.48 | 3.68 | — | — |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | A | A | C | C | C | — | — |
| | RPM | — | 531 | 569 | 605 | 639 | 669 | 702 | 729 | 757 | 785 | 811 | 838 | 645 | 663 | — | — |
| | Turns Open | — | 6 | 4.5 | 3 | 6 | 5 | 3.5 | 3 | 2 | 1 | 0 | 2 | 1 | 0.5 | — | — |
| 3776.0 | BkW | — | 1.26 | 1.41 | 1.56 | 1.71 | 1.78 | 1.86 | 2.00 | 2.15 | 2.30 | 2.45 | 2.53 | 3.48 | 3.68 | — | — |
| | Sheave/Mtr | — | B | B | B | A | A | A | A | A | A | C | C | C | C | — | — |
| | RPM | — | 545 | 582 | 618 | 651 | 683 | 710 | 739 | 767 | 794 | 821 | 845 | 651 | 669 | — | — |
| | Turns Open | — | 5 | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 0.5 | 2.5 | 1.5 | 1 | 0 | — | — |
| 3870.4 | BkW | 1.26 | 1.41 | 1.56 | 1.63 | 1.71 | 1.86 | 2.00 | 2.15 | 2.30 | 2.45 | 2.53 | 2.60 | 3.68 | 3.88 | — | — |
| | Sheave/Mtr | B | B | B | B | A | A | A | A | A | A | C | C | C | C | — | — |
| | RPM | 523 | 560 | 596 | 631 | 661 | 692 | 722 | 750 | 778 | 804 | 831 | 854 | 657 | 676 | — | — |
| | Turns Open | 6 | 4.5 | 3.5 | 2 | 5 | 4 | 3 | 2 | 1 | 0 | 2 | 1.5 | 0.5 | 0 | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**E** — High rpm/Large Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor, E = High rpm/Large Motor.

# Performance data (cont)

## 50VQP300 BLOWER PERFORMANCE DATA (cont)

| AIRFLOW (l/s) | | EXTERNAL STATIC PRESSURE (Pa) | | | | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | 0 | 25 | 50 | 75 | 100 | 125 | 150 | 175 | 200 | 225 | 250 | 275 | 300 | 325 | 350 | 375 |
| 3964.8 | BkW | 1.41 | 1.48 | 1.56 | 1.71 | 1.86 | 2.00 | 2.15 | 2.30 | 2.38 | 2.45 | 2.60 | 2.75 | 3.88 | 4.08 | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | A | A | C | C | C | C | — | — |
| | RPM | 538 | 574 | 609 | 640 | 673 | 703 | 733 | 761 | 788 | 812 | 838 | 863 | 888 | 912 | — | — |
| | Turns Open | 5.5 | 4 | 3 | 6 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 0 | 2 | 1 | 0.5 | 0 | — | — |
| 4059.2 | BkW | 1.41 | 1.56 | 1.71 | 1.86 | 2.00 | 2.15 | 2.30 | 2.38 | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | — | — | — |
| | Sheave/Mtr | B | B | B | A | A | A | A | A | A | C | C | C | C | — | — | — |
| | RPM | 553 | 588 | 620 | 653 | 685 | 715 | 744 | 771 | 796 | 822 | 847 | 872 | 896 | — | — | — |
| | Turns Open | 5 | 3.5 | 2.5 | 5.5 | 4 | 3 | 2.5 | 1.5 | 0.5 | 2.5 | 1.5 | 1 | 0 | — | — | — |
| 4153.6 | BkW | 1.56 | 1.71 | 1.86 | 2.00 | 2.15 | 2.30 | 2.38 | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | 3.20 | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | A | C | C | C | C | — | — | — |
| | RPM | 568 | 602 | 633 | 666 | 697 | 726 | 755 | 782 | 806 | 832 | 857 | 881 | 904 | — | — | — |
| | Turns Open | 4.5 | 3 | 6 | 5 | 4 | 3 | 2 | 1 | 0 | 2 | 1.5 | 0.5 | 0 | — | — | — |
| 4248.0 | BkW | 1.71 | 1.80 | 1.94 | 2.09 | 2.24 | 2.39 | 2.54 | 2.69 | 2.84 | 2.99 | 3.14 | 3.29 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | C | C | C | C | — | — | — | — |
| | RPM | 581 | 613 | 646 | 678 | 706 | 735 | 763 | 791 | 817 | 842 | 867 | 889 | — | — | — | — |
| | Turns Open | 4 | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 1 | 2.5 | 2 | 1 | 0 | — | — | — | — |
| 4342.4 | BkW | 1.78 | 1.86 | 2.00 | 2.15 | 2.30 | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | 3.20 | 3.35 | — | — | — | — |
| | Sheave/Mtr | B | B | A | A | A | A | A | A | C | C | C | C | — | — | — | — |
| | RPM | 598 | 623 | 656 | 687 | 715 | 744 | 772 | 799 | 825 | 850 | 872 | 896 | — | — | — | — |
| | Turns Open | 3.5 | 2.5 | 5 | 4 | 3 | 2.5 | 1 | 0.5 | 2 | 1.5 | 1 | 0 | — | — | — | — |
| 4436.8 | BkW | 1.86 | 2.00 | 2.15 | 2.30 | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | 3.20 | 3.35 | — | — | — | — | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | A | C | C | C | — | — | — | — | — |
| | RPM | 605 | 637 | 666 | 697 | 727 | 755 | 783 | 809 | 835 | 858 | 882 | — | — | — | — | — |
| | Turns Open | 3 | 6 | 5 | 4 | 3 | 2 | 1 | 0 | 2 | 1.5 | 0.5 | — | — | — | — | — |
| 4531.2 | BkW | 2.00 | 2.15 | 2.30 | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | 3.20 | 3.35 | 3.50 | — | — | — | — | — |
| | Sheave/Mtr | B | A | A | A | A | A | A | C | C | C | C | — | — | — | — | — |
| | RPM | 618 | 647 | 678 | 708 | 738 | 766 | 793 | 819 | 844 | 867 | 891 | — | — | — | — | — |
| | Turns Open | 2.5 | 5.5 | 4.5 | 3.5 | 2.5 | 1.5 | 0.5 | 2.5 | 1.5 | 1 | 0.5 | — | — | — | — | — |
| 4625.6 | BkW | 2.15 | 2.30 | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | 3.20 | 3.35 | 3.50 | 3.65 | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | A | C | C | C | C | — | — | — | — | — |
| | RPM | 631 | 662 | 690 | 720 | 749 | 777 | 803 | 827 | 852 | 877 | 900 | — | — | — | — | — |
| | Turns Open | 6 | 5 | 4 | 3 | 2 | 1 | 0 | 2 | 1.5 | 0.5 | 0 | — | — | — | — | — |
| 4720.0 | BkW | 2.30 | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | 3.20 | 3.35 | 3.50 | 3.65 | — | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | A | C | C | C | — | — | — | — | — | — |
| | RPM | 642 | 672 | 702 | 731 | 760 | 785 | 811 | 837 | 862 | 886 | — | — | — | — | — | — |
| | Turns Open | 6 | 4.5 | 3.5 | 2.5 | 2 | 1 | 0 | 2 | 1 | 0.5 | — | — | — | — | — | — |
| 4814.4 | BkW | 2.45 | 2.60 | 2.75 | 2.90 | 3.05 | 3.20 | 3.35 | 3.50 | 3.65 | 3.80 | — | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | C | E | — | — | — | — | — | — |
| | RPM | 655 | 685 | 714 | 743 | 769 | 798 | 822 | 847 | 872 | 896 | — | — | — | — | — | — |
| | Turns Open | 5.5 | 4 | 3 | 2 | 1.5 | 0.5 | 2.5 | 1.5 | 0.5 | 0 | — | — | — | — | — | — |
| 4908.8 | BkW | 2.60 | 2.75 | 2.90 | 3.05 | 3.20 | 3.35 | 3.50 | 3.65 | 3.80 | — | — | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | A | C | C | E | — | — | — | — | — | — | — |
| | RPM | 668 | 697 | 726 | 752 | 782 | 806 | 832 | 857 | 882 | — | — | — | — | — | — | — |
| | Turns Open | 5 | 4 | 2.5 | 2 | 1 | 0 | 2 | 1 | 0.5 | — | — | — | — | — | — | — |
| 5003.2 | BkW | 2.75 | 2.90 | 3.05 | 3.20 | 3.35 | 3.50 | 3.65 | 3.80 | 3.95 | — | — | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | C | E | E | — | — | — | — | — | — | — |
| | RPM | 680 | 709 | 737 | 763 | 790 | 817 | 842 | 867 | 889 | — | — | — | — | — | — | — |
| | Turns Open | 4.5 | 3.5 | 2.5 | 1.5 | 0.5 | 2.5 | 1.5 | 1 | 0 | — | — | — | — | — | — | — |
| 5097.6 | BkW | 2.90 | 3.05 | 3.20 | 3.35 | 3.50 | 3.65 | 3.80 | 3.95 | 4.10 | — | — | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | C | E | E | E | — | — | — | — | — | — | — |
| | RPM | 691 | 717 | 745 | 772 | 799 | 825 | 850 | 873 | 897 | — | — | — | — | — | — | — |
| | Turns Open | 4 | 3 | 2 | 1 | 0 | 2 | 1.5 | 0.5 | 0 | — | — | — | — | — | — | — |
| 5192.0 | BkW | 3.05 | 3.20 | 3.35 | 3.50 | 3.65 | 3.80 | 3.95 | 4.10 | — | — | — | — | — | — | — | — |
| | Sheave/Mtr | A | A | A | A | A | E | E | E | — | — | — | — | — | — | — | — |
| | RPM | 704 | 729 | 756 | 783 | 810 | 836 | 859 | 883 | — | — | — | — | — | — | — | — |
| | Turns Open | 3.5 | 2.5 | 1.5 | 1 | 0 | 1.5 | 1 | 0.5 | — | — | — | — | — | — | — | — |

LEGEND

**A** — Standard rpm/Standard Motor
**B** — Low rpm/Standard Motor
**bhp** — Brake Horsepower
**C** — High rpm/Standard Motor
**E** — High rpm/Large Motor
**ESP** — External Static Pressure

NOTES:
1. Unit is factory shipped with standard rpm sheave and drive at 2.5 turns open. Other speeds require field selection.
2. For applications requiring higher static pressures, contact your local Carrier representative. Performance data does not include drive losses and is based on sea level conditions.
3. All airflow is rated at lowest voltage. If unit is dual voltage rated, data is based on lowest voltage.
4. A = Standard rpm/Standard Motor, B = Low rpm/Standard Motor, C = High rpm/Standard Motor, E = High rpm/Large Motor.

# Electrical data

## ELECTRICAL DATA — STANDARD UNIT

| 50VQP UNIT SIZE | VOLTAGE (V-Ph-Hz) | MIN/MAX VOLTAGE | BLOWER OPTION | COMPRESSOR | | | FAN MOTOR FLA | TOTAL UNIT FLA | MCA | MAX FUSE/ HACR |
|---|---|---|---|---|---|---|---|---|---|---|
| | | | | qty | RLA | LRA | | | | |
| **084** | 380/420-3-50 | 360/440 | A,B,C | 1 | 11.2 | 75.0 | 1.8 | 13.0 | 15.8 | 25 |
| | | | E | 1 | 11.2 | 75.0 | 2.5 | 13.7 | 16.5 | 25 |
| **096** | 380/420-3-50 | 360/440 | A,B,C | 1 | 12.2 | 101.0 | 2.5 | 14.7 | 17.8 | 25 |
| **120** | 380/420-3-50 | 360/440 | A,B,C | 1 | 16.7 | 111.0 | 3.6 | 20.3 | 24.5 | 40 |
| | | | E | 1 | 16.7 | 111.0 | 4.9 | 21.6 | 25.8 | 40 |
| **150** | 380/420-3-50 | 360/440 | A,B,C | 1 | 18.6 | 118.0 | 4.9 | 23.5 | 28.2 | 45 |
| | | | E | 1 | 18.6 | 118.0 | 7.8 | 26.4 | 31.1 | 45 |
| **168** | 380/420-3-50 | 360/440 | A,B,C | 2 | 11.2 | 75.0 | 3.4 | 25.8 | 28.6 | 35 |
| **192** | 380/420-3-50 | 360/440 | A,B,C | 2 | 12.2 | 101.0 | 4.9 | 29.3 | 32.3 | 40 |
| **240** | 380/420-3-50 | 360/440 | A,B,C | 2 | 16.7 | 111.0 | 7.8 | 41.2 | 45.4 | 60 |
| **300** | 380/420-3-50 | 360/440 | A,B,C | 2 | 18.6 | 118.0 | 7.8 | 45.0 | 49.7 | 60 |
| | | | E | 2 | 18.6 | 118.0 | 12.2 | 49.4 | 54.0 | 70 |

LEGEND

**FLA** — Full Load Amps
**HACR** — Heating, Air Conditioning, and Refrigeration
**LRA** — Locked Rotor Amps
**MCA** — Minimum Circuit Amps
**RLA** — Rated Load Amps

NOTES:
1. HACR circuit breaker in U.S.A. only.
2. All fuses Class RK-5.

## ELECTRICAL DATA — DUAL POINT POWER UNIT

| 50VQP UNIT SIZE | VOLTAGE (V-Ph-Hz) | MIN/MAX VOLTAGE | BLOWER OPTION | COMPRESSOR | | | | | | EMERGENCY POWER SUPPLY | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | | | | qty | RLA | LRA | TOTAL COMP FLA | COMP MCA | COMP MAX FUSE | FAN MOTOR FLA | FAN MCA | FAN MAX FUSE |
| **084** | 380/420-3-50 | 360/440 | A,B,C | 1 | 11.2 | 75.0 | 11.2 | 14.0 | 25 | 1.8 | 2.3 | 15 |
| | | | E | 1 | 11.2 | 75.0 | 11.2 | 14.0 | 25 | 2.5 | 3.1 | 15 |
| **096** | 380/420-3-50 | 360/440 | A,B,C | 1 | 12.2 | 101.0 | 12.2 | 15.3 | 25 | 2.5 | 3.1 | 15 |
| **120** | 380/420-3-50 | 360/440 | A,B,C | 1 | 16.7 | 111.0 | 16.7 | 20.9 | 35 | 3.6 | 4.5 | 15 |
| | | | E | 1 | 16.7 | 111.0 | 16.7 | 20.9 | 35 | 4.9 | 6.1 | 15 |
| **150** | 380/420-3-50 | 360/440 | A,B,C | 1 | 18.6 | 118.0 | 18.6 | 23.3 | 40 | 4.9 | 6.1 | 15 |
| | | | E | 1 | 18.6 | 118.0 | 18.6 | 23.3 | 40 | 7.8 | 9.8 | 15 |
| **168** | 380/420-3-50 | 360/440 | A,B,C | 2 | 11.2 | 75.0 | 22.4 | 25.2 | 35 | 3.4 | 4.3 | 15 |
| **192** | 380/420-3-50 | 360/440 | A,B,C | 2 | 12.2 | 101.0 | 24.4 | 27.4 | 35 | 4.9 | 6.1 | 15 |
| **240** | 380/420-3-50 | 360/440 | A,B,C | 2 | 16.7 | 111.0 | 33.4 | 37.6 | 50 | 7.8 | 9.8 | 15 |
| **300** | 380/420-3-50 | 360/440 | A,B,C | 2 | 18.6 | 118.0 | 37.2 | 41.9 | 60 | 7.8 | 9.8 | 15 |
| | | | E | 2 | 18.6 | 118.0 | 37.2 | 41.9 | 60 | 12.2 | 15.3 | 25 |

LEGEND

**FLA** — Full Load Amps
**HACR** — Heating, Air Conditioning, and Refrigeration
**LRA** — Locked Rotor Amps
**MCA** — Minimum Circuit Amps
**RLA** — Rated Load Amps

NOTES:
1. HACR circuit breaker in U.S.A. only.
2. All fuses Class RK-5.

# Typical piping and wiring

**50VQP**




NOTES:
1. Wiring and piping are general guides only. They are not intended for or to include all details for a specific installation.
2. Return air ductwork can be field installed if desired. See base unit dimensions for return air duct pilot hole locations.
3. All wiring must comply with applicable local and national codes.
4. All piping must follow standard refrigerant piping techniques. Refer to Carrier System Design Manual, Part 3, for details.
5. For maximum working pressure, see installation instructions.

# Typical control wiring schematics

## 50VQP084-168 WITH COMPLETE C CONTROL (TYPICAL)




LEGEND

| | |
|---|---|
| **AL** | — Alarm Relay |
| **BC** | — Blower Contactor |
| **CB** | — Circuit Breaker |
| **CC** | — Compressor Contactor |
| **CO** | — Sensor, Condensate Overflow |
| **DPP** | — Dual Point Power |
| **DS** | — Disconnect Switch |
| **FP1** | — Sensor, Water Coil Freeze Protection |
| **FP2** | — Sensor, Air Coil Freeze Protection |
| **HP** | — High-Pressure Switch |
| **HPWS** | — High Pressure Water Switch |
| **JW3** | — Clippable Field Selection Jumper |
| **LOC** | — Loss of Charge Pressure Switch |
| **MV** | — Motorized Valve |
| **PDB1** | — Power Distribution Block |
| **PDB2** | — Power Distribution Block Dual Point Option |
| **RVS** | — Reversing Valve Solenoid |
| **TRANS** | — Transformer |

- Factory Line Voltage Wiring
- Factory Low Voltage Wiring
- Field Line Voltage Wiring
- Field Low Voltage Wiring
- Printed Circuit Trace
- Optional Wiring
- Relay/Contactor Coil
- Thermistor
- Condensate Pan
- Circuit Breaker
- Ground
- Solenoid Coil
- Relay Contacts - N.O.
- Relay Contacts - N.C.
- Temperature Switch
- Switch - Low Pressure
- Switch - High Pressure
- Wire Nut

NOTES:

1. Compressor and blower motor thermally protected internally.
2. All wiring to the unit must comply with NEC (National Electrical Code, U.S.A.) and local codes.
3. 380/420-v transformers will be connected for 380-v operation. For 420-v operation, disconnect VIO lead at L1, and attach BRN lead to L1. Close open end of VIO lead.
4. FPI jumper provides low temperature protection for WATER. When using ANTIFREEZE solutions, cut JW3 jumper.
5. Typical heat pump thermostat wiring shown. Refer to thermostat installation instructions for wiring to the unit. Thermostat wiring must be “Class 1” and voltage rating equal to or greater than unit supply voltage.
6. 24-v alarm signal shown. For dry alarm contact, cut JW1 jumper and dry contact will be available between AL1 and AL2.
7. Transformer secondary ground via Complete C board standoffs and screws to control box. (Ground available from top two stand-offs as shown.)
8. For dual point power option, blower wires (3 qty) will go to PDB2 only.

# Typical control wiring schematics (cont)

## 50VQP084-168 WITH DELUXE D CONTROL (TYPICAL)




LEGEND

**AL** — Alarm Relay
**BC** — Blower Contactor
**CB** — Circuit Breaker
**CC** — Compressor Contactor
**CO** — Sensor, Condensate Overflow
**DPP** — Dual Point Power
**DS** — Disconnect Switch
**FP1** — Sensor, Water Coil Freeze Protection
**FP2** — Sensor, Air Coil Freeze Protection
**HP** — High-Pressure Switch
**HPWS** — High Pressure Water Switch
**JW3** — Clippable Field Selection Jumper
**LOC** — Loss of Charge Pressure Switch
**MV** — Motorized Valve
**PDB** — Power Distribution Block
**PDB2** — Power Distribution Block Dual Point Option
**RVS** — Reversing Valve Solenoid
**TRANS** — Transformer

Factory Line Voltage Wiring
Factory Low Voltage Wiring
Field Line Voltage Wiring
Field Low Voltage Wiring
Printed Circuit Trace
Optional Wiring
Relay/Contactor Coil
Thermistor
Condensate Pan
Circuit Breaker

Ground
Solenoid Coil
Relay Contacts - N.O.
Relay Contacts - N.C.
Temperature Switch
Switch - Low Pressure
Switch - High Pressure
Wire Nut

NOTES:
1. Compressor and blower motor thermally protected internally.
2. All wiring to the unit must comply with NEC (National Electrical Code, U.S.A.) and local codes.
3. 208/230-v transformer will be connected for 208-v operation. For 230-v operation, disconnect RED lead at L1, and attach ORG lead to L1. Insulate open end of RED lead with insulating tape.
4. FP1 thermistor provides freeze protection for WATER. When using ANTIFREEZE solution, cut JW3 jumper.
5. Typical heat pump thermostat wiring shown. Refer to thermostat installation instructions for wiring to the unit. Thermostat wiring must be “Class 1” and voltage rating equal to or greater than unit supply voltage.
6. 24-v alarm signal shown. For dry alarm contact, cut AL2 DRY (JW4) jumper and dry contact will be available between AL1 and AL2.
7. Transformer secondary ground via Deluxe D board standoffs and screws to control box. (Ground available from top two standoffs as shown.)
8. For dual point power option, blower wires (3 qty) will go to PDB2 only.

## PREMIERLINK™ CONTROLLER APPLICATIONS WITH COMPLETE C CONTROL




## PREMIERLINK CONTROLLER APPLICATIONS WITH DELUXE D CONTROL



# Application data

Aquazone™ water source heat pump products are available in a flexible, efficient array of models, which can be used in all types of water loop, ground water, and ground loop type systems. Utilize Aquazone products to provide optimal energy efficient solutions and adapt to the most challenging design requirements.

**AQUAZONE PRODUCT GUIDE**

| 50 SERIES | TYPE SIZE (tons) | APPLICATION |
|---|---|---|
| **50HQP,VQP** | Large Capacity 6-10 (HQP) 7-25 (VQP) | Environmentally sound unit with Puron® refrigerant (R-410A) designed to handle large zoned areas for all geothermal and boiler/tower applications. |
| **50PC** | Compact 1 1/4-5 | Compact WSHP with Puron refrigerant (R-410A) for boiler/tower, ground water, or ground loop systems. |
| **50PS** | Premium Efficiency 1/2-6 | Premium, ultra efficient unit with Puron refrigerant (R-410A) for new boiler/tower, ground water, or ground loop systems. |
| **50PEC** | High Efficiency Console 3/4-1 1/2 | Efficient console unit with Puron refrigerant (R-410A) and attractive design for finished interior, under-window installations. |
| **50PT** | Premium Efficiency 2-6 | Premium, ultra efficient 2-stage unit with Puron refrigerant (R-410A) for new boiler/ tower, ground water, or ground loop systems. |
| **50PSW** | Water-to-Water 3-30 | Efficient unit with Puron refrigerant (R-410A) serves as an alternative to preheat or cool air. Unit can be used as a stand-alone or supplemental boiler/chiller in most hydronic heating applications. Also conditions process fluids, lubricants, and refrigerants. |
| **50RTP** | Rooftop 3-20 | Economical solution for indoor air quality (IAQ) problems and tempering ventilation air. |
| **50VS** | Premium Efficiency Vertical Stack Heat Pump 3/4 to 3 Tons | Ultra efficient unit with environmentally sound Puron refrigerant (R-410A) for boiler/tower and geothermal applications (condominiums, hotels, etc.). Stacked design allows for common piping and simplistic design. |

## Water loop system

Water loop (or boiler/tower) system applications typically include a number of units plumbed to a common piping system. For optimal performance, this system should be designed between 2.41 and 3.23 L/s per kW of cooling capacity. The system is comprised of highly efficient packaged reverse cycle heat pump units interconnected by a water loop. The water circuit serves as both a sink and source for heat absorption and rejection and is designed for entering water temperatures between 15 C and 35 C. Within this temperature range units can heat or cool as required from the same water source. Transferring heat from warm to cold spaces in the building, whenever they coexist, conserves energy rather than creating new heat.

Refer to the **Carrier Water Source Heat Pump System Design Guide** for assistance with the design of water loop systems. The guide includes a practical approach for the latest and most current design recommendations including:

- Product application including horizontal, vertical, console, rooftop and water-to-water applications.
- Ventilation methods and system design including energy recovery.
- Acoustical considerations for different product types.
- Addressing indoor air quality (IAQ) issues such as condensate removal, humidity control.
- Air distribution design including diffuser selection/ layout and ductwork design.
- Hydronic system design including pipe sizing/layout and boiler/tower sizing.
- Control configurations such as stand alone, DDC, DCV, and VVT® controls.
- WSHP Efficiency/Operational Cost Comparison chart.
- System variations such as a system without a boiler, variable pumping, and VAV for interior use.

## Ground water systems

To utilize Aquazone units in ground water applications, extended range should be specified. This will provide factory-installed insulation on the coaxial coil to prevent condensate from dripping when entering water temperatures are below 15 C. In addition, the copper coaxial coil installed on the Aquazone units may not be suitable for all water conditions. Refer to the Water Conditioning section for proper coaxial coil material selection.

**Surface water system —** This system is typically located near a lake or pond. In this application, the loop can be submerged in a series of coils beneath the water surface. The number of coils required depends on system load and design. This application requires minimum piping and excavation.

**Open loop system —** This system is used where ground water is plentiful. In this application, ground water is pumped through supply piping from the well to the building. The water is then pumped back into the ground through a discharge well as it leaves the building. An additional heat exchanger is usually installed between the building water piping system and the ground water piping system. This design limits the amount of piping and excavation required.

Aquazone units are provided with a standard TXV and are rated to extremely low temperatures to self-adjust the refrigeration circuit, therefore water regulating valves are not required on open loop systems. To conserve water on this type of system, a slow opening/closing solenoid valve is recommended.

## Ground loop systems

There are many commonly specified designs for ground loop applications. Typical designs include vertical loops and horizontal loops. In some applications, water is piped from the ground or lake directly to the water source heat pump. Piping is limited to the amount of pipe required to get the water from the source to the unit.

NOTE: When utilizing Aquazone water source heat pumps in ground loop systems, refer to design considerations in the ground water system section.

**Horizontal ground loop —** This system is used when adequate space is available and trenching can be easily accomplished. A series of parallel pipes are laid out in trenches 1 to 2 meters below the ground surface, and then backfilled. Often, multiple pipes are used to maximize the heat transfer capability of each trench. The amount of pipe and the size of the ground loop field are based on ground conditions, heating, and cooling requirements of the application and system design.

**Vertical ground loop —** This system is used in vertical borehole applications. This design is well suited for retrofit applications when space is limited or where landscaping is already complete and minimum disruption of the site is desired. The vertical ground loop system contains a single loop of pipe inserted into a hole. The hole is back-filled and grouted after the pipe is inserted. The completed loop is concealed below ground. The number of loops required depends on ground conditions, heating and cooling requirements, and the depth of each hole.

**Hybrid systems —** In some applications, it may be beneficial to incorporate a cooling tower into the ground loop system to reduce the overall cost. A hybrid system discards excess heat into the air and increases the cooling performance of the ground loop.

## Condensate drainage

**Venting —** Condensate lines should be properly vented to prevent fan pressure from causing water to hang up in the piping. Condensate lines should be pitched to assure full drainage of condensate under all load conditions. Chemical treatment should be provided to remove algae in the condensate pans and drains in geographical areas that are conducive to algae growth.

**Trapping —** Condensate trapping is an essential necessity on every water source heat pump unit. A trap is provided to prevent the backflow of moisture from the condensate pan and into the fan intake or downstream into the mechanical system. The water seal or the length of the trap depends on the positive or negative pressure on the drain pan. As a rule of thumb, the water seal should be sized for 1 mm for every 10 Pa of negative pressure on the unit. The water seal is the distance from the bottom of the unit condensate piping connection to the bottom of the condensate drain line run-out piping. Therefore, the trap size should be double the water seal dimension.

Each unit must be installed with its own individual trap, vent, and means to flush or blowout the condensate drain lines. Do not install units with a common trap or vent.

## Water conditioning

In some applications, maintaining proper water quality may require the use of higher corrosion protection for the water-to-refrigerant heat exchanger. Water quality varies from location to location and is unique for each job. Water characteristics such as pH value, alkalinity, hardness, and specific conductance are of importance when considering any WSHP application. Water typically includes impurities and hardness that must be removed. The required treatment will depend on the water quality as well as type of system. Water problems fall into three main categories:

1. Scale formation caused by hard water reduces the heat transfer rate and increases the water pressure drop through the heat exchanger. As water is heated, minerals and salts are precipitated from a solution and deposited on the inside surface of the pipe or tube.
2. Corrosion is caused by absorption of gases from the air coupled with water on exposed metal. Corrosion is also common in salt-water areas.
3. Organic growths such as algae can reduce the heat transfer rate by forming an insulating coating on the inside tube surface. Algae can also promote corrosion by pitting.

NOTE: In most commercial water loop applications, Aquazone™ WSHP units use copper water-to-refrigerant heat exchanger. Units can also be equipped with a cupronickel heat exchanger for applications where water is outside the standard contaminant limits for a copper heat exchanger.

# Application data (cont)

## WATER QUALITY GUIDELINES

| CONDITION | HX MATERIAL* | CLOSED RECIRCULATING† | OPEN LOOP AND RECIRCULATING WELL** |
|---|---|---|---|
| **Scaling Potential — Primary Measurement** | | | |
| Above the given limits, scaling is likely to occur. Scaling indexes should be calculated using the limits below. | | | |
| pH/Calcium Hardness Method | All | N/A | **pH < 7.5 and Ca Hardness, <100 ppm** |
| **Index Limits for Probable Scaling Situations (Operation outside these limits is not recommended.)** | | | |
| Scaling indexes should be calculated at 150 F for direct use and HWG applications, and at 90 F for indirect HX use. A monitoring plan should be implemented. | | | |
| Ryznar Stability Index | All | N/A | **6.0 - 7.5**<br>If >7.5 minimize steel pipe use. |
| Langelier Saturation Index | All | N/A | **–0.5 to +0.5**<br>If <–0.5 minimize steel pipe use.<br>Based upon 150 F HWG and direct well, 85 F indirect well HX. |
| **Iron Fouling** | | | |
| Iron $Fe^{2+}$ (Ferrous) (Bacterial Iron Potential) | All | N/A | **<0.2 ppm (Ferrous)**<br>If $Fe^{2+}$ (ferrous) >0.2 ppm with pH 6 - 8, $O_2$<5 ppm check for iron bacteria. |
| Iron Fouling | All | N/A | **<0.5 ppm of Oxygen**<br>Above this level deposition will occur. |
| **Corrosion Prevention††** | | | |
| pH | All | 6 - 8.5<br>Monitor/treat as needed. | **6 - 8.5**<br>Minimize steel pipe below 7 and no open tanks with pH <8. |
| Hydrogen Sulfide ($H_2S$) | All | N/A | **<0.5 ppm**<br>At $H_2S$>0.2 ppm, avoid use of copper and cupronickel piping or HXs.<br>Rotten egg smell appears at 0.5 ppm level.<br>Copper alloy (bronze or brass) cast components are okay to <0.5 ppm. |
| Ammonia Ion as Hydroxide, Chloride, Nitrate and Sulfate Compounds | All | N/A | **<0.5 ppm** |
| Maximum Chloride Levels | | | Maximum allowable at maximum water temperature. |
| | | | 50 F (10 C) / 75 F (24 C) / 100 F (38 C) |
| | Copper | N/A | <20 ppm / NR / NR |
| | Cupronickel | N/A | <150 ppm / NR / NR |
| | 304 SS | N/A | <400 ppm / <250 ppm / <150 ppm |
| | 316 SS | N/A | <1000 ppm / <550 ppm / <375 ppm |
| | Titanium | N/A | >1000 ppm / >550 ppm / >375 ppm |
| **Erosion and Clogging** | | | |
| Particulate Size and Erosion | All | <10 ppm of particles and a maximum velocity of 6 fps. Filtered for maximum 800 micron size. | <10 ppm (<1 ppm "sandfree" for reinjection) of particles and a maximum velocity of 6 fps. Filtered for maximum 800 micron size. Any particulate that is not removed can potentially clog components. |
| Brackish | All | N/A | Use cupronickel heat exchanger when concentrations of calcium or sodium chloride are greater than 125 ppm are present. (Seawater is approximately 25,000 ppm.) |

LEGEND

**HWG** — Hot Water Generator
**HX** — Heat Exchanger
**N/A** — Design Limits Not Applicable Considering Recirculating Potable Water
**NR** — Application Not Recommended
**SS** — Stainless Steel

*Heat exchanger materials considered are copper, cupronickel, 304 SS (stainless steel), 316 SS, titanium.

†Closed recirculating system is identified by a closed pressurized piping system.

**Recirculating open wells should observe the open recirculating design considerations.

††If the concentration of these corrosives exceeds the maximum allowable level, then the potential for serious corrosion problems exists.

Sulfides in the water quickly oxidize when exposed to air, requiring that no agitation occur as the sample is taken. Unless tested immediately at the site, the sample will require stabilization with a few drops of one Molar zinc acetate solution, allowing accurate sulfide determination up to 24 hours after sampling. A low pH and high alkalinity cause system problems, even when both values are within ranges shown. The term pH refers to the acidity, basicity, or neutrality of the water supply. Below 7.0, the water is considered to be acidic. Above 7.0, water is considered to be basic. Neutral water contains a pH of 7.0.

To convert ppm to grains per gallon, divide by 17. Hardness in mg/l is equivalent to ppm.

## Acoustical design

Sound power levels represent the sound as it is produced by the source, the WSHP unit, with no regard to attenuation between the source and the space. Acoustical design goals are necessary to provide criteria for occupied spaces where people can be comfortable and communicate effectively over the background noise of the air-conditioning system and other background noise sources.

Acoustical design goals are desirable sound pressure levels within a given conditioned space and are represented by noise criteria (NC) curves. Noise criteria curve levels represent a peak over a full spectrum of frequencies. A high value in a low frequency band has the same effect on NC level as a lower value in a high frequency band. It is important that sound levels be balanced over the entire spectrum relative to the NC curve. The lower the NC criteria curve, the more stringent the room acoustical design must be to meet the design goals.

It is important to know how to convert NC levels from the unit ratings in terms of sound power (Lw). This conversion depends on the specifics of the acoustical environment of the installation.

The resulting calculations are compared to the NC curve selected for the area to assess the acoustical design.

Some of the factors that affect conversion of sound power to sound pressure and consequent NC level include:

- Type of acoustical ceiling
- Use of metal or flex duct
- Absorption in the occupied space
- Location in the occupied space
- Open or closed layout plan
- Use of open or ducted returns
- Orientation of unit to occupant
- Use of lined or unlined duct

**OCTAVE BAND SOUND PRESSURE LEVEL (Lp) ASSOCIATED WITH NC CURVES**

| NOISE CRITERIA CURVES | OCTAVE BAND SOUND PRESSURE LEVEL (Lp) Frequency (Hz) | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 |
| NC-15 | 49 | 36 | 26 | 17 | 17 | 14 | 12 | 11 |
| NC-20 | 52 | 41 | 33 | 27 | 22 | 19 | 17 | 16 |
| NC-25 | 54 | 45 | 38 | 31 | 27 | 24 | 22 | 21 |
| NC-30 | 58 | 49 | 41 | 36 | 31 | 29 | 28 | 27 |
| NC-35 | 61 | 53 | 45 | 40 | 36 | 34 | 33 | 32 |
| NC-40 | 64 | 57 | 50 | 45 | 41 | 39 | 38 | 37 |
| NC-45 | 67 | 61 | 54 | 49 | 46 | 44 | 43 | 42 |
| NC-50 | 71 | 64 | 58 | 54 | 51 | 49 | 48 | 47 |
| NC-55 | 74 | 68 | 63 | 58 | 56 | 54 | 53 | 52 |
| NC-60 | 77 | 71 | 67 | 63 | 61 | 59 | 58 | 57 |
| NC-65 | 80 | 75 | 71 | 68 | 66 | 64 | 63 | 62 |

## WSHP sound control

The analysis of the projected sound level in the conditioned space caused by a WSHP unit located in a ceiling plenum is quite involved. The key is to have good sound power ratings (Lw) in dB on the equipment to determine the sound attenuation effect of the ductwork, ceiling and room. In combination with utilizing standard Aquazone™ equipment attenuating features or the advanced mute package features, suggestions for unit sound design are provided to design around the WSHP units.

Use the following guidelines for layout of Aquazone WSHP units to minimize noise:

1. Obtain sound power ratings in accordance with latest standards from manufacturers to select quietest equipment.
2. Do not locate units over a space with a required NC of 40 or less. Instead, locate units above less sensitive noise areas such as above or in equipment rooms, utility closets, restrooms, storage rooms, or above corridors.
3. Provide at least 3 meters between WSHP units to avoid the additive effect of two noise sources.
4. Provide an acoustical pad underneath the WSHP unit in applications where the unit must be mounted above noise sensitive areas such as private offices or conference rooms. The pad attenuates radiated noise. Be sure the pad has an area at least twice that of the WSHP footprint.
5. Maximize the installed height above the suspended ceiling.
6. Be sure the WSHP unit is located at least 2 meters away from any ceiling return grille to prevent line-of-sight casing noise to reach the space below.
7. Suspend the WSHP unit from the ceiling with hangers that utilize spring or neoprene type isolators to reduce vibration transmission.
8. Utilize flexible electrical connections to the WSHP unit. DO NOT USE NOT RIGID CONNECTIONS.
9. Utilize flexible loop water and condensate piping connections to the WSHP unit.
10. Use a canvas duct connector to connect the WSHP discharge to the downstream duct system. This reduces vibration-induced noise.
11. Provide acoustic interior lining for the first 6 meters of discharge duct, or until the first elbow is reached. The elbow prevents line-of-site sound transmission in the discharge duct.
12. Provide turning vanes in ductwork elbows and tees to reduce air turbulence.
13. Size the sheet metal supply duct with velocities no greater than 5 m/s.
14. Ensure ductwork is rigid.
15. Use round duct whenever possible to further reduce noise.
16. Allow at least 3 equivalent duct diameters of straight duct upstream and downstream of the unit before allowing any fittings, transitions, etc.
17. Seal all penetrations around duct entering the space.
18. Provide a 2 m run-out duct made of flexible material to connect a diffuser to the supply trunk duct. The flex duct provides an “attenuating end-effect” and reduces duct-transmitted sound before it reaches the

space. Typically a 6 dB sound reduction can be accomplished with the use of flex duct.

19. Locate the run-out duct balancing damper as far away from the outlet diffuser as possible. Locating the balancing damper at the trunk duct exit is the best location.
20. If return air is drawn through a ceiling plenum, provide an acoustically lined return duct elbow or "L" shaped boot at the WSHP to eliminate line-of-sight noise into the ceiling cavity and possible through ceiling return air grilles. Face the elbow or boot away from the nearest adjacent WSHP unit to prevent additive noise.
21. Do not hang suspended ceiling from the ductwork.

If installing unit in small equipment rooms or closets, the following additional guidelines apply:

1. Mount the unit on a pad made of high-density sound absorbing material such as rubber or cork. Extend the pad beyond the WSHP unit footprint by at least 155 mm in each direction.
2. Since the unit returns airflow through a grille mounted in a closet door, provide a sound barrier or some other modification of the closet to prevent line-of-site noise into the space.
3. Follow good duct design practice in sizing and locating the connection of the WSHP discharge to the supply duct system. Use an elbow with turning vanes and bent in the direction of the fan rotation to minimize turbulence. Make any duct transitions as smooth and as gradual as possible to again minimize turbulence and loss of fan static pressure.

### Solenoid valves

In applications using variable flow pumping, solenoid valves can be field installed and operated from the control board in the Aquazone™ WSHP unit.

**OPERATING LIMITS**

| AIR LIMITS | COOLING (C) | HEATING (C) |
|---|---|---|
| **Minimum Ambient Air db** | 10 | 10 |
| **Rated Ambient Air db** | 27 | 20 |
| **Maximum Ambient Air db** | 38 | 29 |
| **Minimum Return Air db/wb** | 18/15 | 16 |
| **Maximum Return Air db/wb** | 43/28 | 29 |
| **WATER LIMITS** | | |
| **Standard Unit** | | |
| **Minimum Entering Water*** | 10 | 16 |
| **Maximum Entering Water** | 49 | 43 |
| **Extended Range Unit†** | | |
| **Minimum Entering Water*** | –1 | –6.7 |
| **Maximum Entering Water** | 49 | 43 |

LEGEND

**db** — Dry Bulb
**wb** — Wet Bulb

*Requires optional insulation package when operating below the dew point.
†With antifreeze, optional extended range insulation and low temperature cutout jumper clipped for antifreeze.

### Freeze protection

Applications where systems are exposed to outdoor temperatures below freezing (0° C) must be protected from freezing. The most common method of protecting water systems from freezing is adding glycol concentrations into the water. Design care should be used when selecting both the type and concentrations of glycol utilized due to the following:

- Equipment and performance may suffer with high concentrations of glycol and other antifreeze solutions
- Loss of piping pressure may increase greatly, resulting in higher pumping costs
- Higher viscosity of the mixture may cause excess corrosion and wear on the entire system
- Acidity of the water may be greatly increased, promoting corrosion
- Glycol promotes galvanic corrosion in systems of dissimilar metals. The result is corrosion of one metal by the other, causing leaks.

# Guide specifications

## Commercial Vertical Water Source Heat Pump Units with Puron® Refrigerant (R-410A)

**HVAC Guide Specifications**

Size Range: **22,091 to 80,129 W Cooling Capacity**
**26,876 to 97,304 W Heating Capacity**

Carrier Model Number: **50VQP**

**Part 1 — General**

1.01 SYSTEM DESCRIPTION

A. Heat pump units are designed to operate with 16 to 35 C water temperature or –7 to 49 C water temperature when the extended range option is selected. Units shall consist of high-efficiency scroll compressor(s) and shall have 2 independent refrigeration circuits where appropriate. The air discharge and return are as specified on drawings.

B. Units shall be individually packaged with wooden skid covered with protective corner posts and plastic stretch wrapping for maximum protection.

1.02 QUALITY ASSURANCE

A. Basic unit shall be rated and certified in accordance with AHRI/ISO/ASHRAE Standards.

B. Units shall have insulation and adhesive which meet NFPA 90A requirements for flame spread and smoke generation, and assembled units shall be ETL certified, US and Canada, and meet UL-181 standards.

C. Units shall be factory tested under normal operating conditions at nominal water flow rates to assure proper operation of all components and safety devices.

D. Units shall be CE mark certified.

**Part 2 — Product**

2.01 EQUIPMENT

A. Heat Pump Assembly:

Factory-tested and assembled single-piece water source heat pump units shall be factory wired, charged with Puron refrigerant (R-410A), contain refrigerant-to-water heat exchanger, refrigerant-to-air heat exchanger, 4-way reversing valve, fan motor assembly, compressor, metering device, and all internal controls and safety devices.

B. Unit Cabinet:

1. Unit shall be constructed of heavy gage galvanized sheet metal with powder coat paint finish and with removable service panels, hanging brackets, and insulated galvanized steel condensate pan of welded construction.
2. Supply and return water connections shall be copper FTP, flush-mounted and rigidly connected to prevent damage to tubing and/or noise generation.
3. Cabinet construction shall permit service testing without air bypass on coil and shall incorporate factory-installed supply ductwork connections. Direct connection to fan housing is not recommended due to sound considerations.
4. Unit shall have separate entrances for high and low-voltage electrical supplies.
5. One-in. wide filter bracket and 25 mm fiberglass disposable filter shall be provided on each unit.
6. All interior surfaces shall be lined with 25 mm thick, 24 kg/$m^3$ density acoustic type fiberglass insulation. All fiberglass shall be coated and all edges shall be tucked under flanges to prevent the introduction of glass fibers in the airstream.

C. Fan and Motor Assembly:

1. Units shall have belt driven single or dual centrifugal fans. The fan motor shall be permanently lubricated with internal overload protection.
2. Fan motor shall be isolated from the fan housing by flexible rubber isolation grommets.

D. Compressors:

Unit shall have heat pump duty, high-efficiency scroll compressor(s) with internal and external isolation.

E. Heat Exchangers:

1. Refrigerant-to-air coil shall be aluminum/copper finned-tube construction type rated for 625 psig and shall be fully degreased at the factory to prevent possible condensate blowoff.
2. Refrigerant-to-water heat exchanger shall be steel/copper tube-in-tube type rated for 4309 kPa psig refrigerant, 3447 kPa water-side pressures.
3. Optional steel/cupronickel refrigerant-to-water heat exchanger shall be used for open loop applications, or where water quality cannot be maintained as specified by manufacturer.

F. Refrigerant Components:

1. Refrigeration circuit components shall include liquid line service valve, suction line service valve, reversing valve, a full charge of compressor oil, and a holding charge of refrigerant.
2. Thermostatic expansion valve shall be provided for refrigerant metering.

G. Controls and Safeties:

1. Safety devices on all units shall include low-pressure sensor or loss-of-charge switch, high-pressure switch, low water temperature sensor, and condensate overflow switch.
2. The standard Complete C electronic control system shall interface with a heat pump (Y,O) wall thermostat (mechanical or electronic). The control system shall have the following features:
   a. 75 VA transformer.
   b. Anti-short cycle time delay on compressor operation; time delay shall be 5 minutes minimum.

c. Random start on power-up.
d. Low voltage protection.
e. High voltage protection.
f. Condensate overflow shutdown.
g. Unit shutdown on low refrigerant pressures.
h. Unit shutdown on high or low water temperature (selectable for antifreeze solutions).
i. Option to reset unit at thermostat or disconnect. Fault type shall be retained in memory if reset at thermostat.
j. Automatic intelligent reset. Unit shall automatically restart 5 minutes after shutdown if the fault has cleared. Should a fault occur 3 times sequentially, then lockout will occur.
k. Ability to defeat time delays for servicing.
l. Light-emitting diode (LED) to indicate high pressure, low pressure, improper voltage, water coil freeze protection, air coil freeze protection, condensate overflow, and control status.
m. Unit Performance Monitor to indicate inefficient operating conditions prior to unit lockout.
n. Remote fault type indication at thermostat.
o. Single harness connection for all safety devices.
p. Selectable 24-v or pilot duty dry contact alarm output.
q. 24-v output to cycle a motorized water valve with compressor contactor.

3. The optional Deluxe D electronic control shall have all the features of the Complete C control, with the following additional features:
   a. A removable thermostat connector.
   b. Random start on return from night setback.
   c. Minimized reversing value operation for extended life and quiet operation.
   d. Night setback control from low temperature thermostat, with 2-hour override initiated by a momentary signal from the thermostat.
   e. Dry contact night setback output for digital night setback thermostats.
   f. Ability to work with heat/cool (Y, W) thermostats.
   g. Ability to work with heat pump thermostats using O or B reversing valve control.
   h. Single grounded wire to initiate night setback or emergency shutdown.
   i. Boilerless system control can switch automatically to electric heat at low loop water temperature.
   j. Control board shall allow up to 3 units to be operated from one thermostat without any auxiliary controls.
   k. A relay to operate an external damper. The control to be such that the damper will not open until 30 minutes after the unit comes back from Unoccupied mode.
   l. A relay to restart a central pump or control a 24-v motorized water valve.
4. PremierLink™ Controller:

   This control will function with Carrier Comfort Network® (CCN) and ComfortVIEW™ software. It shall also be compatible with *Comfort*Link™ controllers. It shall be ASHRAE 62 compliant and Internet ready. It shall accept a $CO_2$ sensor in the conditioned space and be demand control ventilation (DCV) ready. The communication rate must be 38.4K or faster. It shall include an integrated economizer controller.
5. LonWorks Interface System:

   Units shall have all features listed above (either Complete C or Deluxe D) and the control board shall be supplied with a LonWorks interface board, which is LONMark certified. This will permit all units to be daisy chained via a 2-wire twisted pair shielded cable. The following points must be available at a central or remote computer location:
   a. space temperature
   b. leaving-water temperature
   c. discharge-air temperature
   d. command of space temperature set point
   e. cooling status
   f. heating status
   g. low temperature sensor alarm
   h. low pressure sensor alarm
   i. high pressure switch alarm
   j. condensate sensor alarm
   k. high/low voltage alarm
   l. fan "ON/AUTO" position of space thermostat
   m. unoccupied / occupied command
   n. cooling command
   o. heating command
   p. fan "ON / AUTO" command
   q. fault reset command
   r. itemized fault code revealing reason for specific shutdown fault (any one of 7)

   This option also provides the upgraded 75 va control transformer with load side short circuit and overload protection via a built-in circuit breaker.

H. Electrical:
1. A control box shall be located within the unit compressor compartment and shall contain a 75 va transformer, 24-volt activated, 3-pole compressor contactor, terminal block for thermostat

wiring and solid-state controller for complete unit operation. Electro-mechanical operation WILL NOT be accepted.

2. Units shall be nameplated for use with time-delay fuses or HACR circuit breakers.
3. Unit controls shall be 24-volt and provide heating or cooling as required by the remote thermostat.

I. Sound Attenuation Package (Mute Package):

Consists of attenuation material that is applied to the cabinet to reduce noise. Attenuation material shall be applied to the basepan, compressor access panels, and blower housing.

J. High-Static Blower:

The optional high-static blower provides increased airflow at various static pressure conditions.

K. Special Features:

1. Aquazone™ Thermostat Controls:
   a. Programmable multi-stage thermostat offers 7-day clock, holiday scheduling, large backlit display and remote sensor capability.
   b. Programmable 7-day light-activated thermostat offers occupied comfort settings with lights on, and unoccupied energy savings with lights off.
   c. Programmable 7-day flush-mount thermostat offers locking coverplate with tamper-proof screws, flush to wall mount, dual point with adjustable deadband, O or B terminal, and optional remote sensor.
   d. Programmable 5-day thermostat offers 2-stage heat, 2-stage cool, auto changeover, 5-minute built-in compressor protection, and included locking cover.
   e. Non-programmable thermostat offers 2 heat stages, 2 cool stages, auto changeover, 5-minute built-in compressor protection, and included locking cover.
2. Filters:

   Filters are available in 51 mm or 102 mm (MERV 8) sizes.
3. Filter Rack:

   Filter rack for 25, 51, or 102 mm filters enhances the filtration system of the water source heat pump.

   NOTE: Filter rack does not include filters.
4. Fire-Rated Hose Kits:

   Kits include a fixed MPT on one end and a swivel with an adapter on the other end. Hose kits can be either stainless steel or galvanized.
5. Ball Valves (Brass Body):

   Valves are for shutoff and balancing water flow. Available with memory, memory stop, and pressure temperature ports.
6. Y Strainers (Bronze Body):

   Strainers are "Y" type configuration with a brass cap. Maximum operating pressure rating of strainers is 3103 kPa. Strainer screen made of stainless steel.
7. Solenoid Valves (Brass Body):

   Valves provide slow operation for quiet system application.
8. Hose Kit Assemblies:

   Assemblies include a ported ball valve with pressure temperature (P/T) plug ports and flexible stainless steel hose with swivel and nipple. Return hose includes a ball valve, preset measure flow (gpm) with two P/T ports, and flexible stainless steel hose with a swivel and nipple.
9. PremierLink™ Accessories:

   Accessories include supply air temperature sensors, communicating room sensors, $CO_2$ sensors, and linkage thermostats to provide a fully integrated DDC (direct digital control) system.
10. Extended Range:

    Extended range units provide an insulated water circuit for the coaxial coil and refrigerant circuit to prevent condensation, and therefore potential dripping problems, in applications where the entering water temperature is beyond the normal operating range.
11. LON wall sensors are available in 3 models: sensor only, sensor with status override indicator, and sensor with set point, status adjustment override, and digital LCD display.

**Manufacturer reserves the right to discontinue, or change at any time, specifications or designs without notice and without incurring obligations.**

Catalog No. 04-52500061-01 Pg 52 Printed in U.S.A. Form 50VQP-C1PD
Replaces: New